

Addendum 4 – Attachment 1

SECTION 3 – Evaluation and Qualification Criteria

(Note - Changes to this Clause replaces one in original bid document)

1.2.4 Functional Guarantees of the facilities

For the purposes of evaluation adjustments as detailed below will be made to the bid price:-

- For each kW (or part thereof) that the guaranteed power station output is above or below the Employer's specified minimum acceptable level:- capitalized over a 15 year period using an energy value of US\$0.30c/kWh, a 10% cost of capital and the Bidders' guaranteed efficiency of gasifier; efficiency of prime mover; and efficiency of alternator and Availability Factor. for the purposes of this evaluation it will be assumed that the feedstock will be available 100% of the time.

Employer's minimum performance levels are:

- a. Gasifier efficiency; 75%
- b. Gas to mechanical energy of prime mover, 25%
- c. Alternator efficiency, 95%
- d. Availability factor, 70%