## **ELECTRIC POWER CORPORATION**

Level 5 Tuiatua Tupua Tamasese Efi Building Apia Samoa



Telephone: (685) 65400
Facsimile: (685) 23 748
E-mail: info@epc.ws
Website: www.epc.ws

PO Box: 2011

16<sup>th</sup> March 2018

To: BIDDERS

Subject: SAM EPC LALOM/01 - 2018

Addendum No. 4

No	Question/ Query Date Issued		EPC Response	Addendum	
				No	
1	Minutes of pre-bid Meeting on March 5 <sup>th</sup> 2018	9 <sup>th</sup> Mar 18	To be distributed later	1	
2	Bid Form	9 <sup>th</sup> Mar 18	Attached	1	
3	Bidders' request to extend bid closing date due to	9 <sup>th</sup> Mar 18	Request is approved. Bid closing date is changed to Monday	1	
	slight delay in receiving bid documents.		2 <sup>nd</sup> April 2018 at 10am, local time.		
4	Supply and installation of local supply transformer	14 <sup>th</sup> Mar 18	This item is included in Lot 1, not Lot 2.	2	
5	Minutes of pre bid meeting held on	14 <sup>th</sup> Mar 18	Attached minutes of pre bid meeting	2	
6	Second extension of bid closing date	15 <sup>th</sup> Mar 18	Because April 2 <sup>nd</sup> is a public holiday; Easter Monday, you	3	
			are informed that bid closing date is further extended to		
			10am local time on Monday 9 <sup>th</sup> April 2018.		
7	EPC bank details to wife payments to for bid	16 <sup>th</sup> Mar 18	Here is EPC Bank details to wire payments for bid	4	
	document		documents		
8	Drawings	16 <sup>th</sup> Mar 18	As built drawings of Taelefaga hydro system can be	4	
			obtained by connecting to Zoom Inform me if you have		
			problem accessing drawings via Zoom.		
9	Access to present O&M Manual of the plant	16 <sup>th</sup> Mar 18	To be provided	4	
10	Questions	16 <sup>th</sup> Mar 18	Refer to attached questions and answers	4	

1.	Only Electronic Governor system need			
	to change or we have to change			
	Hydraulic system also including			
	Hydraulic valves, Nitrogen			
	Accumulators.			
2.	Please provide detailed technical			
	requirement of Electronic Governor			
	system, such as which PLC make, for			
	communication with SCADA what			
	communication protocol to be used.			
3.	If Hydraulic System to be changed,			
	please provide operating pressure			
	rating of the system.			
4.	Whether Servomotors need to be			
	changed?			
5.	Please provide the previous control system drawings, for reference.			
6.	Please confirm which signals are to be			
	sent to SCADA system.			
7.	Please confirm, Main Inlet Valve			
	control is not thru Governor Control			
	Panel and Hydraulic system of			
	Governor.			

Please sign and return acknowledgement form.

Sincerely



Fonoti Perelini S. Perelini Project Manager Project Management Unit

## Attachment

Questions and Answers

## Copy to:

- GM EPC
- Soteria, Secretary, Government Tender Board
- File

## **ACKNOWLEDGEMENT FORM**

Bid: SAM EPC LALOM /01 - 2018 – "Rehabilitation of Lalomauga Hydro Plant"

Bidder Name:								
We confirm receiving this Addendum 4								
Signed by:								

Name of Authorized Person