



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUAHAN
P.O. BOX 2977 AGANA, GUAM U.S.A. 96932-2977

May 16, 2018

AMENDMENT NO.: II

TO

INVITATION FOR BID NO.: GPA-072-18

FOR

RELAY TEST EQUIPMENT

Prospective Bidders are hereby notified of the following response to inquiry received from America's Best ElectricMart dated May 11, 2018:

QUESTION:

1. Will the Megger alternative (SMRT410-41P0F0A0S1) be accepted for GPA-072-18?

ANSWER:

The test equipment must be compatible with the CMC test universe software and Omicron test library.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.


JOHN M. BENAVENTE, P.E.
General Manager