



EXPLANATORY NOTICE – 2nd RELEASE

**POWER STATION SWITCHGEAR REPLACEMENT
PROJECT - CK171831**

Closing Date and Time: 3pm (CI Time) 1st June 2018

ITEM	EXPLANATORY NOTICES
1.	<p>Commissioning and installation assistance</p> <p>Installation is by the Principal with the Tenderer to provide on-site installation supervision and commissioning assistance as detailed in Attachment 1 – Technical Specification and Drawings, Section 5 On site Commissioning and Installation Assistance. This is also covered in Tender schedules to be submitted, item 24.1.</p>
2.	<p>Tender submission</p> <p><u>Please note the following:</u></p> <ol style="list-style-type: none"> 1. Both hard copies and electronic copies of the tender are required as per the tender documents. 2. Amendment - All submissions will be considered if electronic submissions are received by the closing date and the posted hard copies receipt from courier, is before the tender closing time and date.
3.	<p>Tender evaluation</p> <ol style="list-style-type: none"> 1. All tenders received will be evaluated provided that; <ol style="list-style-type: none"> a) With exceptions to point 2 (Amendment) above, all mandatory conditions set out in section 3 or 4.2 of this RFT are met and; b) All tenders that meets the mandatory conditions will be evaluated based on evaluation criteria set out in section 4.3 of this RFT.
4.	<p>Equipment/service delivery</p> <p>Timeline for equipment/service delivery is for tenderers to confirm in their workplans.</p>

Powering the Future

5.	Test facility on revenue meter EDMI Energy Meter test disconnect sliding link terminals with test plug capability fitted to the terminal may be used. Weidmuller Type WLT6/STB is the preferred terminal option, refer to Attachment 1 Technical Specifications and Drawings Section 4.4.3 – Terminals. Tenderer to clearly identify option proposed in tender response.
6.	Protection relays and metering equipment's The Principal, TAU will not supply protection relays and metering equipment's under this RFT.
7.	Tender due date amendment New tender due date is <u>3pm, Friday 15th June 2018 (CI Time)</u>