



American Samoa Power Authority

P.O. Box PPB

Pago Pago, American Samoa 96799

Telephone: (684) 699-1234/248-1234

Email: info@aspower.com & Website: www.aspower.com



ISSUANCE DATE: October 10, 2018

RFQ NO.: RFQ No. ASPA18.053.ESD-WTR "MANU'A TANK REPLACEMENT PROJECT MATERIALS AND QA/QC SERVICES (Re-bid)

SUBJECT: Addendum No. 2

The American Samoa Power Authority hereby issues Addendum No. 2 to amend Request for Quotes (RFQ) requirements. This addendum is issued pursuant to the conditions of the RFQ documents and is hereby made part of the RFQ. The addendum serves to clarify, revise, and supersede information contained in the RFQ. The Offeror must acknowledge receipt of this addendum in the appropriate space provided in the Addendum Form. Failure to do so may subject the Offeror to disqualification.

- 1. The Closing date for this RFQ has been extended from Wednesday, October 10, 2018 to Wednesday, October 17, 2018 at 2:00 p.m. American Samoa Time.**

In addition to this Addendum No. 2 to the Request for Quotes (RFQ) for RFQ NO. ASPA18.053.ESD.WTR – "MANU'A TANK REPLACEMENT PROJECT MATERIALS AND QA/QC SERVICES (Re-bid) issued by the American Samoa Power Authority to respond to questions received from potential Offerors submitted. This Addendum No. 2 is hereby incorporated into the RFQ:

2. QUESTIONS RECEIVED FROM POTENTIAL OFFERORS:

Q-1: Does we need to be an American Samoa company or need to have American Samoa business license in order to bid? We do understand that it is indicated on the general terms and conditions but we just need to clarify this further.

A-1: **No, you do not.**

Q-2: Reference to attachment B -Quotation Form title states" Supply & Delivery of Discharge Piping, Valves and Fitting for Manu'a Tank Replacement Project" but the quotation form is for tanks supply. Please confirm if we need to include these materials. Attachment G (Existing tank data) shows said parts but need to confirm the extent if we need to include? Or this is just a typo error?

A-2: **This is for Tanks only.**

Q-3: Spec section 1.01.B.2 states tanks larger than 36 ft requires Alum Dome roofs. Since these tanks are 21 ft dia that a glass fused to steel knuckle roof would be acceptable?

A-3: **Knuckle roofs will be considered by ASPA as long as it meets the load requirements in the specifications**

Q-4: Ref to PRE-QUOTATION QUESTIONS indicates "Any pre-Quotation questions and/or clarifications shall be submitted in writing to the Procurement Office via bids@aspower.com through electronic mail or in hard copy. All pre-Quotation questions must be received no later than 4:00 p.m. on August 10, 2018. After that time,

ASPA will issue addenda to address any questions and/or clarifications as may be necessary on August 16, 2018." The bid invitation was issued September 12, 2018 and please let us know if there's new timeline.

A-4: An Addendum was issued to change dates for pre-quotation questions. This new addendum will address all inquiries. All interested bidders will be notified accordingly. New deadline for questions are set to end on September 27, 2018. Addendum to address all questions is included in this Addendum No. 2.

Q-5: General Conditions (Item 1.2 and 13) implies that this RFQ is CIF – ASPA Tafuna warehouse. Quote form indicates CIF – American Samoa port in Fagatogo only. Please confirm which is correct? If this will be CIF-ASPA Tafuna warehouse, aside from the 8% excise tax indicated, confirm percentage (%) cost for customs fees? Also, are there other fees to include? Note that it is our understanding that if it CIF ASPA warehouse, we have to include import duty and all other taxes.

A-5: CIF ASPA Tafuna warehouse is preferred but not a requirement. Please go ahead with CIF Pago Pago.

Should you have any questions or need clarification, please call me at 248-1247.

Sincerely,

 2018 October 10

Ioana S. Uli
Procurement Manager

Please sign and date below to acknowledge receiving Addendum 2. You may return this document via email to the ASPA Procurement Office at bids@aspower.com.

ACKNOWLEDGEMENT OF RECEIVING ADDENDUM 2

Received by _____, this _____ day of October, 2018.

Company _____ Title _____

Phone No. _____ Email Address _____