


POLE SCHEDULE									
POLE NO.	POLE DESCRIPTION WOOD/CONC OR EXIST	POLE LENGTH STRENGTH m/kN	SPAN m	ANGLE OF DEVIATION IN DEG.	POLE TOP DESCRIPTION OR DRESSINGS	STAYS			REMARKS
						GRND	FLY	FLY +GRND	
A	EXIST.	EXIST.	-	-	EXIST + 14A				EXIST + PROP 1Ø HV
1	CONC.	10.2/6	80	30	14A	1			PROP 1Ø HV ONLY
2	CONC.	10.2/6	85	30	14A	1			" " " " " " " " " "
3	CONC.	10.2/6	80	20	12A	1			" " " " " " " " " "
4	CONC.	10.2/6	80	30	14A	1			" " " " " " " " " "
5	CONC.	10.2/6	50	30	14A	1			" " " " " " " " " "
6	CONC.	10.2/6	75	40	14A	1			" " " " " " " " " "
7	CONC.	10.2/6	80	10	11A				" " " " " " " " " "
8	CONC.	10.2/6	60	50	14A	1			" " " " " " " " " "
9	CONC.	10.2/6	130	90	13A+13A	2			" " " " " " " " " "
10	CONC.	10.2/6	90	60	14A	1			" " " " " " " " " "
11	CONC.	10.2/6	45	55	14A	1			" " " " " " " " " "
12	CONC.	10.2/6	70	20	12A		1		" " " " " " " " " "
13	CONC.	10.2/6	85	5	11A				" " " " " " " " " "
14	CONC.	10.2/6	65	25	12A	1			" " " " " " " " " "
15	CONC.	10.2/6	75	40	14A	1			" " " " " " " " " "
16	CONC.	10.2/6	100	45	14A	1			" " " " " " " " " "
17	CONC.	10.2/6	90	30	14A		1		" " " " " " " " " "
18	CONC.	10.2/6	80	75	13A+13A	2			" " " " " " " " " "
19	CONC.	10.2/6	70	65	14A	2			" " " " " " " " " "
20	CONC.	10.2/6	70	10	11A				" " " " " " " " " "
21	CONC.	10.2/6	60	65	14A	2			" " " " " " " " " "
22	CONC.	10.2/6	75	95	13A+13A	2			" " " " " " " " " "
23	CONC.	10.2/6	85	60	14A	1			" " " " " " " " " "
24	CONC.	10.2/6	80	30	14A	1			" " " " " " " " " "
25	CONC.	10.2/6	70	70	13A+13A	2			" " " " " " " " " "
26	CONC.	10.2/6	50	30	14A		1		" " " " " " " " " "
27	CONC.	10.2/6	90	5	11A				" " " " " " " " " "
28	CONC.	10.2/6	65	65	14A	1			" " " " " " " " " "
29	CONC.	10.2/6	70	30	14A	1			" " " " " " " " " "
30	CONC.	10.2/6	80	25	12A	1			" " " " " " " " " "
31	CONC.	10.2/6	80	20	12A	1			" " " " " " " " " "
32	CONC.	10.2/6	60	15	12A	1			" " " " " " " " " "
33	CONC.	10.2/6	60	10	11A				" " " " " " " " " "
34	CONC.	10.2/6	80	20	12A		1		" " " " " " " " " "
35	CONC.	10.2/6	70	20	12A	1			" " " " " " " " " "
36	CONC.	10.2/6	60	5	11A				" " " " " " " " " "
37	CONC.	10.2/6	80	15	12A	1			" " " " " " " " " "
38	CONC.	10.2/6	50	10	11A	1			" " " " " " " " " "
39	CONC.	10.2/6	115	30	14A	1			" " " " " " " " " "
40	CONC.	10.2/6	70	75	13A+13A	2			" " " " " " " " " "
41	CONC.	10.2/6	75	15	12A	1			" " " " " " " " " "
42	CONC.	10.2/6	105	10	11A		1		" " " " " " " " " "
43	CONC.	10.2/6	70	30	14A	1			" " " " " " " " " "
44	CONC.	10.2/6	70	10	11A		1		" " " " " " " " " "
45	CONC.	10.2/6	90	50	14A	1			" " " " " " " " " "
46	CONC.	10.2/6	70	25	12A	1			" " " " " " " " " "
47	CONC.	10.2/6	70	35	14A	1			" " " " " " " " " "
48	CONC.	10.2/6	75	0	11A				" " " " " " " " " "
49	CONC.	11.0/5	70	10	19A				PROP 1Ø HV + PROP ABS
50	CONC.	10.2/6	80	35	14A	1			PROP 1Ø HV ONLY
51	CONC.	10.2/6	75	0	11A				" " " " " " " " " "
52	CONC.	10.2/6	80	5	11A				" " " " " " " " " "
53	CONC.	10.2/6	80	5	11A				" " " " " " " " " "
54	CONC.	10.2/6	90	20	12A	1			" " " " " " " " " "
55	CONC.	10.2/6	80	50	14A	1			" " " " " " " " " "
56	CONC.	10.2/6	80	25	12A	1			" " " " " " " " " "
57	CONC.	10.2/6	80	20	12A	1			" " " " " " " " " "
58	CONC.	10.2/6	80	50	14A	1			" " " " " " " " " "
59	CONC.	10.2/6	80	20	12A	1			" " " " " " " " " "
60	CONC.	10.2/6	50	60	14A		1		" " " " " " " " " "
61	CONC.	10.2/6	80	60	14A		1		" " " " " " " " " "
62	CONC.	10.2/6	90	70	13A+13A	2			" " " " " " " " " "
63	CONC.	10.2/6	80	20	12A	1			" " " " " " " " " "
64	CONC.	10.2/6	80	60	14A	1			" " " " " " " " " "
65	CONC.	10.2/6	90	60	14A	1			" " " " " " " " " "
66	CONC.	10.2/6	70	75	13A+13A	2			PROP 1Ø HV + PROP ABS
67	CONC.	10.2/6	40	65	14A	2			PROP 1Ø HV ONLY
68	CONC.	10.2/6	65	20	12A		1		" " " " " " " " " "
69	CONC.	10.2/6	80	15	12A	1			" " " " " " " " " "
70	CONC.	10.2/6	65	5	11A				" " " " " " " " " "
71	CONC.	10.2/6	80	40	14A		1		" " " " " " " " " "
72	CONC.	10.2/6	90	60	14A	1			" " " " " " " " " "
73	CONC.	10.2/6	80	20	12A	1			" " " " " " " " " "
74	CONC.	10.2/6	30	15	12A	1			" " " " " " " " " "
75	CONC.	10.2/6	120	15	12A		1		" " " " " " " " " "
76	CONC.	10.2/6	100	10	11A		1		" " " " " " " " " "
77	CONC.	10.2/6	85	10	11A		1		" " " " " " " " " "



							REFERENCE		
0	ORIGINAL ISSUE	16.03.17	RR					CAD FILENAME	
No.	REVISION	DATE	BY	CHK	PSD	APP		DRAWING No.	TITLE

DRAWN	RAULUIORO.R	16.03.17
CHECKED		
CHIEF DRAUGHTSMAN	<i>[Signature]</i>	21.03.17
TEAM LEADER DESIGN & PLANNING	<i>[Signature]</i>	21.03.17
ENGINEER		
HEAD OF DEPARTMENT	<i>[Signature]</i>	22.03.17

<h1 style="text-align: center;">FIJI ELECTRICITY AUTHORITY</h1>					
<p style="text-align: center;">SUPPLY TO NABUKELEVU VILLAGE SERUA DISTRICT (STAGE 1) NABOUTINI (SE01.13)</p>		DRAWING NUMBER			
		A1	04	N89	025
		SCALE 1 : 2500			