

# ELECTRIC POWER CORPORATION

Level 5  
Tuiatua Tupua Tamasese Efi  
Building  
Apia  
Samoa



Telephone: (685) 65400  
Facsimile: (685) 23 748  
E-mail: [info@epc.ws](mailto:info@epc.ws)  
Website: [www.epc.ws](http://www.epc.ws)  
PO Box: 2011

11<sup>th</sup> November 2018

To: BIDDERS

Subject: SAM EPC 44/2018 – GOVT BUILDING STANDBY GENERATOR

Addendum No. 1

No	Question/ Query	Date Issued	EPC Responses	Addendum No
1	Could the Bid Closing date be extended out to 3 <sup>rd</sup> December as the time frame is very tight to get prices back from suppliers and subcontractors?	11 <sup>th</sup> Nov 2018	Bid closing date is extended to 10am Monday 26 <sup>th</sup> November 2018 (local time).  Bid opening will be at 11am on same day, 26 <sup>th</sup> Nov 2018	1
2	What is the construction of the new generator building, will it be fully enclosed and what type of cladding material will be used on the walls? As the exhaust stack is to be taken outside this is important to know.	11 <sup>th</sup> Nov 2018	Generator building will be built using concrete blocks with openings to allow ventilation for engine. Exhaust pipe from engine to be fully insulated with proper cladding to exit building. Requirements of generator supplier will be incorporated in design of generator building. Generator building is built by others.	1
3	EPC will relocate the 2 x 500kVA transformers, will EPC also run new mains cable from these re-located transformers into the new ATS?	11 <sup>th</sup> Nov 2018	EPC is replacing two 500kva transformers with a single 1MVA transformer. Yes, EPC will run new HV and LV mains cable to transformer and new generator ATS. Contractor for new generator will supply termination and connect all LV main cables to ATS.	1
4	Will EPC re-direct the existing mains cable	11 <sup>th</sup> Nov 2018	Yes, as stated in 3 above.	1

	for the Government building back to the new ATS?			
5	Will the new generator building have built in cable trenches for the incoming transformer cables and outgoing building cables from the ATS?	11 <sup>th</sup> Nov 2018	Yes. Generator supplier will provide layout of cable trenches to be build in floor of new building.	1

Please sign and return acknowledgement form.

Sincerely



Fonoti Perelini S. Perelini  
 Project Manager  
 Project Management Unit

**ACKNOWLEDGEMENT FORM**

**Bid: SAM EPC 44/2018 – GOVT BUILDING STANDBY GENERATOR**

Bidder Name: \_\_\_\_\_

We confirm receiving this Addendum 1

Signed by: \_\_\_\_\_

Name of Authorized Person