

ELECTRIC POWER CORPORATION

Level 5
Tuiatua Tupua Tamasese Efi
Building
Apia
Samoa



Telephone: (685) 65400
Facsimile: (685) 23 748
E-mail: info@epc.ws
Website: www.epc.ws
PO Box: 2011

14th November 2018

To: BIDDERS

Subject: SAM EPC 44/2018 – GOVT BUILDING STANDBY GENERATOR

Addendum No. 4

No	Question/ Query	Date Issued	EPC Responses	Addendum No
1	Could the Bid Closing date be extended out to 3 rd December as the time frame is very tight to get prices back from suppliers and subcontractors?	11 th Nov 2018	Bid closing date is extended to 10am Monday 26 th November 2018 (local time). Bid opening will be at 11am on same day, 26 th Nov 2018	1
2	What is the construction of the new generator building, will it be fully enclosed and what type of cladding material will be used on the walls? As the exhaust stack is to be taken outside this is important to know.	11 th Nov 2018	Generator building will be built using concrete blocks with openings to allow ventilation for engine. Exhaust pipe from engine to be fully insulated with proper cladding to exit building. Requirements of generator supplier will be incorporated in design of generator building. Generator building is built by others.	1
3	EPC will relocate the 2 x 500kVA transformers, will EPC also run new mains cable from these re-located transformers into the new ATS?	11 th Nov 2018	EPC is replacing two 500kva transformers with a single 1MVA transformer. Yes, EPC will run new HV and LV mains cable to transformer and new generator ATS. Contractor for new generator will supply termination and connect all LV main cables to ATS.	1
4	Will EPC re-direct the existing mains cable	11 th Nov 2018	Yes, as stated in 3 above.	1

	for the Government building back to the new ATS?			
5	Will the new generator building have built in cable trenches for the incoming transformer cables and outgoing building cables from the ATS?	11 th Nov 2018	Yes. Generator supplier will provide layout of cable trenches to be build in floor of new building.	1
6	Correction on date of Pre-bid meeting	12 th Nov 2018	Pre-bid meeting/teleconference is on Wednesday 14 th November 2018 at 10am. Call in numbers will be advised later for those bidders who cannot attend meeting but to call in by teleconference.	2
7	Is Alternative Bids with different make and model generators allowed	14 th Nov 2018	Yes, Alternative Bids are allowed for different make and model generator with different prices and specification of as long as they meet bid requirements. Example under one bid, a bidder can offer two price proposals; one with a European Make generator and other with an Australian or a US Make generator.	3
8	Contract Form	14 th Nov 2018	Attached is Contract Form for this bid	4
9	Payment Terms		Payment Terms is covered in Clause GCC 16.1 of Contract Form attached.	4
10	Fuel day tank of generator	14 th Nov 2018	Generator must include a fuel day tank incorporated with generator container. Fuel day tank is automatically topped up from the 5000L fuel tank. Bidder will allow to supply all materials and fittings to connect the fuel day tank of the generator with bulk fuel tank.	4
11	Cabling	14 th Nov 2018	Bidder shall allow to supply and install all cables and fittings between generator terminals and ATS. At least two 500 MCM cables per phase are used.	4

Please sign and return acknowledgement form.

Sincerely



Fonoti Perelini S. Perelini
Project Manager
Project Management Unit

Attachments – contract form

ACKNOWLEDGEMENT FORM

Bid: SAM EPC 44/2018 – GOVT BUILDING STANDBY GENERATOR

Bidder Name: _____

We confirm receiving this Addendum 4

Signed by: _____

Name of Authorized Person