

# ELECTRIC POWER CORPORATION

Level 5  
Tuiatua Tupua Tamasese Efi  
Building  
Apia  
Samoa



Telephone: (685) 65400  
Facsimile: (685) 23 748  
E-mail: [info@epc.ws](mailto:info@epc.ws)  
Website: [www.epc.ws](http://www.epc.ws)  
PO Box: 2011

10 July 2019

To: BIDDERS

Subject: SAM EPC 2019/24 – Engineering, Supply, Installation and Commissioning of 33kv Equipment in Fuluasou Substation and Tanugamanono power station

Addendum No. 3

No	Question/ Query	Date Issued	EPC Responses	Addendum No
1	Date and time of pre-bid meeting	14 June 2019	Pre bid meeting is changed to 24 <sup>th</sup> June 2019 at 10am in EPC office in Level 5 TATTE Building	1
2	Can bidders bid for just equipment ONLY?	14 June 2019	NO. This is a design, supply, install and commissioning bid where bidder will prepare design of installation, supply all equipment and materials, construct, install and commissioning equipment.	1
3	Request to extend bid closing date	14 June 2019	Bid closing date is extended to Monday 29 <sup>th</sup> July 2019	1
4	Revision of equipment to be supplied and installed in Tanugamanono	25 June 2019	Provide/install Base Steel Plate to fit three (3) 33kv circuit breakers but only install two 33kv circuit breakers as specified in the bid. Space for a 3 <sup>rd</sup> circuit breaker is for future use.	2
5	Tanugamanono circuit breakers	“	There shall be 3 new circuit breakers installed in Tanugamanono; two (2) 33kv CBs and one (1) 22kv CBs.	2
6	Location of 10MVA transformer in Tanugamanono power station	“	New 10MVA 33/22kv transformer will be located on concrete pad where one of old 5MVA 6.6/22kv transformers is installed. Contractor will modify this pad to	2

			<p>install new 10MVA transformer. Pad shall have a bund with a drain fitted with a device that only release water and hold oil.</p> <p>EPC will disconnect and remove existing 5MVA 6.6/22kv old transformer.</p>	
7	Replacement of one Schneider 22kv circuit breaker in Samasoni hydro plant	“	There are two generators and 22kv circuit breakers (CB) in Samasoni hydro plant. Make of circuit breakers is Schneider Electric. One of CBs is fault with a leaking insulation gas.	2
8	Factory Testing	“	Original Bid Form included item to cover cost of one EPC engineer to attend factory testing of equipment. Decision was made to remove this item from Bid Form. EPC will not send anyone to factory. Acceptance of equipment by EPC will be done after installation.	
9	Equipment Warranty	“	All equipment supplied under this bid and installation shall be warranted for 4 additional years after ‘Defect Maintenance Period’. Manufacturers’ warranty for equipment shall be included in offer to EPC.	2
10	As Option - Adding a 2 <sup>nd</sup> lot, Lot 2, for this bid. Original scope is Lot 1.	“	<p>Optional - Lot 2 – Bidders to provide a separate quote as part of this bid to provide annual servicing of all power transformers used in power stations and substation in Upolu and Savaii.</p> <p>The total number of power transformers is 28 and locations of power transformers as listed below:</p> <p>Tanugamanono power station – 4  Fuluasou substation – 3  Fiaga power station – 5  Lalomauga hydro - 4  Samasoni hydro - 2  Alaoa hydro - 1  Fale ole Fee hydro - 1  Taelefaga hydro - 3  Salelologa power station – 2  Tafitoala-Fausaga – 1</p>	2

			<p>Vailoa Savaii – 1 Fulusou hydro – 1</p> <p>Bidder to provide detailed services and tests to be carried out and frequency of performing. Service shall be annual. Transformer service contract will be for 2 years. Contractor will train EPC staff to take over services after 2 years contract.</p> <p>Price to include: cost of labor, travel, hotel, per diem, test equipment and tools, local transport.</p>	
11	Minutes of Prebid meeting	“	Attached is minutes of prebid meeting	2
12	Extension of Bid closing date	10 July 2019	EPC approved to extend bid closing date to August 5, 2019 at 10am local time.	3
13	Lot 3 for replacement of one of 22kv Schneider Circuit breakers in Samasoni hydro plant	10 July 2019	Item 7 above to replace one of the 22kv Schneider Circuit Beakers in Samasoni hydro plant covered under a separate Lot 3, not to be included in Lot 1 for 33kv tie equipment.	3

Please sign and return acknowledgement form.

Sincerely

George Suisala  
Procurement Officer

#### ACKNOWLEDGEMENT FORM

**Bid: SAM EPC 2019/1 – Engineering, Construction, Installation, Testing and Commissioning of 33kv tie equipment in Fulusou substation and Tanugamanono power station**

Bidder Name: \_\_\_\_\_

We confirm receiving this Addendum 3

Signed by: \_\_\_\_\_

Name of Authorized Person