



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

July 14, 2020

AMENDMENT NO.: I

TO

INVITATION FOR BID NO.: GPA-057-20

FOR

WIRE

Prospective Bidders are hereby notified of the following response to inquiry received from Bidder No. 4 dated 07/13/2020:

Bidder No. 4 inquiry dated 07/13/2020:

QUESTION:

1. My supplier is asking if GPA-057-20 calls for stranded or solid wire.

ANSWER:

GPA-057-20 requires for #2 7 strand per GPA Specification E-001, Revision 2, Section 7.0, Table A.

GLOBAL NOTICE: COVID-19PANDEMIC

To ensure the safety and well-being of personnel and prospective bidders, please be advised on the following:

1. Six (6) Feet of Social Distancing shall be practiced.
2. Mandatory face mask required for each individual.
3. Temperature checks shall be conducted upon entrance of the Gloria B. Nelson Public Service Building.
4. One (1) Personnel per Prospective Bidder to submit and attend public opening.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.


for JOHN M. BENAVENTE, P.E.
 General Manager