

# Energy Fiji Limited



## **Tender Document**

Tender No. : MR 121/2021

**Calibration of IDO Vertical Tanks at EFL Kinoya  
Power Station and EFL Vuda Power Station.**

Generation SBA  
Energy Fiji Limited

25 June 2021  
AmitS@efl.com.fj

## **Table of Content**

<b>1.0</b>	<b>INVITATION FOR TENDERS</b>	<b>4</b>
<b>2.0</b>	<b>INSTRUCTION TO BIDDERS</b>	<b>5</b>
2.1	ELIGIBLE BIDDERS	5
2.2	ELIGIBLE MATERIALS, EQUIPMENT AND SERVICES	5
2.3	ONE BID PER BIDDER	5
2.4	COST OF BIDDING	5
2.5	SITE VISITS	5
2.6	CONTENTS OF THE BIDDING DOCUMENTS	6
2.7	CLARIFICATION OF BIDDING DOCUMENTS	6
2.8	AMENDMENT OF BIDDING DOCUMENT	6
2.9	LANGUAGE OF BID	6
2.10	BID PRICES	6
2.11	BID CURRENCIES	7
2.12	BID VALIDITY	7
2.13	FORMAT AND SIGNING OF BIDS	7
2.14	SEALING AND MARKING OF BIDS	7
2.15	DEADLINE FOR SUBMISSION OF BIDS	8
2.16	LATE BIDS	8
2.17	MODIFICATION AND WITHDRAWAL OF BIDS	8
2.18	REJECTION OF ONE OR ALL BIDS	9
2.19	PROCESS TO BE CONFIDENTIAL	9
2.20	CLARIFICATION OF BIDS	9
2.21	PRELIMINARY EXAMINATION	9
<b>3.0</b>	<b>TECHNICAL SPECIFICATION</b>	<b>10</b>
3.1	GENERAL INFORMATION	10
3.1.1	PRELIMINARY AND GENERAL CONDITIONS	10
3.1.2	SITE LOCATION	10
3.1.3	OHS REQUIREMENTS	10
3.1.4	BUILDING CONDITIONS	10
3.1.5	WORK PLAN	10
3.1.6	SITE SAFETY MANAGEMENT SYSTEM	10
3.1.7	ENVIRONMENTAL CONTROL	10
3.1.8	PROTECTION OF PEOPLE AND PROPERTY	11
3.1.9	DURATION OF WORK	11
3.1.10	STORAGE OF MATERIALS AND EQUIPMENT'S	11
3.1.11	DAILY DIARY REPORTS	11
3.1.12	CARE OF THE WORKS	11
3.1.13	CLEARING AWAY	11
3.1.14	TOBACCO/ALCOHOL/DRUG FREE ENVIRONMENT	11
3.2	INSURANCES	11

<b>3.3</b>	<b>TANK DETAILS</b>	<b>12</b>
<b>3.4</b>	<b>SITE PHOTOS</b>	<b>13</b>
<b>4.0</b>	<b>SCOPE OF WORK</b>	<b>15</b>
<b>4.1</b>	<b>REQUIREMENTS FOR STAIRWAY</b>	ERROR! BOOKMARK NOT DEFINED.
<b>4.2</b>	<b>OTHER WORK</b>	ERROR! BOOKMARK NOT DEFINED.
<b>5.0</b>	<b>PRICE SCHEDULE</b>	<b>16</b>
<b>5.1</b>	<b>COMPLIANCE CHECKLIST DECLARATION</b>	<b>18</b>
<b>5.2</b>	<b>TENDER CHECK LIST</b>	<b>19</b>
<b>6.0</b>	<b>TENDER FORM</b>	<b>20</b>
<b>7.0</b>	<b>SUBMISSION TO TENDER</b>	<b>21</b>

## **1.0 INVITATION FOR TENDERS**

Energy Fiji Limited is inviting bids for calibration of 2 x Vertical IDO Tank at EFL Kinoya Power Station and 1 x Vertical IDO Tank at EFL Vuda Power Station. The stations are listed under section 3.3. A complete tank calibration to be carried out at listed power stations inclusive of calibration certificate and fuel Dip table.

The Detailed scope of works listed in the following pages.

Interested bidders may obtain Tender Document at the:

Supply Chain Office  
Energy Fiji Limited  
Head Office  
2 Marlow Street, Suva  
Contact: 322 4360 / 999 2400

All tenders shall submit all documents required including spares pricing as per price template.

During evaluation of tenders, the Authority will invite a tenderer or tenderers for discussions, presentations and necessary clarification before awarding of the contract

The tender submissions close on the **21/07/21**

## **2.0 INSTRUCTION TO BIDDERS**

### **2.1 Eligible Bidders**

- 2.1.1. This invitation is open to all Bidders who have sound financial background, and have previous experience in calibrating vertical fuel tanks.
- 2.1.2. Bidders shall provide such evidence of their continued eligibility satisfactory to EFL as EFL shall reasonably request.
- 2.1.3. Bidders shall not be under a declaration of ineligibility for corrupt or fraudulent practice.

### **2.2 Eligible Materials, Equipment and Services**

- 2.2.1. The materials, equipment, and services to be supplied under the Contract shall have their origin from reputable companies as specified by EFL and from various countries and all expenditures made under the Contract will be limited to such materials, equipment, and services. Upon request, bidders may be required to provide evidence of the origin of materials, equipment, and services.
- 2.2.2. For purposes of this Contract, "services" means the works and all project-related services including design services.
- 2.2.3. For purposes of this Contract, "origin" means the place where the materials and equipment are mined, grown, produced or manufactured, and from which the services are provided. Materials and equipment are produced when, through manufacturing, processing or substantial or major assembling of components, a commercial recognized product results that is substantially different in basic characteristics or in purpose or utility from its components.
- 2.2.4. The materials, equipment and services to be supplied under the Contract shall not infringe or violate any industrial property or intellectual property rights or claim of any third party.

### **2.3 One bid per Bidder**

- 2.3.1. Each bidder shall submit only one bid. A bidder who submits or participates in more than one bid will cause all those bids to be rejected.

### **2.4 Cost of Bidding**

- 2.4.1. The bidder shall bear all costs associated with the preparation and submission of its bid and EFL will in no case be responsible or liable for those costs.

### **2.5 Site Visits (Optional)**

<b><u>Location</u></b>	<b><u>Site Visit Date</u></b>	<b><u>Site Visit Time</u></b>
EFL Kinoya Power Station	30/06/21	11am
EFL Vuda Power Station	01/07/21	1pm

## **2.6 Contents of the Bidding Documents**

- 2.6.1. The bidder is expected to examine carefully the contents of this Bidding document. Failure to comply with the requirements of bid submission will be at the bidder's own risk. Bids which are not substantially responsive to the requirements of the bidding documents will be rejected.
- 2.6.2. The following are the mandatory submission of a successful tender bid;
- Pricing Schedule
  - Program of Works
  - Company Profile (Max 2 pages in standard A4)
    - Work History - Project/ Work done with referee, EFL work history.
    - Company background
    - Bidder available resources e.g. Manpower, Machines & Equipment.
    - OHS Policies or Plan
  - Fiji Revenue & Customs Service (FRCA) compliance
  - Fiji National Provident Fund (FNPF) compliance
  - Signed checklist declaration (Appendix 5.1)

Failure to submit required documents may affect bid compliance even make it non-compliance.

## **2.7 Clarification of Bidding Documents**

- 2.7.1. A prospective bidder requiring any clarification of the bidding documents may notify EFL in writing by fax (hereinafter the term "fax" is deemed to include electronic transmission such as facsimile, cable and telex), or email addressed to:

Jitendra Reddy  
Manager Procurement, Inventory & Supply Chain  
2 Marlow Street,  
Suva, Fiji  
Phone: +679 3224 360/9992400  
Email: [JReddy@efl.com.fj](mailto:JReddy@efl.com.fj)

- 2.7.2. EFL will respond to any request for clarification which it receives earlier than 5 days prior to the deadline for submission of bids.

## **2.8 Amendment of Bidding Document**

- 2.8.1. At any time prior to the deadline for submission of bids, EFL may, for any reason, whether at its own initiative or in response to a clarification requested by a prospective bidder, modify the bidding documents by issuing addenda.

## **2.9 Language of Bid**

- 2.9.1. The bid, and all correspondence and documents related to the bid, exchanged between the bidder and the EFL shall be written in the English language.

## **2.10 Bid Prices**

- 2.10.1. Unless specified otherwise, Bidders shall quote for the entire facilities on a "single responsibility" basis such that the total bid price covers all the Supplier's obligations mentioned

in or to be reasonably inferred from the bidding documents in respect of the design, manufacture, including procurement and subcontracting (if any), testing and delivery.

- 2.10.2. Bidders shall give a breakdown of the prices in the manner and detail called for in this bidding document, or any issued addenda.
- 2.10.3. For Oversea Suppliers, bids shall be given on Cost Insurance Freight (CIF) or Delivery at Place (DAP) basis. The point of delivery shall be Suva/Lautoka port for Sea or Nadi Airport for Air. The term CIF & DAP shall be governed by the rules prescribed in the current edition of Incoterms (i.e. the eighth version - Incoterms 2010), published by the International Chamber of Commerce, Paris. Stated Otherwise with validation. (*not applicable*)

## **2.11 Bid Currencies**

- 2.11.1. Prices shall be quoted in a single currency only.

## **2.12 Bid Validity**

- 2.12.1. Bids shall remain valid for a period of 60 days from the date of Deadline for Submission of Bids specified in Sub-Clause 2.15.

## **2.13 Format and Signing of Bids**

- 2.13.1. The bidder shall prepare one original and two (2) copies of the technical and financial proposals, clearly marking each one as: "ORIGINAL-TECHNICAL & PRICE PROPOSAL", "COPY NO. 1 - TECHNICAL & PRICE PROPOSAL", etc. as appropriate. In the event of discrepancy between the original and any copy, the original shall prevail.
- 2.13.2. The original and all copies of the bid shall be typed or written in indelible ink (in the case of copies, Photostats are also acceptable) and shall be signed by a person or persons duly authorized to sign on behalf of the bidder. All pages of the bid where entries or amendments have been made shall be initialled by the person or persons signing the bid.
- 2.13.3. The bidder shall provide one electronic copy of the Technical and Financial proposals on EFL's electronic tender hosting website; <https://www.tenderlink.com/efl>
- 2.13.4. The bid shall contain no alterations, omissions or additions, except those to comply with instructions issued by EFL, or as necessary to correct errors made by the bidder, in which case such corrections shall be initialled by the person or persons signing the bid.

## **2.14 Sealing and Marking of Bids**

- 2.14.1. The bidder shall seal the original copy of the technical proposal and the original copy of the price proposal and each copy of the technical proposal and each copy of the price proposal in separate envelopes clearly marking each one as: "ORIGINAL-TECHNICAL & PRICE PROPOSAL", "COPY NO. 1 - TECHNICAL & PRICE PROPOSAL", etc. as appropriate.
- 2.14.2. The bidder shall seal the original bids and each copy of the bids in an inner and an outer envelope, duly marking the envelopes as "ORIGINAL", "COPY No. 1", etc.

2.14.3. The inner and outer envelopes shall

- a) be addressed to EFL at the following address:

Jitendra Reddy  
Manager Procurement, Inventory & Supply Chain  
2 Marlow Street,  
Suva, Fiji  
Phone: +679 3224 360/9992400  
Email: [JReddy@efl.com.fj](mailto:JReddy@efl.com.fj)

And

- b) bear the following identification:

Bid for: MR 121/2021 - Calibration of IDO Vertical Tanks at EFL Kinoya Power Station and EFL Vuda Power Station.

- 2.14.4. In addition to the identification required, the inner envelope shall indicate the name and address of the bidder to enable the bid to be returned unopened in case it is declared "late" pursuant to Deadline for Submission of Bids.
- 2.14.5. If the outer envelope is not sealed and marked as above, EFL will assume no responsibility for the misplacement or premature opening of the bid.

## **2.15 Deadline for Submission of Bids**

- 2.15.1. Bids must be received by EFL at the address specified above no later than 1600 hours (Fiji Time) 21/07/21.
- 2.15.2. EFL may, at its discretion, extend the deadline for submission of bids by issuing an addendum, in which case all rights and obligations of EFL and the bidders previously subject to the original deadline will thereafter be subject to the deadlines extended.

## **2.16 Late Bids**

- 2.16.1. Any bid received by EFL after the deadline for submission of bids prescribed above will be rejected and returned unopened to the bidder.

## **2.17 Modification and Withdrawal of Bids**

- 2.17.1. The bidder may modify or withdraw its bid after bid submission, provided that written notice of the modification or withdrawal is received by EFL prior to the deadline for submission of bids.
- 2.17.2. The bidder's modification or withdrawal notice shall be prepared, sealed, marked and delivered in accordance with Sealing and Marking of Bids, with the outer and inner envelopes additionally marked "MODIFICATION" or "WITHDRAWAL", as appropriate. A withdrawal notice may also be sent by fax but must be followed by a signed confirmation copy.
- 2.17.3. No bid may be modified by the bidder after the deadline for submission of bids.

## **2.18 Rejection of one or all Bids**

- 2.18.1. EFL reserves the right to accept or reject any bid, and to annul the bidding process and reject all bids, at any time prior to award of Contract, without thereby incurring any liability to the affected bidder or bidders or any obligation to inform the affected bidder or bidders of the grounds for the rejection.

## **2.19 Process to be Confidential**

- 2.19.1. Information relating to the examination, clarification, evaluation and comparison of bids and recommendations for the award of a contract shall not be disclosed to bidders or any other persons not officially concerned with such process.
- 2.19.2. Any effort by a bidder to influence EFL's processing of bids or award decisions may result in the rejection of the bidder's bid.
- 2.19.3. Lowest bid will not necessarily be accepted as successful bid.

## **2.20 Clarification of Bids**

- 2.20.1. To assist in the examination, evaluation and comparison of bids, EFL may, at its discretion, ask any bidder for clarification of its bid. The request for clarification and the response shall be in writing or by fax, but no change in the price or substance of the bid shall be sought, offered or permitted except as required to confirm the correction of arithmetic errors discovered by EFL in the evaluation of the bids in.

## **2.21 Preliminary Examination**

- 2.21.1. Energy Fiji Limited will examine the tenders to determine whether they are complete, whether any computational errors have been made, whether the documents have been properly signed, and whether the tenders are generally in order.
- 2.21.2. Arithmetical errors will be rectified on the following basis. If there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail, and the total price shall be corrected. If the tenderer does not accept the correction of the errors, its tender will be rejected. If there is a discrepancy between words and figures, the amount in words will prevail.
- 2.21.3. Energy Fiji Limited may waive any minor informality or non-conformity or irregularity in a tender which does not constitute a material deviation, provided such waiver does not prejudice or affect the relative ranking of any tenderer.
- 2.21.4. Prior to the detailed evaluation, pursuant to Clause 21, Energy Fiji Limited will determine the substantial responsiveness of each tender to the tender document. For purposes of these paragraphs, a substantially responsive tender is one, which conforms to all the terms and conditions of the tender document without material deviation. Energy Fiji Limited's determination of a tender's responsiveness is to be based on the contents of the tender itself without recourse to extrinsic evidence.
- 2.21.5. If a tender is not substantially responsive, it will be rejected by Energy Fiji Limited and may not subsequently be made responsive by the tenderer by correction of the nonconformity.

### **3.0 TECHNICAL SPECIFICATION**

#### **3.1 General Information**

##### **3.1.1 Preliminary and General Conditions**

The contractor shall furnish all labour, equipment, transportation and services as necessary to complete all projected work included in this specifications.

##### **3.1.2 Site Location**

- EFL Kinoya Power Station
- EFL Vuda Power Station

##### **3.1.3 OHS Requirements**

The contractor shall at times comply with all Energy Fiji Limited's HSE Regulations currently in force.

Contractors shall at times comply with all Covid 19 rules and regulations regulated by EFL and Fiji Government for all site works.

##### **3.1.4 Building Conditions**

The contractor is advised to visit and assess the site and existing premises prior to tendering, as no claim will be allowed on the grounds of ignorance of the conditions existing.

##### **3.1.5 Work Plan**

The contractor shall prepare a Work Programme, Work Safety Plan/Risk Assessment Plan in accordance and shall submit the plan to the property officer for his approval before commencing with work on the site.

##### **3.1.6 Site Safety Management System**

The contractor shall establish and maintain a Site Safety Management that ensures the safety of all persons on the site in accordance with the requirements of the Energy Fiji Limited Occupational Health and Safety Policy and the Health and Safety at Work Act, 1996 requiring strict compliance by the parties here to. The Contractor is to obtain all approvals from Ministry of Labour for any scaffolding to be used on the site. All PPE's and other safety equipment's will be checked by EFL's Health and Safety Department (HSE) to confirm if they are in compliance with the relevant current safety standards. No work shall commence prior to approvals given from EFL's HSE Department. (Mandatory Requirement)

EFL will carry out an induction for the contractor and its members to familiarize with the Energy Fiji Limited Occupational Health and Safety Policy.

##### **3.1.7 Environmental Control**

Comply with all environmental protection provisions in the contract and the requirements of any statute, by law, standard and the like related to environmental protection.

### **3.1.8 Protection of People and Property**

The contractor shall keep all persons (workers) under control and within the boundaries of the site. He will be held responsible for the care of the existing premises and works generally until completion.

### **3.1.9 Duration of Work**

The expected duration for the completion of work shall be specified by the contractor.

### **3.1.10 Storage of Materials and Equipment's**

Materials and equipment's stored on site must not pose any danger to property and minimize hazards to persons, materials and equipment. Keep storage area neat and tidy. Take proper precautions to keep poisonous and other injurious substance in place secured against access by unauthorised person.

### **3.1.11 Daily Diary Reports**

Progress reports shall be submitted daily on a standard form to the supervising EFL Engineer.

### **3.1.12 Care of the Works**

The contractor shall keep all persons under control and within the boundaries of the site. He will be held responsible for the care of the existing premises and works generally until completion.

### **3.1.13 Clearing Away**

The contractor shall take the removed rubbish and debris to a location which will be advised in the **site visit**.

### **3.1.14 Tobacco/Alcohol/Drug Free Environment**

EFL maintains tobacco, alcohol and drug free environment. Any personnel of the contractor found violating the policy will be requested to remove the product and themselves from the sites. Offensive language or actions are not acceptable. The EFL shall have the absolute right to require replacement of any employee the EFL deems objectionable to work on EFL premises.

## **3.2 Insurances**

The Contractor shall be solely responsible for all relevant insurance covers for person, tools, plants and equipment involved in carrying out the Works. The Contractor must obtain and maintain all relevant insurance covers at all material times sufficient to cover any loss or costs that may be incurred which the Contractor is liable for in connection with the duration and Scope of Works, including:

- Contractors All Risk
- Public Liability and
- Workmen's Compensation

### 3.3 Tank Details

<u>Location</u>	<u>Tank ID</u>	<u>Volumes (L) (Approx.)</u>	<u>Type</u>	<u>Approx. Diameter (M)</u>	<u>Approx. Height (M)</u>	<u>Approx. Circumference (M)</u>	<u>Approx. Shell wall thickness(mm)</u>	<u>Operational Status</u>
Kinoya Power Station	T1	1.2 M	Vertical	12.18	11.04	38.32	12	In Operation
	T2	600,000	Vertical	9.12	9.17	28.67	12	In Operation
Vuda Power Station	T1	700,000	Vertical	9.07	11.00	28.5	12	In Operation

### 3.4 Site Photos



**Figure 1:** IDO storage tank 1 at EFL Kinoya Power Station.



**Figure 2:** IDO storage tank 2 at EFL Kinoya Power Station.



**Figure 3:** IDO storage tank at EFL Vuda Power Station.

## **4.0 SCOPE OF WORK**

1. The bidder shall provide information regarding works carried out on similar projects
2. Bidder shall provide a work timeline.
3. Calibration / Dry calculation shall be done for all the tanks.
4. Contractor to state the uncertainty of the sensor and data sheet.
5. Torispherical volume (Dead volume) for listed tanks shall be provided to EFL.
6. Calibration charts shall be provided for calibrated tanks.
7. Dip table shall be provided for all calibrated tanks. Data shall be presented in Volume per Dip (Liters/mm)
8. Contractor shall also provide the following documents to EFL :
  - Critical level certificate.
  - Reference height at the time of calibration.
  - Capacity below dip plate.
  - Nominal Tank Height
  - Tank diameter external at base.
  - Temperature at which calibration table is certified.
  - Expansion under head based upon density
  - Nominated maximum safe fill level (safe working height)
  - Storage temperature.
  - Uncertainty of measurement.
9. All the calibration shall be done according to ISO Standard 7507 – 4 or ASTM D1220-85.
10. At the end of the work, contractor shall provide a report stating all the calculation or methodology used to carry out the calibration work.

### **Note:**

- All EFL OHS requirements must be followed.
- Contractor shall use any calibration method as long as it is approved by EFL.
- Contractor shall submit a preferred work plan and methodology for the type of calibration method that would be used.
- Contractor shall provide the final calibrated table in Hard copy or Soft Copy (Excel & PDF)
- For Foreign Contractors, any On-Shore work (In Fiji) with incur a withholding Tax of 15% e.g. commissioning, training etc.
- Contractor shall state the price for accommodation and travelling to and from Fiji Islands. (Covid 19 protocols)

## 5.0 PRICE SCHEDULE

### Calibration of IDO Vertical Tanks at EFL Kinoya Power Station and EFL Vuda Power Station

Item	Item Description (Labour, consumables and material)	Total Price (Currency = _____)
1	Carryout calibration and provide calibration table for EFL Vuda IDO tank (Hardcopy and Softcopy (Excel & PDF))	
2	Carryout calibration and provide calibration table for EFL Kinoya IDO tank 1 (Hardcopy and Softcopy(Excel & PDF))	
3	Carryout calibration and provide calibration table for EFL Kinoya IDO tank 2 (Hardcopy and Softcopy(Excel & PDF))	
4	Quarantine in and out of Fiji Islands for 14 days.(accommodation)	
5	Travelling Cost	
<b>TOTAL (VEP)</b>		
<b>Withholding Tax 15% (If applicable) *2f</b>		

**Notes:**

1. Technical;
  - a. The bids must as per the Technical Specifications in the Tender Documents. Bids that do not conform to the technical Specification will be disqualified
  - b. Tenderers shall provide proof of successful completion within the stipulated delivery period of similar contracts undertaken in the past.
  - c. Documentary evidence to prove that the items offered comply with the Technical Specification must be provided.
  - d. Contractor to verify all drawing measurements onsite.
  - e. The Supplier/ Contractor shall provide a warrants for Goods or services for provided unless stated otherwise.
  - f. EFL's Engineer or his representative shall have the right to inspect and/or to witness test the Goods at the factory or place of manufacture, for their conformity to the specifications
  - g. The Goods supplied under this Contract shall conform to the standards mentioned in the Technical Specifications
2. Financial;
  - a. In case of discrepancy between unit and total cost, the unit cost shall prevail
  - b. Any advance payment will require a bank guarantee. And this added cost will be beared by bidder
  - c. The currency used in the tender bid prices must be indicated in the tender bid
  - d. Prices shall be fixed during the Supplier's performance of the Contract and not subject to variation on any account.
  - e. EFL financial terms are applicable for these works.
  - f. For Foreign Supplier, any On-Shore work with incur a withholding Tax of 15% e.g. commissioning, training etc.
3. EFL Energy Fiji Limited uses Federation Internationale Des Ingenieurs Conseil (FIDIC) Contract template. General conditions of this contract shall be governed by it.
4. EFL have right to spilt award, tender may be awarded to multiple suppliers. And Minimum order quantity (MOQ) will not be acceptable.
5. All clarification request must be sent 5 days prior to the deadline for submission of bids
6. Price Schedule must be typed and stamped on the bid submission.
7. Failure to submit required documents may affect bid compliance. Failure to submit mandatory items as stated in Compliance Checklist will result in non-compliance.

8. Contractor shall provide all materials, tools equipment and labour necessary to perform works.
9. A detailed work plan to be provided with expected date for the works.
10. Installation & Commissioning works must incorporate all cost incur for this activity e.g. travel, accommodation, visa etc.
11. All Sub-contractors to be used for any part of the works are to be declared.
12. Site Visit mandatory.

## 5.1 Compliance Checklist Declaration

I \_\_\_\_\_ of \_\_\_\_\_ located at \_\_\_\_\_ confirm that the bid submitted for the following tender MR 121/2021 : Calibration of IDO Vertical Tanks at EFL Kinoya Power Station and EFL Vuda Power Station bid complies to the mandatory bidder submission as stated in Sub Clause 2.6;

	Yes	No	Details
<b>Commercial</b>			
Price Schedule			
Company Profile			
Detailed Scope of Work/Supply			
Program [preferred Gantt Chart] (If Applicable)			
Payment Term (comply with EFL Credit term – 30 days)			
Price Validity [preferred 60 days]			
Insurance policy			
Valid FNPF Compliance certificate (If Applicable)			
Valid FRCS Compliance certificate (If Applicable)			
Valid Business Registration certificate (If Applicable)			
<b>Technical</b>			
Duration of work (timeline)			
Safety Management Plan			
OHS Compliance certificate			
Type and methodology for tank calibration.			
Company's capabilities & Background (resources, staff cv, etc.)			
History of similar Project			
Experience with EFL			
Covid 19 travelling and accommodation price			
Standards used for calibration work.			
Completed Specification Check sheet			
<b>Scope of Works</b>			
Statement of Exclusion or Amendment for Tender Specification (if Any)			

Note that these submissions are mandatory submission for a successful tender bid. This declaration must be signed and submit as well.

Name: \_\_\_\_\_

Position: \_\_\_\_\_

Company: \_\_\_\_\_

Sign Off: \_\_\_\_\_

Date: \_\_\_\_\_

## 5.2 Tender Check List

### TENDER SUBMISSION CHECK LIST

***The Bidders must ensure that the details and documentation mention below must be submitted as part of their tender Bid***

Tender Number \_\_\_\_\_

Tender Name \_\_\_\_\_

1. Full Company / Business Name: \_\_\_\_\_

**(Attach copy of Registration Certificate)**

2. Director/Owner(s): \_\_\_\_\_

3. Postal Address: \_\_\_\_\_

4. Phone Contact: \_\_\_\_\_

5. Fax Number: \_\_\_\_\_

6. Email address: \_\_\_\_\_

7. Office Location: \_\_\_\_\_

8. TIN Number: \_\_\_\_\_

**(Attach copy of the VAT/TIN Registration Certificate - Local Bidders Only (Mandatory))**

9. FNPF Employer Registration Number: \_\_\_\_\_ **(For Local Bidders only) (Mandatory)**

10. **Provide a copy of Valid FNPF Compliance Certificate (Mandatory- Local Bidders only)**

11. **Provide a copy of Valid FRCS (Tax) Compliance Certificate (Mandatory Local Bidders only)**

12. Contact Person: \_\_\_\_\_

I declare that all the above information is correct.

Name: \_\_\_\_\_

Position: \_\_\_\_\_

Sign: \_\_\_\_\_

Date: \_\_\_\_\_

## 6.0 TENDER FORM

To: Jitendra Reddy  
Manager Procurement, Inventory & Supply Chain  
2 Marlow Street,  
Suva, Fiji  
Phone: +679 3224 360/9992400  
Email: [JReddy@efl.com.fj](mailto:JReddy@efl.com.fj)

Sir,

1. Having examined the Tender Document, the receipt of which is hereby duly acknowledged, we, the undersigned, offer to supply  
.....  
(Description of Goods) in conformity with the said Tender Document for the sum  
.....  
..... (total tender amount in words and figures) or such  
other sums as may be ascertained in accordance with the Schedule of Prices  
attached herewith and made part of this Tender.
2. We undertake, if our Tender is accepted, to deliver the Goods in accordance with the delivery schedule specified in the Schedule of Requirements.
4. We agree to abide by this Tender for a period of 90days from the date fixed for Tender opening under Clause 19 of the Instructions to Tenderers, and it shall remain binding upon us and may be accepted at any time before the expiration of that period.
5. Until a formal Contract is prepared and executed, this Tender, together with your written acceptance thereof and your notification of award, shall constitute a binding Contract between us.
6. We understand that you are not bound to accept the lowest or any Tender you may receive.

Dated this: \_\_\_\_\_ day of \_\_\_\_\_ 201\_\_.

[Signature] [In the capacity of]

Duly authorized to sign Tender for and on behalf of

## **7.0 SUBMISSION TO TENDER**

It is mandatory for Bidders to upload a copy of their bid in the TENDER LINK Electronic Tender Box no later than 4.00pm (1600hrs Fiji Time) **Wednesday 21<sup>st</sup> July, 2021.**

To register your interest and tender a response, view 'Current Tenders' at: <https://www.tenderlink.com/efl>

For further information please contact Jitendra Reddy by e-mail [JReddy@efl.com.fj](mailto:JReddy@efl.com.fj)

In addition, hard copies of the tender, one original and one copy must be deposited in the tender box located at the EFL Head Office, 2 Marlow Street, Suva, Fiji no later than 1600hrs Wednesday 21<sup>st</sup> July, 2021 - Addressed as

**Tender - MR 121/2021 - Calibration of IDO Vertical Tanks at EFL's Kinoya and Vuda Power Stations**

**The Secretary Tender Committee  
Energy Fiji Limited  
Head Office  
Suva  
Fiji**

Courier charges for delivery of Tender Document must be paid by the bidders. EFL will not clear any bids received at the Post Office via registered mail.

Hard copies of the Tender bid will be accepted after the closing date and time provided a soft copy is uploaded in the e-Tender Box and it is dispatched before the closing date and time.

Tenders received after closing time 4.00pm (1600hrs Fiji Time) **Wednesday 21<sup>st</sup> July, 2021.**

- Will not be considered.
- Lowest bid will not necessarily be accepted as successful bid.

It is the responsibility of the bidder to pay courier charges and all other cost associated with the delivery of the hard copy of the Tender submission.

The Tender Bids particularly the "Price" must be typed and not hand written.

**(Tender Submission via email or fax will not be accepted)**