

MATERIAL SPECIFICATION

VOCAB NUMBER	ITEM DESCRIPTION
111006	CONDUCTOR, 37/3.00, ALL ALUMINIUM, (AAC) "SATURN" SIZE: 21.00MM DIA. X 261MM ²

SPECIFICATION DETAILS

- General Requirements:** All aluminium conductor in accordance with AS 1531 - 1991
"Conductor – Bare overhead Aluminium and Aluminium Alloy"
- Strand:** 37/3.00.
- Packing Length:** 2000metres
- Quality Standard References:** AS 1531 -1991.

The Conductor shall be supplied on timber drums in accordance with the attached general specification. Attention is drawn to the requirements of clause 7

- Unit of Measure:** Metre
- Rejection:** PNG Power Ltd reserves all rights to reject whole or part of the order not complying with this specification and is not liable for any cost or loss with the return of rejects to the Supplier. Facilitation of Invoice Credit must commence between the supplier and PNG Power Ltd through the process of PNG Power Ltd Discrepancy Report provisions.

Drawing References:

Manufacturer's Product Code:

ENGINEERING STANDARDS APPROVAL

Approval by: Grevasius Peni
T/L Standards & Materials

Signature: 

Date: 9 / 7 / 20

DATA REVIEW ENDORSEMENT

NAME	TITLE	SIGNATURE	DATE
Rawali Rawali	Engineer - Standards and Materials		

SPECIFICATION DETAILS FOR VOCAB 111006

1. All drums shall comply with AS 2857 "Timber Drums for Insulated Electric Cables and Bare Conductors" and the last amendments.
2. The net contents of any drum shall not exceed the capacity limits of clause 2.1.1 of AS 2857.
3. Spindle Holes shall be reinforced with steel plates in accordance with clause 2.5 of AS 2857.
4. All drums other than those with Plywood flanges shall be supplied with close fittings timber batten lagging in accordance with clause 6.3 of AS 2857.
5. Drums intended to be used for bare aluminium based conductors shall be evenly coated on the barrel and inside flanges with an aluminium paint or approved alternative. See clause 6.1 of AS 2857.
6. Drums intended to be used for underground cables shall be fabricated from preservative treated timber.
 - 6.1 Preservative treatment of timber shall comply with the requirements of AS 1604 "Preservative Treated timber, Veneer and Plywood."
 - 6.2 Timber shall be seasoned to 30% moisture content or less and shall be Vacuum-pressure impregnated with recognized waterborne CCA preservative prior to construction and assembly of the drum.
 - 6.3 Preservative treatment shall comply with the minimum retention specified for hazard level H5 (outdoor, unpainted, moderate) as set out in table 2 of AS 1604.
7. Drums markings shall be in accordance with AS 2857 with the following information;
 - a) A description of the construction of the cable and conductors.
 - b) The conductor material and the conductor cross-section
 - c) The number of cores and the voltage rating of the cable.
 - d) The length of cable or conductor on the drum.
 - e) The PNG Power Vocabulary numbers as shown on the particular Material Specification.

NB: Additional marking may be required by the particular material specification which should be read in conjunction with this clause.