

52ST400  
Intr. 3/12aw



PNG POWER LTD

### MATERIAL SPECIFICATION

VOCAB. NUMBER.	ITEM DESCRIPTION:
132292	CLAMP, INSULATION PIERCING, FOR AERIAL BUNDLED CABLE AND BARE COPPER CONDUCTOR 6-35/35-95MM <sup>2</sup>

Item Category = A

#### SPECIFICATION DETAILS.

The clamp shall be of the insulation piercing type and shall be designed for application to aerial bundled cable and bare conductor.

Similar to; Sicame NTD 151 F

Fittings shall be marked with the following information,

- a) Manufacturer's name or trade mark
- b) Cross sectional area range for each side
- c) Installing torque in Newton-metres

Type test and full technical details of the clamp shall be provided with the Tender.

**Unit of Measure:** Each.

**Rejection:** PNG Power Ltd, reserves all rights to reject whole or part of the order not complying with this specification and is not liable for any cost or loss with the return of rejects to the Supplier. Facilitation of Invoice credit must commence between the supplier and PNG Power Ltd through the process of PNG Power Ltd Discrepancy Report provisions.

*Drawing References:*

*Manufacturers Product code:*

#### STANDARDS COMMITTEE APPROVAL

APPROVED BY:

*Alex Oa*  
Chairman

SIGNATURE: .....

DATE *22.5.2015*

#### DATA REVIEW ENDORSEMENT

NAME	TITLE	SIGNATURE	DATE
<i>Grevasias Peni</i>	TL. Standards	<i>[Signature]</i>	<i>20/5/15</i>
<i>G. PENI</i>	<i>/</i>	<i>[Signature]</i>	<i>25/1/19</i>