

## MATERIAL SPECIFICATION

VOCAB NUMBER	ITEM DESCRIPTION
132293	<b>CLAMP, INSULATION PIERCING FOR AERIAL BUNDLED CABLE AND BARE COPPER CONDUCTOR 35-95/7-95MM<sup>2</sup></b>

SPECIFICATION DETAILS
-----------------------

The clamp shall be of the insulation piercing type and shall be designed for application to Aerial Bundled Cable and Bare Copper Conductor.

Similar to Sicame 301F.

Fittings shall be marked with the following information:

- a) Manufacturer's name or trade mark
- b) Cross sectional area range for each side
- c) Installing torque in Newton-metres

Type tests and full technical details of the clamp shall be provided with the tender.

- **Unit of Measure: Each**
- **Rejection:** PNG Power Ltd reserves all rights to reject whole or part of the order not complying with this specification and is not liable for any cost or loss with the return of rejects to the Supplier. Facilitation of Invoice Credit must commence between the supplier and PNG Power Ltd through the process of PNG Power Ltd Discrepancy Report provisions.

**Drawing References:**

**Manufacturer's Product Code:**




### STANDARDS COMMITTEE APPROVAL

Approval by Alex Oa  
Chairman

Signature: 

Date: 3 / 6 / 2015

### DATA REVIEW ENDORSEMENT

NAME	TITLE	SIGNATURE	DATE
G. Peni	Team Leader Standards and Materials		2/6/15
	✓		25/1/19