

52ST400
Intr. 3/12aw



PNG POWER LTD

MATERIAL SPECIFICATION

VOCAB. NUMBER.	ITEM DESCRIPTION:
132297	CLAMP, INSULATION PIERCING, FOR AERIAL BUNDLED CABLE AND BARE ALUMINIUM CONDUCTOR 35-95/50-150MM ²

Item Category = C

SPECIFICATION DETAILS.

The clamp shall be of the insulation piercing type and shall be designed for application to aerial bundled cable and bare conductor.

Similar to; Sicame NTD 351 AF

Fittings shall be marked with the following information,

- a) Manufacturer's name or trade mark
- b) Cross sectional area range for each side
- c) Installing torque in Newton-metres

Type test and full technical details of the clamp shall be provided with the Tender.

Unit of Measure: Each.

Rejection: PNG Power Ltd, reserves all rights to reject whole or part of the order not complying with this specification and is not liable for any cost or loss with the return of rejects to the Supplier. Facilitation of Invoice credit must commence between the supplier and PNG Power Ltd through the process of PNG Power Ltd, Discrepancy Report provisions.

Drawing References:

Manufacturers Product code:

STANDARDS COMMITTEE APPROVAL

APPROVED BY:

Alex Oa
Chairman

SIGNATURE:

DATE 22 / 5 / 2015

DATA REVIEW ENDORSEMENT

NAME	TITLE	SIGNATURE	DATE
Grevasias Peni	TL. Standards		20/5/15
G. PENI	/		29/01/19