

Structure		SP-LH-AS-003-001, OPGW Suspension Assembly to suit Ø 7.6mm OPGW	SP-LH-AS-004-001, OPGW Strain Assembly to suit Ø 7.6mm OPGW	SP-LH-AS-004-002, OPGW Insulated Strain Assembly to suit Ø 7.6mm Vibration Damper (Anteac Span), Helical, to suit Ø 7.6mm OPGW	Vibration Damper (Back Span), Helical, to suit Ø 7.6mm OPGW	OPGW Joint Box, complete with coiling bracket, and support cleats (see note 5)	Triangular yoke plate, 70mm spacing, 70kN, 16mm									Remarks
Number	Type															
LG	Strain			2	2	0	1									
T1	Strain		3		2	2		1								
T2	Susp	1			2	2										
T3	Susp	1			4	2										
T4	Strain		2		4	4										
T5	Strain		2		4	4										
T6	Susp	1			2	4										
T7	Strain		2		4	2										
T8	Susp	1			4	4										
T9	Strain		2		4	4										
T10	Susp	1			2	4										
T11	Strain		2		2	2										
T12	Strain		2		2	2										
T13	Susp	1			2	2										
T14	Susp	1			2	2										
T15	Strain		2		2	2	1									
T16	Strain		2		2	2										
T17	Susp	1			2	2										
T18	Susp	1			2	2										
T19	Strain		2		4	2										
T20	Susp	1			4	4										
T21	Susp	1			2	4										
T22	Susp	1			2	2										
T23	Strain		2		2	2										
T24	Strain		2		4	2										
T25	Strain		2		4	4										
T26	Strain		2		4	4										
T27	Strain		2		2	4										
T28	Strain		2		4	2	1									
T29	Strain		2		4	4										
T30	Susp	1			2	4										
T31	Strain		2		2	2										
T32	Strain		2		6	2										
T33	Strain		2		2	6										
T34	Susp	1			2	2										
T35	Susp	1			4	2										
T36	Strain		2		2	4										
T37	Susp	1			2	2										
T38	Susp	1			2	2										
T39	Strain		2		2	2										
T40	Strain		2		2	2										
T41	Strain		2		2	2										
T42	Strain		2		2	2										
T43	Strain		3		2	2		1								
Honiara	Strain			2	0	2	1									
TOTAL		17	54	4	120	120	4									

NOTES:
 1. Items and quantities shown does not include Construction & Operational Spares
 2. The contractor shall confirm with the manufacturer the required quantities of vibration dampers.

ALTERATIONS	ORIGINAL ISSUE		FOR INFORMATION ONLY NOT FOR CONSTRUCTION	 SolomonPower <i>energising our nation</i>	Lungga-Honiara 33kV Transmission Line Line Equipment Schedule		
	ENGAGEMENT NO. E307765				Prepared By: AJD	Drawing No.	Rev
	REVIEWED BY:				APPROVED BY: DATE	SP - LH - LS - 002 - 001	0