



TENDER NO: MR 298/2022

**SUPPLY OF UNARMoured CONTROL CABLES FOR VUDA &
CUNNINGHAM 145KV CIRCUIT BREAKER PROJECT**

ADDENDUM No. 1

This addendum is to clarify/modify the cable lengths stated in **clause 4 - Financial** of tender specification.

The bidders are required to note the following **changes** as highlighted in yellow below:

Cable Description	Locations	Cable Size	Number of Cores	Cable length (metres)	Price (VIP FJD for local company or CFR to EFL Depots for overseas company)
Unarmoured AC Cable	Vuda SS (Delivery to Navutu Depot)	4 mm ²	4C + E	500	
		2.5 mm ²	12C + E	6,000	
		2.5 mm ²	8C + E	1,500	
		2.5 mm ²	2C + E	2,500	
	Cunningham SS (Delivery to Kinoya Depot)	4 mm ²	4C + E	500	
		2.5 mm ²	12C + E	1000	
		2.5 mm ²	8C + E	500	
		2.5 mm ²	2C + E	1,000	
Total Cable Cost (VIP FJD)					

All other requirements shall be as per tender specification for MR298/2022.