



**American Samoa Power Authority**

P.O. Box PPB

Pago Pago, American Samoa 96799

Telephone: (684) 699-3057

Email: [procurement@aspower.com](mailto:procurement@aspower.com)

Website: [www.aspower.com](http://www.aspower.com)



ISSUANCE DATE:

**June 14, 2024**

RFP NO.:

**RFQ NO. ASPA24.030 – Supply & Delivery of Two (2) Standby Generators & Automatic Transfer Switches**

SUBJECT:

**Addendum No. 1**

The American Samoa Power Authority hereby issues Addendum No. 1 to amend Request for Proposals (RFP) requirements. This addendum is issued pursuant to the conditions of the RFQ documents and is hereby made part of the RFP. The addendum serves to clarify, revise, and supersede information contained in the RFQ. The Offeror must acknowledge receipt of this addendum in the appropriate space provided in the Addendum Form. Failure to do so may subject the Offeror to disqualification.

- 1. G2 – Standby Power Specification for Wastewater Treatment Plant (Bid Item(s) #3 & 4) has been revised. Attachment G2, attached at the end of this addendum, has been updated. Changes are highlighted in red print.**

Should you have any questions or need clarification, please call me at (684) 699-3057 or [procurement@aspower.com](mailto:procurement@aspower.com).

Sincerely,

**Renee Leotele Togafau**  
Procurement Manager

Please sign and date below to acknowledge receiving Addendum 1. You may return this document via email at [procurement@aspower.com](mailto:procurement@aspower.com), or the ASPA Procurement Office.

**ACKNOWLEDGEMENT OF RECEIVING ADDENDUM 1**

Received by \_\_\_\_\_, this \_\_\_\_\_ day of \_\_\_\_\_, 2024.

Company \_\_\_\_\_ Title \_\_\_\_\_

Fax No. \_\_\_\_\_ Email Address \_\_\_\_\_

## G2 – Specifications for Wastewater Treatment Plant (Bid Item(s) #3 & 4)

Make/Model	Bidders may offer any make/model, subject to the general specifications listed below. A complete brochure or spec sheet of the generator being offered must accompany quotation.
Voltage Output	120/240V AC
Phase	3PH
Frequency	60HZ
Wire	4-Wire
<b>Standby Rating</b>	<b>500KVA</b>
Voltage Requirement	±0.5%
Frequency Requirement	±0.25%
Engine	4 Stroke Multi Cylinder Water Cooled Coldstart Direct Fuel Injection Turbo-Charged
Speed Governor	Yes
Alarm Shutdown System	Yes
Cooling System	Yes
Lubricating and Fuel Oil Filters	Fuel Low Type
Noise	Sound Attenuated
Air Filters	Yes
Mounting	Skid Frame Forklift Pocket
Fuel Tanks	UL Rated Sub-Base 24HR Run Time
Trailer	Not Required
Exterior	Weather Resistant Aluminum Enclosure Hinged Access Doors
Generator Control Panel	High Visibility LCD Display Screen Emergency Stop

	Main Genset Breaker Provision for ATS integration
<b>AUTOMATIC TRANSFER SWITCH SPECIFICATIONS</b>	
<b>Make/Model</b>	Bidders may offer <b>generally acceptable</b> make/model, subject to the general specifications listed below. A complete brochure or spec sheet of the ATS being offered must accompany quotation.
Transition	Open
<b>Current Rating</b>	<b>1200A</b>
Pole	3
<b>Enclosure</b>	<b>For Outdoor Installation</b>
Voltage	120V/240V
Phase	3
Wire	4 Wire (Solid neutral)
Frequency	60HZ