



American Samoa Power Authority

P.O. Box PPB
Pago Pago, American Samoa 96799
Telephone: (684) 699-3057
Email: procurement@aspower.com
Website: www.aspower.com



ISSUANCE DATE: **July 30, 2024**
RFP NO.: **RFQ NO. ASPA24.034 – 500K Gallon Water Tank**
SUBJECT: **Addendum No. 1**

The American Samoa Power Authority hereby issues Addendum No. 1 to amend Request for Quotations (RFQ) requirements. This addendum is issued pursuant to the conditions of the RFQ documents and is hereby made part of the RFQ. The addendum serves to clarify, revise, and supersede information contained in the RFQ. The Offeror must acknowledge receipt of this addendum in the appropriate space provided in the Addendum Form. Failure to do so may subject the Offeror to disqualification.

1. Responses to inquiries received for this tender are included as part of this Addendum #1.

Should you have any questions or need clarification, please call me at (684) 699-3057 or procurement@aspower.com.

Sincerely,

Renee Leotele Togafau
Procurement Manager

Please sign and date below to acknowledge receiving Addendum 1. You may return this document via email at procurement@aspower.com, or the ASPA Procurement Office.

ACKNOWLEDGEMENT OF RECEIVING ADDENDUM 1

Received by _____, this _____ day of _____ 2024.
Company _____ Title _____
Fax No. _____ Email Address _____

RFQ NO. ASPA24.034 - 500K Glass Fused to Steel Water Tank

No	Question	Answer:
1	Please clarify the following: (a) Nominal diameter; (b) Max nominal tank sidewall height; (c) design freeboard; (d) minimum nominal tank capacity; (e) minimum usable tank capacity	a) 52.63 feet b) 31.93 feet c) 1 feet d) 500,000 + us gallons e) 500,000 us gallons
2	Is this a supply only request, or is the contractor required to install as well?	ASPA will install the tank
3	Regarding tank foundation, can you please provide the following: (a) maximum allowable soils design bearing capacity; (b) site class as per projects geo-technical report; (c) frost depth as per projects geo technical report; (d) frof depth as per projects geotechnical report	ASPA will design the Foundation
4	Include the tank mixer or Tideflex mixing system	