

Month and Year: January, 2022

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
1/1/22						1.3	254417.								
1/2/22						1.3	255763.								
1/3/22	0.2		27.0	7.0	6.9	1.3	257109.			6.6	0.1				
1/4/22	0.0		28.0	7.1	6.9	1.3	258423.								
1/5/22	0.3		27.0	7.1	7.0	1.2	259576.		20000.0	6.6	0.1				
1/6/22	0.4		28.0	7.0	6.9	1.1	260699.			6.7	0.1			235	
1/7/22	0.0		28.0	7.0	6.9	1.4	262064.			6.5	0.1				
1/8/22						1.4	263457.								
1/9/22						1.4	264850.								
1/10/22	0.2		28.0	7.1	6.9	2.0	266243.			6.7	0.1				
1/11/22	0.5		28.0	7.1	7.0	0.6	267481.			6.7	0.1				
1/12/22	0.9		27.0	7.1	7.0	1.2	268639.		8000.0	6.6	0.1				
1/13/22	0.8		28.0	7.1	6.9	1.3	269966.			6.7	0.1			210	1
1/14/22	1.0		28.0	7.1	7.0	1.3	271263.			6.8	0.1				
1/15/22						1.4	272702.								
1/16/22						1.4	274141.								
1/17/22						1.4	275580.								
1/18/22	0.4		28.0	7.0	6.9	1.4	277020.			6.5	0.1				
1/19/22	0.0		28.0	7.1	7.0	1.1	278080.			6.6	0.1				
1/20/22	0.0		28.0	7.1	7.0	1.2	279307.			6.6	0.1			205	1
1/21/22	3.6		28.0	7.2	7.0	1.8	281061.			6.8	0.1				
1/22/22						1.3	282367.								
1/23/22						1.3	283673.								
1/24/22	0.0		29.0	7.0	6.9	1.3	284979.			6.5	0.1				
1/25/22	0.0		28.0	7.0	6.9	1.2	286138.			6.5	0.1				
1/26/22	0.0		28.0	7.1	6.9	1.2	228730		52000.0	6.5	0.1				
1/27/22	0.8		28.0	7.1	6.9	1.2	288549.			6.7	0.1			305	1
1/28/22	0.9		28.0	7.0	6.9	1.4	289943.			6.7	0.1				
1/29/22						1.4	291330.								
1/30/22						1.4	292717.								
1/31/22	0.5		28.0	7.0	6.9	1.4	294103.			6.6	0.1				
Total	10.7					41.0			80000.0	125.9	1.9				
Max.	3.6		29.0	7.2	7.0	2.0	228730			6.8	0.1			305	1
Min.	0.0		27.0	7.0	6.9	0.6		254417.		6.5	0.1			205	
Avg.	0.5		27.9	7.1	6.9	1.3				6.6	0.1			239	1

Signature - Plant Manager _____

CEO _____

Month and Year: February, 2022

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
2/1/22	4.0		28.0	7.1	6.9	1.7	295818.			6.8	0.2				
2/2/22	1.6		28.0	7.1	6.9	1.3	297148.			6.7	0.1				
2/3/22	3.0		28.0	7.1	6.9	1.8	298942.		20000.0	6.7	0.1			325	1
2/4/22	0.6		28.0	7.1	6.9	1.6	300587.		14000.0	6.6	0.1				
2/5/22						1.4	302024.								
2/6/22						1.4	303461.								
2/7/22	0.1		28.0	7.1	6.9	1.4	304898.		12000.0	6.6	0.1				
2/8/22	0.7		28.0	7.1	6.9	1.2	306091.		8000.0	6.7	0.1				
2/9/22	0.2		28.0	7.1	6.9	1.3	307351.		8000.0	6.6	0.1				
2/10/22	0.0		28.0	7.0	6.9	1.3	308701.			6.5	0.1			295	1
2/11/22	0.7		28.0	7.1	6.9	1.3	309995.			6.5	0.1				
2/12/22						1.7	310825.								
2/13/22						1.7	311655.								
2/14/22	0.4		27.0	7.0	6.9	1.7	312486.			6.6	0.1				
2/15/22	0.4		27.0	7.0	6.9	1.3	313739.			6.6	0.1				
2/16/22	0.0		27.0	7.1	6.9	1.0	314750.			6.6	0.1				
2/17/22	1.5		27.0	7.1	7.0	1.3	316091.		28000.0	6.6	0.1			151	1
2/18/22	2.0		27.0	7.1	7.0	2.0	318111.		12000.0	6.7	0.1				
2/19/22						1.6	319044.								
2/20/22						1.6	319977.								
2/21/22						1.6	320910.								
2/22/22	0.8		27.0	7.1	6.9	1.6	321843.			6.7	0.1				
2/23/22	0.8		27.0	7.1	6.9	1.8	322776.			6.7	0.1				
2/24/22	0.6		27.0	7.1	6.9	1.8	323707.		20000.0	6.6	0.1				
2/25/22	0.5		28.0	7.1	6.9	1.5	325191.			6.6	0.1			185	1
2/26/22						1.5	326633.								
2/27/22						1.5	328075.								
2/28/22	0.1		28.0	7.0	6.9	-1538.8	329518.	0.0		6.5	0.1				
Total	17.8					-1497.6	2.0		122000.0	125.9	2.0				
Max.	4.0		28.0	7.1	7.0		329518.			6.8	0.2			325	1
Min.	0.0		27.0	7.0	6.9	-1538.8		295818.		6.5	0.1			151	1
Avg.	0.9		27.6	7.1	6.9	-53.5				6.6	0.1			239	1

Signature - Plant Manager _____

CEO _____

Month and Year: March, 2022

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
3/1/22	0.2		28.0	7.0	6.9	1.3	330833.			6.5	0.1				
3/2/22	0.2		28.0	7.0	6.9	1.6	332403.			6.5	0.1				
3/3/22	0.2		28.0	7.0	6.9	1.1	333476.			6.5	0.1			211	1
3/4/22	0.2		28.0	7.0	6.9	1.2	334679.			6.5	0.1				
3/5/22						1.1	335827.								
3/6/22						1.1	336975.								
3/7/22	0.2		28.0	7.0	6.9	1.2	338125.			6.5	0.1				
3/8/22	0.2		28.0	7.0	6.9	1.5	339629.			6.5	0.1				
3/9/22	0.2		28.0	7.0	6.9	1.2	340844.			6.5	0.1				
3/10/22	0.2		28.0	7.0	6.9	1.6	342439.			6.5	0.1				
3/11/22	0.2		28.0	7.0	7.0	1.1	343569.			6.5	0.1				
3/12/22						1.3	344914.								
3/13/22						1.3	346259.								
3/14/22	0.2		28.0	7.0	7.0	1.3	347605.			6.5	0.1				
3/15/22	0.2		28.0	7.1	7.0	1.5	349101.			6.5	0.1				
3/16/22	0.1		28.0	7.1	7.0	1.3	350367.			6.5	0.1				
3/17/22	0.1		28.0	7.1	7.0	1.2	351594.			6.5	0.1			157	1
3/18/22	0.1		28.0	7.1	7.0	1.3	352927.			6.5	0.1				
3/19/22						1.4	353030.								
3/20/22						1.4	355679.								
3/21/22	0.1		28.0	7.1	6.9	1.4	357056.			6.5	0.1				
3/22/22	0.1		28.0	7.1	7.0	0.8	358612.		24000.0	6.5	0.1				
3/23/22	0.1		28.0	7.1	7.0	0.8	358612.		24000.0	6.5	0.1				
3/24/22	0.1		28.0	7.0	6.9	0.7	359344.			6.5	0.1			147	
3/25/22	0.2		28.0	7.1	7.0	0.7	360077.		24000.0	6.5	0.1				
3/26/22						1.4	361516.								
3/27/22						1.4	362955.								
3/28/22	2.1		28.0	7.0	6.9	1.4	364394.			6.5	0.1				
3/29/22	0.0		28.0	7.0	6.9	1.4	365833.			6.5	0.1				
3/30/22	0.1		28.0	7.0	6.9	1.3	367091.			6.5	0.1				
3/31/22	0.1		28.0	7.0	6.9	1.3	368368.			6.5	0.1			135	
Total	4.9					38.9			72000.0	149.5	2.3				
Max.	2.1		28.0	7.1	7.0	1.6	368368.			6.5	0.1			211	1
Min.	0.0		28.0	7.0	6.9	0.7		330833.		6.5	0.1			135	
Avg.	0.2		28.0	7.0	6.9	1.3				6.5	0.1			163	1

Signature - Plant Manager _____

CEO _____

Month and Year: April, 2022

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested sludge drawn to beds (gallons)	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.		Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
4/1/22	0.1		28.0	7.1	6.9	1.3	36966.3			6.5	0.1				
4/2/22						1.4	37102.2								
4/3/22						1.4	37238.1								
4/4/22	0.3		28.0	7.1	7.0	1.4	37374.0			6.5	0.1				
4/5/22	0.0		28.0	7.1	7.0	1.1	37488.8			6.5	0.1				
4/6/22	0.0		28.0	7.1	7.0	1.3	37620.4			6.5	0.1				
4/7/22	0.5		28.0	7.1	7.0	1.4	37760.7			6.5	0.1			139	
4/8/22	0.5		28.0	7.1	7.0	1.4	37898.7			6.5	0.1				
4/9/22						1.4	38039.6								
4/10/22						1.4	38180.5								
4/11/22	0.3		28.0	7.1	7.0	1.4	38321.3			6.5	0.1				
4/12/22	0.0		28.0	7.1	7.0	1.2	38443.0			6.5	0.1				
4/13/22	0.5		28.0	7.1	7.0	1.4	38578.3			6.5	0.1				
4/14/22	0.0		28.0	7.1	7.0	1.3	38707.7			6.5	0.1			172	
4/15/22						1.4	38845.9								
4/16/22						1.4	38984.1								
4/17/22						1.4	39122.1								
4/18/22						1.4	39260.3								
4/19/22	0.2		28.0	7.1	7.0	1.4	39398.5			6.5	0.1				
4/20/22	0.0		28.0	7.1	7.0	1.2	39517.4			6.6	0.1				
4/21/22	0.1		28.0	7.1	7.0	1.2	39641.9			6.5	0.1			162	
4/22/22	0.3		28.0	7.1	7.0	1.3	39776.6			6.6	0.1				
4/23/22						1.0	39881.3								
4/24/22						1.0	39986.0								
4/25/22	0.2		28.0	7.0	6.9	1.0	40090.8			6.5	0.1				
4/26/22	0.6		28.0	7.0	6.9	1.3	40222.9			6.5	0.1				
4/27/22	0.4		27.0	7.0	6.9	1.3	40353.7			6.5	0.1				
4/28/22	1.0		28.0	7.1	6.9	1.4	40490.0			6.5	0.1			129	
4/29/22	0.5		28.0	7.1	6.9	1.5	40638.9		10000.0	6.5	0.1				
4/30/22						0.9	40730.3								
Total	5.3					38.9			10000.0	123.7	1.9				
Max.	1.0		28.0	7.1	7.0	1.5	40730.3			6.6	0.1			172	
Min.	0.0		27.0	7.0	6.9	0.9	36966.3			6.5	0.1			129	
Avg.	0.3		27.9	7.1	7.0	1.3				6.5	0.1			151	

Signature - Plant Manager _____

CEO _____

Month and Year: May, 2022

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
5/1/22						0.9	40821.7								
5/2/22	0.2		27.0	7.0	7.0	0.9	40913.1			6.5	0.1				
5/3/22	0.0		27.0	7.0	7.0	1.2	41031.4			6.5	0.1				
5/4/22	0.0		28.0	7.0	7.0	1.6	41195.0			6.5	0.1				
5/5/22	0.7		28.0	7.1	7.0	1.0	41295.5		8000.0	6.6	0.1			162	
5/6/22	0.1		28.0	7.0	7.0	1.3	41429.8								
5/7/22						1.4									
5/8/22						1.4									
5/9/22	0.0		28.0	0.0	7.0	1.4	41845.5			6.5	0.1				
5/10/22	0.0		28.0	7.0	7.0	1.3	41972.3			6.5	0.1				
5/11/22	0.0		27.0	7.0	6.9	1.3			41250.0	6.5	0.1				
5/12/22	0.0		28.0	7.0	6.9	1.1	42210.3			6.5	0.1			172	
5/13/22	1.5		28.0	7.0	6.9	1.5	42388.8			6.7	0.1				
5/14/22						1.5									
5/15/22						1.5									
5/16/22	0.8		27.0	7.1	6.9	1.5				6.8	0.2				
5/17/22	0.5		27.0	7.0	6.9	1.4				6.6	0.1				
5/18/22	0.8		27.0	7.1	6.9	1.5			15000.0	6.7	0.2				
5/19/22	0.0		28.0	7.0	7.0	1.4				6.5	0.1			146	
5/20/22	0.3		28.0	7.0	7.0	1.3				6.5	0.1				
5/21/22						1.4									
5/22/22						1.4									
5/23/22	0.2		28.0	7.1	7.0	1.4				6.5	0.1				
5/24/22	0.0		28.0	7.0	7.0	1.3			38000.0	6.5	0.1				
5/25/22	0.1		28.0	7.1	7.0	1.4				6.5	0.2				
5/26/22	0.6		27.0	7.1	7.0	1.4				6.7	0.2			171	
5/27/22	0.1		28.0	7.0	7.0	1.5				6.5	0.1				
5/28/22						1.3									
5/29/22						1.3									
5/30/22						1.3									
5/31/22	0.2		28.0	7.0	7.0	1.3				6.6	0.1				
Total	6.2					41.7			102250.0	131.2	2.4				
Max.	1.5		28.0	7.1	7.0	1.6	42388.8			6.8	0.2			172	
Min.	0.0		27.0	0.0	6.9	0.9	40821.7			6.5	0.1			146	
Avg.	0.3		27.7	6.7	7.0	1.3				6.6	0.1			163	

Signature - Plant Manager _____

CEO _____

Month and Year: June, 2022

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
6/1/22	0.0		28.0	7.0	6.9	1.7	45072.4			6.5	0.1				
6/2/22	0.0		28.0	7.0	6.9	1.3	45197.4			6.5	0.1			151	
6/3/22	0.1		28.0	7.0	6.9	1.3	45328.7			6.5	0.1				
6/4/22						1.4	45471.8								
6/5/22						1.4	45614.9								
6/6/22	0.1		28.0	7.0	7.0	1.4	45757.9			6.5	0.1				
6/7/22	0.0		28.0	7.0	7.0	1.2	45876.8		12000.0	6.5	0.1				
6/8/22	0.0		28.0	7.0	7.0	1.2	45999.8		27750.0	6.5	0.1				
6/9/22	0.1		27.0	7.0	6.9	1.3	46126.1			6.5	0.1			230	
6/10/22	0.1		28.0	7.0	6.9	1.4	46262.6			6.5	0.1				
6/11/22						1.4	46405.2								
6/12/22						1.4	46547.8								
6/13/22	0.1		28.0	7.0	7.0	1.4	46690.5			6.5	0.1				
6/14/22	0.1		28.0	7.0	7.0	1.3	46816.0			6.5	0.1				
6/15/22	0.1		28.0	7.0	7.0	1.2	46939.1		31000.0	6.5	0.1				
6/16/22	0.1		28.0	7.0	7.0	1.3	47069.9			6.5	0.1			178	
6/17/22	0.1		28.0	7.0	7.0	1.4	47204.9			6.6	0.1				
6/18/22						1.5	47352.1								
6/19/22						1.5	47499.3								
6/20/22						1.5	47646.5								
6/21/22	0.1		28.0	7.0	7.0	1.5	47793.6		12000.0	6.6	0.1				
6/22/22	0.0		28.0	6.9	6.9	1.2	47911.5		20000.0	6.5	0.1				
6/23/22	0.4		28.0	7.0	6.9	1.4	48049.1			6.5	0.1			181	
6/24/22	0.1		28.0	7.0	6.9	1.4	48189.5			6.5	0.1				
6/25/22						1.6	48352.5								
6/26/22						1.6	48515.5								
6/27/22	0.8		28.0	7.0	6.9	1.6	48678.4			6.7	0.1				
6/28/22	0.5		28.0	7.0	6.9	1.3	48813.1			6.6	0.1				
6/29/22	0.3		28.0	7.0	7.0	1.3	48944.0		32000.0	6.5	0.1				
6/30/22	0.1		28.0	7.0	7.0	1.3	49074.3			6.5	0.1			153	
Total	3.0					41.7			134750.0	137.0	2.1				
Max.	0.8		28.0	7.0	7.0	1.7	49074.3			6.7	0.1			230	
Min.	0.0		27.0	6.9	6.9	1.2	45072.4			6.5	0.1			151	
Avg.	0.1		28.0	7.0	7.0	1.4				6.5	0.1			179	

Signature - Plant Manager _____

CEO _____

Month and Year: July, 2022

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested sludge drawn to beds (gallons)	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.		Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
7/1/22	0.0		28.0	7.0	7.0	1.3	49204.6			6.5	0.1				
7/2/22						1.4	49340.7								
7/3/22						1.4	49476.8								
7/4/22						1.4	49612.9								
7/5/22	0.0		28.0	7.0	6.9	1.4	49749.1			6.5	0.1				
7/6/22	0.2		28.0	7.0	6.9	1.2	49871.4		12000.0						
7/7/22	0.4		27.0	7.0	6.9	1.2	49990.1			6.7	0.1			165	
7/8/22	0.9		27.0	7.0	7.0	1.4	50132.0			6.7	0.1				
7/9/22						1.1	50239.8								
7/10/22						1.1	50347.6								
7/11/22	0.6		27.0	7.0	6.9	2.2	50563.4			6.7	0.1				
7/12/22	0.1		28.0	7.0	7.0	1.5	50715.1			6.5	0.1				
7/13/22	0.4		28.0	7.0	7.0	1.5	50866.8			6.5	0.1				
7/14/22	0.7		27.0	7.0	6.9	1.5	510185.			6.6	0.1			225	1
7/15/22						0.0	51018.5								
7/16/22						2.4	51256.7								
7/17/22						1.2	51375.8								
7/18/22	0.3		28.0	7.0	7.0	1.7	517478.			6.5	0.1				
7/19/22	0.1		28.0	7.0	7.0	0.7	516140.			6.5	0.1				
7/20/22	0.1		28.0	7.0	7.0	2.6	518747.			6.5	0.1				
7/21/22	0.0		28.0	7.0	7.0	1.3	520085.			6.5	0.1			165	
7/22/22	0.1		28.0	7.0	7.0	1.4	521521.			6.5	0.1				
7/23/22						1.3									
7/24/22						1.3	52419.3								
7/25/22	0.2		28.0	7.0	7.0	1.3	52552.8			6.5	0.1				
7/26/22	0.1		28.0	7.0	7.0	1.2	52669.6			6.5	0.1				
7/27/22	0.0		28.0	7.0	7.0	1.1	52783.4			6.5	0.1				
7/28/22	0.0		28.0	7.0	7.0	1.2	52903.8			6.5	0.1			165	
7/29/22	0.0		28.0	7.0	7.0	1.3	53031.3			6.5	0.1				
7/30/22						1.4	53166.8								
7/31/22						1.4	53302.3								
Total	4.3					42.3			12000.0	117.7	1.8				
Max.	0.9		28.0	7.0	7.0	2.6	521521.			6.7	0.1			225	1
Min.	0.0		27.0	7.0	6.9	0.0		49204.6		6.5	0.1			165	
Avg.	0.2		27.8	7.0	7.0	1.4				6.5	0.1			180	

Signature - Plant Manager _____

CEO _____

Month and Year: August, 2022

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
8/1/22	0.2		28.0	7.0	7.0	1.4	53437.8								
8/2/22	0.2		28.0	7.1	7.0	1.3	53566.0		20000.0	6.5	0.1				
8/3/22	0.1		28.0	7.0	7.0	1.2	53684.9		20000.0	6.5	0.1				
8/4/22	0.6		28.0	7.0	6.9	1.3	53812.2			6.6	0.1			230	
8/5/22	0.4		27.0	7.0	6.9	1.3	53942.9			6.6	0.1				
8/6/22						1.4	54079.8								
8/7/22						1.4	54216.7								
8/8/22	0.1		28.0	7.0	7.0	1.4	54353.6		6000.0	6.5	0.1				
8/9/22	0.1		28.0	7.0	7.0	1.4	54489.5			6.5	0.1				
8/10/22	0.0		28.0	7.0	7.0	1.3	54620.8			6.5	0.1				
8/11/22	0.0		28.0	7.0	7.0	1.3	54753.0		40000.0	6.5	0.1			138	
8/12/22	0.6		27.0	7.0	7.0	1.4	54894.8			6.6	0.1				
8/13/22						1.5	55044.6								
8/14/22						1.5	55194.7								
8/15/22	0.4		28.0	7.1	7.0	1.5	55345.1			6.5	0.1				
8/16/22	0.3		27.0	7.1	6.9	1.4	55480.8			6.6	0.1				
8/17/22	0.0		28.0	7.0	7.0	1.3	55609.7		51000.0	6.5	0.1				
8/18/22	0.0		28.0	7.0	7.0	1.3	55738.3			6.5	0.1			131	
8/19/22	0.0		28.0	7.0	7.0	1.3	55870.6			6.5	0.1				
8/20/22						1.5	56021.4								
8/21/22						1.5	56172.2								
8/22/22	0.4		28.0	7.0	7.0	1.5	56322.9			6.5	0.1				
8/23/22	0.0		28.0	7.0	7.0	1.2	56445.1			6.5	0.1				
8/24/22	0.0		28.0	7.0	7.0	1.2	56562.9			6.5	0.1				
8/25/22	0.2		28.0	7.0	7.0	1.3	56688.3			6.6	0.1			130	
8/26/22	0.2		28.0	7.0	7.0	1.2	56813.0		20000.0	6.6	0.1				
8/27/22						1.3	56946.2								
8/28/22						1.3	57079.4								
8/29/22	0.1		28.0	7.0	7.0	1.3	57212.7			6.5	0.1				
8/30/22	0.0		28.0	7.0	7.0	1.2	57332.0			6.5	0.1				
8/31/22	0.0		28.0	7.0	7.0	1.2	57449.0			6.5	0.1				
Total	3.9					41.5			157000.0	150.1	2.3				
Max.	0.6		28.0	7.1	7.0	1.5	57449.0			6.6	0.1			230	
Min.	0.0		27.0	7.0	6.9	1.2	53437.8			6.5	0.1			130	
Avg.	0.2		27.9	7.0	7.0	1.3				6.5	0.1			157	

Signature - Plant Manager _____

CEO _____

Month and Year: September, 2022

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
9/1/22	0.9		28.0	7.0	7.0	1.3	57581.8		17000.0	6.5	0.1			161	
9/2/22	0.9		28.0	7.0	7.0	1.2	57697.7			6.5	0.1				
9/3/22						1.3	57832.0								
9/4/22						1.3	57966.3								
9/5/22						1.3	58100.6								
9/6/22	0.1		28.0	7.0	7.0	1.3	58234.8			6.5	0.1				
9/7/22	0.1		28.0	7.0	7.0	1.1	58347.0			6.5	0.1				
9/8/22	0.1		28.0	7.0	7.0	1.2	58468.1			6.5	0.1				
9/9/22	0.2		28.0	7.0	7.0	1.2	58587.0		15500.0	6.5	0.1			124	
9/10/22						1.4	58725.4								
9/11/22						1.3	58859.6								
9/12/22			28.0	7.0	7.0	1.4	59002.2		24000.0	6.5	0.1				
9/13/22	0.0		28.0	7.0	7.0	1.1	59112.2			6.5	0.1				
9/14/22	0.1		28.0	7.0	7.0	1.2	59235.9		24000.0	6.5	0.1				
9/15/22	0.0		28.0	7.0	7.0	1.2	59360.5			6.5	0.1				
9/16/22	0.2		28.0	7.0	7.0	1.3	59493.7			6.5	0.1			130	
9/17/22						1.3	59625.7								
9/18/22						1.3	59757.7								
9/19/22	0.1		28.0	7.0	7.0	1.3	59889.8		12000.0	6.5	0.1				
9/20/22	0.0		28.0	7.0	7.0	1.2	60005.5		20000.0	6.5	0.1				
9/21/22	0.1		28.0	7.0	7.0	1.2	60122.6			6.5	0.1				
9/22/22	0.1		28.0	7.0	7.0	1.1	60237.2			6.5	0.1				
9/23/22	0.4		28.0	7.1	7.0	1.2	60354.2		4000.0	6.5	0.1			146	
9/24/22						1.4	60496.0								
9/25/22						1.4	60637.8								
9/26/22	0.1		28.0	7.0	7.0	1.4	60779.6			6.5	0.1				
9/27/22	0.0		28.0	7.0	7.0	1.1	60892.8		12000.0	6.5	0.1				
9/28/22	0.0		28.0	7.0	7.0	1.1	61002.5			6.5	0.1				
9/29/22	0.2		28.0	7.0	7.0	1.4	61138.0			6.5	0.1				
9/30/22	0.0		28.0	7.0	7.0	1.1	61252.3			6.5	0.1			107	
Total	3.7					38.0			128500.0	136.5	2.1				
Max.	0.9		28.0	7.1	7.0	1.4	61252.3			6.5	0.1			161	
Min.	0.0		28.0	7.0	7.0	1.1	57581.8			6.5	0.1			107	
Avg.	0.2		28.0	7.0	7.0	1.3				6.5	0.1			134	

Signature - Plant Manager _____

CEO _____

Month and Year: October, 2022

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
10/1/22						1.4	61390.4								
10/2/22						1.4	61528.5								
10/3/22	0.1		28.0	7.0	7.0	1.4	61666.7		16000.0	6.5	0.1				
10/4/22	0.1		28.0	7.0	7.0	1.2	61782.2			6.5	0.1				
10/5/22	0.1		28.0	7.0	7.0	1.2	61897.6			6.6	0.1				
10/6/22	0.1		28.0	7.0	7.0	1.2	62020.3			6.6	0.1			119	
10/7/22	0.0		28.0	7.0	7.0	1.2	62140.3		20000.0	6.5	0.1				
10/8/22						1.4	62277.7								
10/9/22						1.4	62415.1								
10/10/22						1.4	62552.5								
10/11/22	0.0		28.0	7.0	7.0	1.4	62689.9			6.5	0.1				
10/12/22	0.0		28.0	7.0	7.0	1.1	62801.8			6.5	0.1				
10/13/22	0.1		28.0	7.0	7.0	1.2	62920.3			6.5	0.1			107	
10/14/22	0.2		28.0	7.0	7.0	1.3	63046.4		9000.0	6.5	0.1				
10/15/22						1.2	63167.6								
10/16/22	0.1		28.0	7.0	7.0	1.2	63288.9			6.5	0.1				
10/17/22	0.7		28.0	7.0	7.0	1.6	63449.1			6.7	0.1				
10/18/22	0.0		28.0	7.0	7.0	1.1	63558.6			6.6	0.1				
10/19/22	0.0		28.0	7.1	7.0	1.2	63674.4			6.5	0.1				
10/20/22	0.0		27.0	7.1	6.9	1.1	63782.5			6.5	0.1			125	
10/21/22	0.0		27.0	7.0	6.9	1.1	63896.9			6.5	0.1				
10/22/22						1.5	64042.2								
10/23/22						1.5	64187.5								
10/24/22	1.0		28.0	7.0	6.9	1.5	64332.9			6.8	0.1				
10/25/22	0.0		28.0	7.0	6.9	1.2	64452.6			6.5	0.1				
10/26/22	0.1		28.0	7.0	6.9	1.1	64565.9			6.5	0.1				
10/27/22	5.9		27.0	7.1	7.0	2.2	64785.5			6.5	0.1			159	
10/28/22	0.2		27.0	7.0	6.9	1.9	64971.1			6.5	0.1				
10/29/22						1.5	65124.1								
10/30/22						1.5	65277.1								
10/31/22	0.9		27.0	7.1	6.9	1.5	65430.2			6.5	0.1				
Total	9.5					41.8			45000.0	137.3	2.1				
Max.	5.9		28.0	7.1	7.0	2.2	65430.2			6.8	0.1			159	
Min.	0.0		27.0	7.0	6.9	1.1	61390.4			6.5	0.1			107	
Avg.	0.5		27.8	7.0	7.0	1.3				6.5	0.1			128	

Signature - Plant Manager _____

CEO _____

Month and Year: November, 2022

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested sludge drawn to beds (gallons)	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.		Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
11/1/22	0.0		27.0	7.1	7.0	1.4	65567.3			6.5	0.1				
11/2/22	0.0		27.0	7.0	6.9	1.2	65682.5			6.5	0.1				
11/3/22	1.5		27.0	7.0	6.9	1.5	65836.7			6.5	0.1			159	
11/4/22	0.0		27.0	7.0	6.9	1.6				6.5	0.1				
11/5/22						1.6									
11/6/22						1.6									
11/7/22	0.2		27.0	7.1	7.0	1.6				6.5	0.1				
11/8/22	0.0		27.0	7.1	7.0	1.2	66580.9			6.5	0.1				
11/9/22	0.9		28.0	7.0	6.9	1.4	66724.2			6.6	0.1				
11/10/22	0.1		28.0	7.1	6.9	1.3	66858.4			6.6	0.1			138	
11/11/22						1.3									
11/12/22						1.3									
11/13/22						1.3									
11/14/22	0.1		28.0	7.0	6.9	1.3				6.5	0.1				
11/15/22	0.8		28.0	7.1	6.9	1.2				6.6	0.1				
11/16/22	0.5		28.0	7.0	6.9	1.4				6.7	0.1				
11/17/22	0.0		27.0	7.0	6.9	1.3			13000.0	6.5	0.1			225	
11/18/22	0.0		27.0	7.1	6.9	1.2				6.5	0.1				
11/19/22						1.4									
11/20/22						1.4									
11/21/22	0.1		28.0	7.0	6.9	1.4				6.5	0.1				
11/22/22	1.2		27.0	7.1	6.9	1.1			15000.0	6.7	0.1				
11/23/22	0.0		27.0	7.0	6.9	1.0				6.5	0.1			150	
11/24/22						1.3									
11/25/22	0.1		27.0	7.0	6.9	1.3				6.5	0.1				
11/26/22						0.0									
11/27/22	1.2		27.0	7.1	6.9	0.0				6.7	0.1				
11/28/22	0.0		27.0	7.0	6.9	4.4				6.5	0.1				
11/29/22	1.2		27.0	7.1	6.9	1.4			10000.0	6.6	0.1				
11/30/22	1.6		27.0	7.1	6.9	1.7				6.7	0.1				
Total	9.5					41.0			38000.0	137.7	2.1				
Max.	1.6		28.0	7.1	7.0	4.4	66858.4			6.7	0.1			225	
Min.	0.0		27.0	7.0	6.9	0.0		65567.3		6.5	0.1			138	
Avg.	0.5		27.3	7.0	6.9	1.4				6.6	0.1			168	

Signature - Plant Manager _____

CEO _____

Month and Year: December, 2022

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested sludge drawn to beds (gallons)	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.		Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
12/1/22	0.0		27.0	7.0	6.9	1.0				6.5	0.1			173	
12/2/22	0.1		27.0	7.0	6.9	1.0				6.5	0.1				
12/3/22						1.0									
12/4/22						1.0									
12/5/22	0.1		27.0	7.0	6.9	1.5				6.5	0.1				
12/6/22	1.1		27.0	7.1	7.0	1.3				6.5	0.1				
12/7/22	0.4		27.0	7.1	7.0	1.2				6.6	0.1				
12/8/22	0.1		27.0	7.0	6.9	1.4				6.5	0.1			170	
12/9/22	0.1		27.0	7.0	6.9	1.4				6.5	0.1				
12/10/22						1.4									
12/11/22						1.4									
12/12/22	0.3		27.0	7.0	6.9	1.4				6.5	0.1				
12/13/22	0.3		27.0	7.0	6.9	1.2			12000.0	6.5	0.1				
12/14/22	0.0		27.0	7.0	6.9	1.3			28000.0	6.5	0.1				
12/15/22	0.3		27.0	7.1	7.0	1.2			18000.0	6.5	0.1			175	
12/16/22	0.8		27.0	7.0	6.9	1.3				6.5	0.1				
12/17/22						1.6									
12/18/22						1.6				6.5	0.1				
12/19/22	0.1		27.0	7.0	6.9	1.6				6.5	0.1				
12/20/22	0.5		27.0	7.1	7.0	1.3				6.5	0.1				
12/21/22	0.0		27.0	7.1	7.0	1.3				6.5	0.1				
12/22/22	0.0		27.0	7.1	6.9	0.7				6.5	0.1			200	
12/23/22	0.0		27.0	7.1	6.9	1.3				6.5	0.1				
12/24/22						1.1									
12/25/22						1.1									
12/26/22						1.1				6.5	0.1				
12/27/22	1.3		27.0	7.1	6.9	1.1			11000.0	6.5	0.1				
12/28/22	0.0		27.0	7.1	6.9	0.8				6.5	0.1				
12/29/22	0.1		27.0	7.1	6.9	1.3			12000.0	6.5	0.1				
12/30/22	0.0		27.0	7.1	6.9	1.2			6000.0	6.5	0.1				
12/31/22						1.4									
Total	5.3					38.4			87000.0	149.6	2.3				
Max.	1.3		27.0	7.1	7.0	1.6				6.6	0.1			200	
Min.	0.0		27.0	7.0	6.9	0.7				6.5	0.1			170	
Avg.	0.3		27.0	7.1	6.9	1.2				6.5	0.1			180	

Signature - Plant Manager _____

CEO _____

Month and Year: January, 2023

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
1/1/23						1.4									
1/2/23						1.4									
1/3/23	1.2		27.0	7.1	6.9	1.4			12000.0	6.8	0.3				
1/4/23	0.5		27.0	7.1	6.9	1.3			16000.0	6.8	0.3				
1/5/23	2.6		27.0	7.0	6.9	1.8			44000.0	6.8	0.3			200	
1/6/23	1.0		27.0	7.0	6.9	1.7				6.8	0.3				
1/7/23						1.7									
1/8/23						1.7									
1/9/23	1.4		27.0	7.0	6.9	1.7				6.8	0.3				
1/10/23	0.0		27.0	7.0	6.9	1.7				6.7	0.3				
1/11/23	0.0		27.0	7.0	6.9	1.5				6.8	0.3				
1/12/23	0.3		27.0	7.0	6.9	1.4				6.8	0.3			215	1
1/13/23	0.1		27.0	7.0	6.9	1.2				6.8	0.3				
1/14/23						1.4									
1/15/23						1.4									
1/16/23						1.4									
1/17/23	0.4		27.0	7.0	6.9	1.4			24000.0	6.6	0.3				
1/18/23	0.1		27.0	7.1	7.0	1.2			8000.0	6.6	0.3				
1/19/23	0.0		28.0	7.1	7.0	1.3				6.6	0.3			220	
1/20/23	0.3		28.0	7.0	6.9	1.3			32000.0	6.6	0.3				
1/21/23						1.3									
1/22/23						1.3									
1/23/23	0.2		28.0	7.0	6.9	1.3				6.6	0.3				
1/24/23	0.0		28.0	7.0	6.9	1.4				6.6	0.2				
1/25/23	0.0		28.0	7.0	6.9	1.1				6.6	0.1				
1/26/23	0.1		28.0	7.0	6.9	1.3				6.6	0.2				
1/27/23	0.2		28.0	7.1	7.0	1.3				6.6	0.2			200	
1/28/23						1.4									
1/29/23						1.4									
1/30/23	0.5		28.0	7.1	7.0	1.4				6.6	0.2				
1/31/23	0.2		28.0	7.1	7.0	1.4				6.6	0.2				
Total	9.0					43.8			136000.0	133.7	5.3				
Max.	2.6		28.0	7.1	7.0	1.8				6.8	0.3			220	1
Min.	0.0		27.0	7.0	6.9	1.1				6.6	0.1			200	
Avg.	0.4		27.5	7.0	6.9	1.4				6.7	0.3			209	

Signature - Plant Manager _____

CEO _____

Month and Year: February, 2023

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested sludge drawn to beds (gallons)	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.		Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
2/1/23	1.9		28.0	7.1	7.0	1.5				6.6	0.2				
2/2/23	0.1		28.0	7.1	7.0	1.5			24000.0	6.6	0.2			192	
2/3/23	0.7		28.0	7.0	6.9	1.4				6.6	0.2				
2/4/23						1.5									
2/5/23						1.5									
2/6/23	0.2		28.0	7.1	7.0	1.5				6.6	0.2				
2/7/23	0.7		28.0	7.1	7.0	1.3				6.6	0.2				
2/8/23	0.2		28.0	7.1	6.9	1.2				6.6	0.2				
2/9/23	0.3		28.0	7.0	6.9	0.7			22000.0	6.6	0.2			212	
2/10/23	0.0		28.0	7.0	6.9	1.3				6.6	0.2				
2/11/23						1.4									
2/12/23						1.4									
2/13/23	0.4		28.0	7.1	7.0	1.4				6.6	0.2				
2/14/23	0.2		28.0	7.0	6.9	1.2				6.6	0.2				
2/15/23	0.2		28.0	7.0	6.9	1.3				6.6	0.2				
2/16/23	0.0		28.0	7.0	6.9	1.2				6.6	0.2			153	
2/17/23	0.0		28.0	7.0	6.9	1.2				6.6	0.2				
2/18/23						1.6									
2/19/23						1.6									
2/20/23						1.6									
2/21/23	8.2		28.0	7.0	6.9	1.6				6.6	0.2				
2/22/23	1.2		28.0	7.1	7.0	1.6				6.6	0.2				
2/23/23	0.3		28.0	7.1	7.0	1.8				6.6	0.2			138	
2/24/23	0.3		28.0	7.1	7.0	1.7				6.6	0.2				
2/25/23						1.6									
2/26/23						1.6									
2/27/23	1.7		28.0	7.1	7.0	1.6				6.6	0.2				
2/28/23	0.1		28.0	7.1	7.0	1.3				6.6	0.2				
Total	16.9					40.1			46000.0	125.4	3.8				
Max.	8.2		28.0	7.1	7.0	1.8				6.6	0.2			212	
Min.	0.0		28.0	7.0	6.9	0.7				6.6	0.2			138	
Avg.	0.9		28.0	7.1	7.0	1.4				6.6	0.2			174	

Signature - Plant Manager _____

CEO _____

Month and Year: March, 2023

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
3/1/23	0.0		28.0	7.1	7.0	1.2				6.6	0.2				
3/2/23	0.0		28.0	7.1	7.0	1.3				6.6	0.2			212	
3/3/23	0.2		28.0	7.1	7.0	1.2				6.6	0.2				
3/4/23						1.5									
3/5/23						1.5									
3/6/23	2.8		28.0	7.1	7.0	1.5				6.6	0.2				
3/7/23	0.0		28.0	7.1	7.0	1.1				6.6	0.2				
3/8/23	0.3		28.0	7.1	7.0	1.3				6.6	0.2				
3/9/23	0.9		28.0	7.1	7.0	1.6				6.6	0.2			157	
3/10/23	1.5		28.0	7.1	7.0	1.7				6.6	0.2				
3/11/23						2.0									
3/12/23						2.0									
3/13/23	2.1		28.0	7.1	7.0	2.0				6.6	0.2				
3/14/23	0.0		28.0	7.1	7.0	1.5				6.6	0.2				
3/15/23	0.0		28.0	7.1	7.0	1.2			5000.0	6.6	0.2				
3/16/23	0.0		28.0	7.1	7.0	1.3			10000.0	6.6	0.2			198	
3/17/23	0.0		28.0	7.1	7.0	1.3				6.6	0.2				
3/18/23						1.6									
3/19/23						1.6									
3/20/23	2.3		28.0	7.1	7.0	1.6				6.7	0.2				
3/21/23	0.2		28.0	7.1	7.0	1.5			27000.0	6.6	0.2				
3/22/23	0.0		28.0	7.1	7.0	1.4				6.6	0.2				
3/23/23	0.1		28.0	7.1	7.0	1.5				6.6	0.2			120	
3/24/23	0.2		28.0	7.1	7.0	1.4				6.6	0.2				
3/25/23						1.6									
3/26/23						1.6									
3/27/23	1.2		28.0	7.1	7.0	1.6			16000.0	6.6	0.2				
3/28/23	0.3		28.0	7.1	7.0	1.4			16000.0	6.6	0.2				
3/29/23	0.1		28.0	7.1	7.0	1.3			42000.0	6.6	0.2			197	
3/30/23	0.0		28.0	7.1	7.0	1.3				6.6	0.2				
3/31/23	0.3		28.0	7.1	7.0	1.4				6.6	0.2				
Total	12.4					45.9			116000.0	151.9	4.6				
Max.	2.8		28.0	7.1	7.0	2.0				6.7	0.2			212	
Min.	0.0		28.0	7.1	7.0	1.1				6.6	0.2			120	
Avg.	0.5		28.0	7.1	7.0	1.5				6.6	0.2			177	

Signature - Plant Manager _____

CEO _____

Month and Year: April, 2023

ASPA Fogagogo Wastewater

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
4/1/23						1.1									
4/2/23						1.1									
4/3/23	0.7		28.0	7.1	7.0	1.1				6.6	0.2				
4/4/23	0.1		28.0	7.1	7.0	0.9				6.6	0.2				
4/5/23	0.0		28.0	7.1	7.0	1.2				6.6	0.2				
4/6/23	0.1		28.0	7.1	7.0	1.2				6.6	0.2				
4/7/23						1.1									
4/8/23						1.1									
4/9/23						1.1									
4/10/23	0.5		28.0	7.1	7.0	1.1				6.6	0.2				
4/11/23	0.1		28.0	7.1	7.0	1.3				6.6	0.2				
4/12/23	0.2		28.0	7.1	7.0	1.3				6.6	0.2				
4/13/23	0.0		28.0	7.1	7.0	1.2				6.6	0.2				
4/14/23	0.6		28.0	7.1	7.0	1.4				6.6	0.2			225	
4/15/23						1.8									
4/16/23						1.8									
4/17/23						1.8									
4/18/23	4.7		28.0	7.1	7.0	1.8				6.6	0.2				
4/19/23	0.5		28.0	7.1	7.0	1.6				6.6	0.2				
4/20/23	0.5		28.0	7.1	7.0	1.4				6.6	0.2				
4/21/23	0.9		28.0	7.1	7.0	1.8				6.6	0.2			133	
4/22/23						2.0									
4/23/23						2.0									
4/24/23	0.8		28.0	7.1	7.0	2.0				6.6	0.2				
4/25/23	0.2		28.0	7.1	7.0	1.5				6.6	0.2				
4/26/23	0.0		28.0	7.0	7.0	1.4				6.6	0.2				
4/27/23	1.2		28.0	7.0	6.9	1.4				6.6	0.2				
4/28/23	0.2		28.0	6.9	6.9	1.4				6.6	0.2			171	
4/29/23						1.4									
4/30/23						1.4									
Total	11.1					42.5				118.8	3.6				
Max.	4.7		28.0	7.1	7.0	2.0				6.6	0.2			225	
Min.	0.0		28.0	6.9	6.9	0.9				6.6	0.2			133	
Avg.	0.6		28.0	7.1	7.0	1.4				6.6	0.2			176	

Signature - Plant Manager _____

CEO _____

Month and Year: May, 2023

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
5/1/23	0.0		28.0	6.9	6.8	1.4				6.6	0.2				
5/2/23	0.7		28.0	7.1	7.0	1.2				6.6	0.2				
5/3/23	0.8		28.0	7.0	6.9	1.1				6.6	0.2				
5/4/23	0.8		28.0	7.0	6.9	1.6				6.6	0.2			171	
5/5/23	2.6		28.0	7.0	6.9	1.6				6.6	0.2				
5/6/23						1.6									
5/7/23						1.6									
5/8/23	0.0		28.0	7.0	6.9	1.6				6.6	0.2				
5/9/23	0.0		28.0	7.0	6.9	1.3				6.6	0.2				
5/10/23	0.0		28.0	7.0	6.9	1.4				6.6	0.2				
5/11/23	0.0		28.0	7.0	6.9	1.4				6.6	0.2			177	
5/12/23	0.0		28.0	7.0	6.9	1.2				6.6	0.2				
5/13/23						1.5									
5/14/23						1.5									
5/15/23						1.5									
5/16/23	0.2		28.0	7.0	6.9	1.5				6.6	0.2				
5/17/23	3.2		28.0	7.0	6.9	2.0				6.6	0.2				
5/18/23	1.0		28.0	7.0	6.9	2.0				6.6	0.2			144	
5/19/23	0.9		28.0	7.0	6.9	1.8				6.6	0.2				
5/20/23						1.8									
5/21/23						1.8									
5/22/23	0.1		28.0	7.0	6.9	1.8			10000.0	6.6	0.2				
5/23/23	0.7		28.0	7.0	6.9	1.7				6.6	0.2				
5/24/23	0.0		28.0	7.0	6.9	1.4				6.6	0.2				
5/25/23	0.0		28.0	7.0	6.9	1.4				6.6	0.2			169	
5/26/23	4.6		28.0	7.0	6.9	2.1				6.6	0.2				
5/27/23						1.9									
5/28/23						1.9									
5/29/23						1.9									
5/30/23	0.4		28.0	7.0	6.9	1.9				6.6	0.2				
5/31/23	0.3		28.0	7.0	6.9	1.5				6.6	0.2				
Total	16.1					49.9			10000.0	138.6	4.2				
Max.	4.6		28.0	7.1	7.0	2.1				6.6	0.2			177	
Min.	0.0		28.0	6.9	6.8	1.1				6.6	0.2			144	
Avg.	0.8		28.0	7.0	6.9	1.6				6.6	0.2			165	

Signature - Plant Manager _____

CEO _____

Month and Year: June, 2023

ASPA Fogagogo Wastewa

						Sewage Flow MGD			Digested sludge drawn to beds (gallons)	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.		Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
6/1/23	0.0		28.0	7.0	6.9	1.4			40000.0	6.6	0.2			198	
6/2/23	0.1		28.0	7.0	6.9	1.5				6.6	0.2				
6/3/23						1.7									
6/4/23						1.7									
6/5/23	0.0		28.0	7.0	6.9	1.7				6.6	0.2				
6/6/23	0.0		28.0	7.0	6.9	1.6				6.6	0.2				
6/7/23	0.7		28.0	7.0	6.9	1.8			8000.0	6.6	0.2				
6/8/23	0.5		28.0	7.0	6.9	1.9			12000.0	6.6	0.2			189	
6/9/23	0.5		28.0	7.0	6.9	2.0			12000.0	6.6	0.2				
6/10/23						1.7									
6/11/23						1.7									
6/12/23	0.3		28.0	7.0	6.9	1.7			8000.0	6.6	0.2				
6/13/23	0.4		28.0	7.0	6.9	1.6				6.6	0.2				
6/14/23	0.2		28.0	7.0	6.9	1.5			20000.0	6.6	0.2				
6/15/23	0.3		28.0	7.0	6.9	1.6			12000.0	6.6	0.2			161	
6/16/23	0.2		28.0	7.0	6.9	1.7			12000.0	6.6	0.2				
6/17/23						1.9									
6/18/23						1.9									
6/19/23						1.9									
6/20/23	0.4		28.0	7.0	6.9	1.9			12000.0	6.6	0.2				
6/21/23	1.3		28.0	7.0	6.9	1.8			26000.0	6.6	0.2				
6/22/23	0.3		28.0	7.0	6.9	1.6			16000.0	6.6	0.2			172	
6/23/23	0.1		28.0	7.0	6.9	1.4				6.6	0.2				
6/24/23						1.9									
6/25/23						1.9									
6/26/23	0.1		28.0	7.0	6.9	1.9				6.6	0.2				
6/27/23	0.0		28.0	7.0	6.9	1.6				6.6	0.2				
6/28/23	0.0		28.0	7.0	6.9	1.4				6.6	0.2				
6/29/23	0.0		28.0	7.0	6.9	1.7				6.6	0.2			119	
6/30/23	0.0		28.0	7.0	6.9	1.5				6.6	0.2				
Total	5.2					50.9			178000.0	138.6	4.2				
Max.	1.3		28.0	7.0	6.9	2.0				6.6	0.2			198	
Min.	0.0		28.0	7.0	6.9	1.4				6.6	0.2			119	
Avg.	0.2		28.0	7.0	6.9	1.7				6.6	0.2			168	

Signature - Plant Manager _____

CEO _____

Month and Year: July, 2023

ASPA Fogagogo Wastewater

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
7/1/23						1.3									
7/2/23						1.3									
7/3/23	0.1		28.0	7.0	6.9	1.3				6.6	0.2				
7/4/23						1.2									
7/5/23	0.0		28.0	7.0	6.9	1.5				6.6	0.2				
7/6/23	0.0		28.0	7.0	6.9	1.0				6.6	0.2			220	1
7/7/23	0.2		28.0	7.0	6.9	1.3				6.6	0.2				
7/8/23						1.4									
7/9/23						1.4									
7/10/23	0.2		28.0	7.0	6.9	1.4				6.6	0.2				
7/11/23	0.2		28.0	7.0	6.9	1.3				6.6	0.2				
7/12/23	0.0		28.0	7.0	6.9	1.2				6.6	0.2				
7/13/23	0.8		28.0	7.0	6.9	1.4				6.5	0.1			178	
7/14/23	0.0		28.0	7.0	6.9	1.3				6.5	0.1				
7/15/23						1.4									
7/16/23						1.4									
7/17/23						1.4									
7/18/23	3.2		28.0	7.0	6.9	1.4			24000.0	6.7	0.1				
7/19/23	0.4		28.0	7.0	6.9	1.1									
7/20/23	0.1		28.0	7.0	6.9	1.2			30000.0	6.5	0.1			187	
7/21/23	0.1		28.0	7.0	6.9	1.2			34000.0	6.5	0.1				
7/22/23						1.5									
7/23/23						1.5									
7/24/23	0.1		28.0	7.0	6.9	1.5				6.5	0.1				
7/25/23	0.0		28.0	7.0	6.9	1.2				6.5	0.1				
7/26/23	0.0		28.0	7.0	6.9	1.0				6.5	0.1				
7/27/23	0.0		28.0	7.0	6.9	1.3				6.5	0.1			157	
7/28/23	0.0		28.0	7.0	6.9	1.3				6.5	0.1				
7/29/23						1.5									
7/30/23						1.5									
7/31/23	0.4		28.0	7.0	6.9	1.5				6.5	0.1				
Total	5.6					41.1			88000.0	117.9	2.5				
Max.	3.2		28.0	7.0	6.9	1.5				6.7	0.2			220	1
Min.	0.0		28.0	7.0	6.9	1.0				6.5	0.1			157	
Avg.	0.3		28.0	7.0	6.9	1.3				6.6	0.1			186	

Signature - Plant Manager _____

CEO _____

Month and Year: August, 2023

ASPA Fogagogo Wastewater

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
8/1/23	0.1		28.0	7.0	6.9	1.3				6.5	0.2				
8/2/23	0.0		28.0	7.0	6.9	1.2			20000.0	6.5	0.1				
8/3/23	0.0		28.0	7.0	6.9	1.3			12000.0	6.5	0.1			190	
8/4/23	0.0		28.0	7.0	6.9	1.3				6.5	0.1				
8/5/23						1.5									
8/6/23						1.5									
8/7/23	0.5		28.0	7.0	6.9	1.5			12000.0	6.5	0.1				
8/8/23	0.0		28.0	7.0	6.9	1.2				6.5	0.1				
8/9/23	0.0		28.0	7.0	6.9	1.3				6.5	0.1				
8/10/23	0.0		28.0	7.0	6.9	1.3				6.5	0.1			235	
8/11/23	0.0		28.0	7.0	6.9	1.3			4000.0	6.5	0.1				
8/12/23						1.5									
8/13/23						1.1									
8/14/23	0.8		28.0	7.0	6.9	1.1				6.5	0.1				
8/15/23	0.0		28.0	7.0	6.9	1.1				6.5	0.1				
8/16/23	0.0		28.0	7.0	6.9	1.1			10000.0	6.5	0.1				
8/17/23	0.0		28.0	7.0	6.9	1.1				6.5	0.1			162	
8/18/23	0.2		28.0	7.0	6.9	1.3				6.5	0.1				
8/19/23						1.2									
8/20/23						1.2									
8/21/23	0.0		28.0	7.0	6.9	1.2			20000.0	6.5	0.1				
8/22/23	0.0		28.0	7.0	6.9	1.1				6.5	0.1				
8/23/23	0.0		28.0	7.0	6.9	1.2				6.5	0.1				
8/24/23	0.2		28.0	7.0	6.8	1.3				6.5	0.1			130	
8/25/23	0.3		28.0	7.0	6.9	1.4				6.5	0.1				
8/26/23						1.5									
8/27/23						1.5									
8/28/23	0.2		28.0	7.0	6.9	1.5			2000.0	6.5	0.1				
8/29/23	0.0		28.0	7.0	6.9	1.2				6.5	0.1				
8/30/23	0.6		28.0	7.0	6.9	1.3				6.5	0.1				
8/31/23	0.0		28.0	7.0	6.9	1.4				6.5	0.1			245	
Total	2.9					39.9			80000.0	149.5	2.4				
Max.	0.8		28.0	7.0	6.9	1.5				6.5	0.2			245	
Min.	0.0		28.0	7.0	6.8	1.1				6.5	0.1			130	
Avg.	0.1		28.0	7.0	6.9	1.3				6.5	0.1			192	

Signature - Plant Manager _____

CEO _____

Month and Year: September, 2023

ASPA Fogagogo Wastewater

						Sewage Flow MGD			Digested	Settleable Solids ml/L		Conductivity			
Date	Rainfall Inches	Ambient Temp Avg. °F	Effluent Temp. °C	pH Influent	pH Effluent	Flow	Max.	Min.	sludge drawn to beds (gallons)	Influent	Effluent	influent	Effluent	Influent mg/L	Effluent mg/L
9/1/23	0.0		28.0	7.0	6.9	1.4				6.5	0.1				
9/2/23						1.4									
9/3/23						1.4									
9/4/23						1.4									
9/5/23	0.2		28.0	7.0	6.9	1.4			10000.0	6.5	0.1				
9/6/23	0.0		28.0	7.0	6.9	1.2			10000.0	6.5	0.1				
9/7/23	6.0		28.0	7.0	6.9	2.6				6.8	0.2			198	
9/8/23	0.6		28.0	7.0	6.9	1.8			34000.0						
9/9/23						1.5									
9/10/23						1.5									
9/11/23	0.6		28.0	7.0	6.9	1.5				6.5	0.1				
9/12/23	0.3		28.0	7.0	6.9	1.2			32000.0	6.5	0.1				
9/13/23	0.0		28.0	7.0	6.9	1.4			12000.0						
9/14/23	0.3		28.0	7.0	6.9	1.4			16000.0	6.5	0.1			188	
9/15/23	0.1		28.0	7.0	6.9	1.3				6.5	0.1				
9/16/23						1.6									
9/17/23						1.6									
9/18/23	0.8		28.0	0.1	6.9	1.6				6.5	0.1				
9/19/23	0.0		28.0	7.0	6.9	1.2				6.5	0.1				
9/20/23	0.0		28.0	7.0	6.9	1.5				6.5	0.1				
9/21/23	0.4		28.0	7.0	6.9	1.4				6.5	0.1			147	
9/22/23	0.1		28.0	7.0	6.9	1.4				6.5	0.1				
9/23/23						1.6									
9/24/23						1.6									
9/25/23	0.1		28.0	7.0	6.9	1.6			4000.0	6.5	0.1				
9/26/23	0.0		28.0	7.0	6.9	1.3			24000.0	6.5	0.1				
9/27/23	0.0		28.0	7.0	6.9	1.4				6.5	0.1				
9/28/23	0.0		28.0	7.0	6.9	1.4				6.5	0.1			165	
9/29/23	0.0		28.0	7.0	6.9	1.4				6.5	0.1				
9/30/23						1.6									
Total	9.5					44.6			142000.0	117.3	1.9				
Max.	6.0		28.0	7.0	6.9	2.6				6.8	0.2			198	
Min.	0.0		28.0	0.1	6.9	1.2				6.5	0.1			147	
Avg.	0.5		28.0	6.7	6.9	1.5				6.5	0.1			175	

Signature - Plant Manager _____

CEO _____