



MARSHALLS ENERGY COMPANY INC.

P.O. Box 1439 - Majuro - Marshall Islands - MH 96960

Tel. (692) 625-3827 - Fax (692) 625-3397

Email meccorp@ntamar.net

November 13, 2024

NOTICE TO BIDDERS

TO : Bidders

FROM : Steve Wakefield, CTO.

SUBJECT : **MEC CABLE BID**

BID # : **MEC - 1112679**

NOTICE # : **RFP MEC 24-003**

Clarification of cable product description.

The cable required should have a **minimum** 1/3 concentric neutral layer of copper wires.

The General description of 20 x #12 Concentric Neutral refers to a 100% Concentric Neutral cable.

Both 1/3 Concentric Neutral and 100% Concentric Neutral cables are acceptable for the bid proposal.

END MESSAGE.