



American Samoa Power Authority

P.O. Box PPB

Pago Pago, American Samoa 96799

Telephone: (684) 699-3057

Email: procurement@aspower.com

Website: www.aspower.com



ISSUANCE DATE: **November 25, 2024**

RFP NO.: **RFP NO. ASPA24.051 – Construction of Fagaalu to Utulei ACP Replacement Project**

SUBJECT: **Addendum No. 5**

The American Samoa Power Authority hereby issues Addendum No. 5 to amend Request for Proposals (RFP) requirements. This addendum is issued pursuant to the conditions of the RFP documents and is hereby made part of the RFP. The addendum serves to clarify, revise, and supersede information contained in the RFP. The Offeror must acknowledge receipt of this addendum in the appropriate space provided in the Addendum Form. Failure to do so may subject the Offeror to disqualification.

1. Closing deadline has been extended as follows:

New Closing Date: Friday, December 27, 2024 at 2:00PM

2. Responses to queries received regarding this tender are included with this Fifth Addendum. A revised Bid Form is included as part of the response. Previous versions of the bid form are considered obsolete and must not be used.

Should you have any questions or need clarification, please call me at (684) 699-3057 or procurement@aspower.com.

Sincerely,

A handwritten signature in black ink, appearing to read "Renee Leotele Togafau".

Renee Leotele Togafau
Procurement Manager

Please sign and date below to acknowledge receiving Addendum 5. You may return this document via email at procurement@aspower.com, or the ASPA Procurement Office.

ACKNOWLEDGEMENT OF RECEIVING ADDENDUM 5

Received by _____, this _____ day of _____ 2024.

Company _____ Title _____

Fax No. _____ Email Address _____

ATTACHMENT B - BID FORM - PHASE 1,2,&3 (Rev03)



Project Name : ASPA24.051 Faga'alu to Utulei ACP Replacement Project

Project Location : Tutuila Island, Pago Pago, As, 96799, American Samoa

Name of Bidding Company:

Method of Submission :

Email ☐

Physical delivery ☐

Others ☐

Timeline for Completion:

Calendar days

No	Scope Of Work	Unit	Qty	Unit Cost	Total Cost
BASE BID FORM - PHASE 1,2&3					
1	MOBILIZATION & DEMOBILIZATION (5% MAX)	LS	1	\$	\$
2	SITE WORKS ,TEMPORARY FACILITIES AND CONTROLS	LS	1	\$	\$
3	POTHOLING	LS	1	\$	\$
4	EROSION AND SEDIMENTATION CONTROLS	LS	1	\$	\$
5	16" WATER COLLECTION MAINS ONLY ((C031 to C035)	LF	8,620		
6	6" WATER SUPPLY MAINS ONLY	LF	1,360	\$	\$
7	8" WATER SUPPLY MAINS ONLY (C040)	LF	10,120	\$	\$
8	FIRE HYDRANT ASSEMBLY	EA	12	\$	\$
9	STREAM CROSSING			\$	\$
9.1	STREAM CROSSING STA 16+20	EA	1	\$	\$
9.2	STREAM CROSSING STA 79+60	EA	1	\$	\$
10	UTILITY & DRAINAGE PIPE CROSSING	EA	22	\$	\$
11	SERVICE STUB-OUT	EA	35	\$	\$
12	2" SERVICE LINE	LF	4,575	\$	\$
13	1" SERVICE LINE	LF	4,560	\$	\$
14	METER RELOCATION	EA	59	\$	\$
15	PRESSURE & LEAKAGE TESTING	LS	1	\$	\$
16	FLUSHING & DISINFECTION	LS	1	\$	\$
17	CONCRETE PAVEMENT RESTORATION	SY	3,950	\$	\$
TOTAL BASE BID:					\$ -

ALTERNATIVE BID FORM - PHASE 1,2&3					
1	CONSTRUCTION OF BOOSTER STATION	LS	1	\$	\$
2	GENERAL MECHANICAL	LS	1	\$	\$
3	GENERAL ELECTRICAL	LS	1	\$	\$
4	FENCING	LS	1	\$	\$
5	ASPHALT PAVEMENT RESTORATION	SY	9600	\$	\$
TOTAL ALTERNATIVE BID:					\$

TOTAL BASE + ALTERNATIVE BID \$ _____

Total amount in words: _____

RFP NO. ASPA24.051 - FAGAALU TO UTULEI ACP REPLACEMENT

No .	Question	Answer:
1	Please confirm the total quantity of 8" water supply main pipe, phase 1 - have a quantity of 6,100LF, phase 2 with a quantity of 1500 LF and phase 3 with 2,520 LF these will give us a total of 10,120 LF. However, in the base bid form 1, 2 and 3 these item have 2 scope of works item #5 with a quantity of 8,620 LF and item 8 having a quantity of 10,120 LF. Please confirm these quantit[ies].	Base Bid Form 1, 2 and 3 (Rev 03) will be issued to address the discrepancy in the quantity of the 8" water supply main pipe; discrepancy in the quantity of concrete pavement restoration; and the issue regarding the tie-in and interconnection.
2	Please confirm the quantity of Concret Pavement Restoration - if we do the addition of the quantities Phase 1, 2 and 3 is way off to the quantity of Base Bid Form 1, 2 and 3.	
3	Tie in and interconnection have been removed to the scope of work from Phase 1 and Phase 3. However, in base bid form 1, 2 and 3 - these items stil show in the SOW. Please confirm.	