



ENERGY FIJI LIMITED

**Preferred Supplier
Of
Design, Manufacture, Testing and Supply Of
Electrical Conduits**

MR 118/2025

Revision History & Document Control

Rev No.	Notes	Prepared By	Reviewed & Approved By	Date of Issue
1	Prepared by	Rajiv Singh		08/02/2022
2	Reviewed by	Anishal Chandra		31/01/2025
3	Reviewed by		Mohammed Zainal Alim	

Next Scheduled Revision

This technical specification is due for review in July 2027.

TABLE OF CONTENT

Revision History & Document Control.....	2
Next Scheduled Revision	2
1. INTRODUCTION AND SCOPE OF WORK.....	5
1 INSTRUCTIONS TO BIDDERS	6
1.1 Eligible Bidders.....	6
1.2 Eligible Materials, Equipment and Services	6
1.3 One Bid per Bidder.....	6
1.4 Cost of Bidding.....	6
1.5 Site Visits	6
1.6 Contents of Bidding Documents	7
1.7 Clarification of Bidding Documents	7
1.8 Amendment of Bidding Document	7
1.9 Language of Bid.....	7
1.10 Bid Prices	7
1.11 Bid Currencies	8
1.12 Bid Validity.....	8
1.13 Format and Signing of Bids	8
1.14 Sealing and Marking of Bids.....	8
1.15 Deadline for Submission of Bids.....	8
1.16 Late Bids.....	8
1.17 Modification and Withdrawal of Bids.....	8
1.18 Rejection of One or All Bids.....	8
1.19 Process to be Confidential	9
1.20 Clarification of Bids.....	9
1.21 Compliance with Specifications	9
2. REFERENCES.....	10
2.1. Applicable Standard	10
3. SERVICE CONDITIONS.....	11
3.1. Environmental Conditions	11
3.2. System Conditions.....	11
3.3. Underground Conditions.....	11
4. DESIGN AND CONSTRUCTION.....	12
4.1 General Design	12
4.2. Dimensions and Form.....	12
4.3. Color.....	12
4.4. Marking.....	12
5 PERFORMANCE AND TESTING.....	13
5.1 Type & Routine Testing	13

5.2	Type Testing	13
5.3	Acceptance Tests	14
5.4	Witnessing of Tests	14
5.5	Test Certificates	14
5.6	Compliance	14
6	RELIABILITY	15
6.1	Service Life	15
6.2	Evidence in Support of Reliability	15
7	ENVIRONMENTAL CONSIDERATIONS	15
8	PACKAGING AND MARKING	15
8.1	Packaging	15
9	QUALITY REQUIREMENTS	15
10	STOCK AVAILABILITY	16
11	PRODUCT WARRANTY PERIOD	16
12	INFORMATION TO BE PROVIDED BY THE BIDDER	16
12.1	Documentation to be supplied with the tender	16
12.2	Samples	16
12.3	Training	17
13	APPENDIX	18
13.1	Price Schedule	18
13.2	Technical Specifications – Electrical Conduits	19
13.3	Submission Requirements	22

1. INTRODUCTION AND SCOPE OF WORK

Energy Fiji Limited [EFL] is responsible for generation, transmission and distribution of electricity in Viti Levu, Vanua Levu, Ovalau and Taveuni in Fiji. By the end of 2024, EFL had 223,539 customers. This includes residential, commercial and institutional customers.

The preferred Supplier arrangement will be for a period of 3 (three) years from the date of signing of the contract.

The items covered by this specification are listed below:

No.	Stock Code	Item Description	Nominal Conduit Diameter	Mechanical Classification
1	I06244	Electrical Conduit	50mm	HD
2	I06241	Electrical Conduit	100mm	HD
3	I06243	Electrical Conduit	150mm	HD

Table 1.1: Items Covered Under this Specification

This Specification covers the general requirements of design, manufacture, testing, supply and delivery for Electrical Conduits for use in EFL's distribution and sub-transmission networks.

1 INSTRUCTIONS TO BIDDERS

1.1 Eligible Bidders

This invitation is open to all Bidders who have sound Financial Background, and have previous experience in Design, Manufacture, Testing and Supply of Electrical Conduits.

Bidders shall provide such evidence of their continued eligibility satisfactory to EFL as EFL shall reasonably request. Bidders who are not manufacturers of such transformers shall provide evidence of agency.

Bidders shall not be under a declaration of ineligibility for corrupt or fraudulent practice.

1.2 Eligible Materials, Equipment and Services

The materials, equipment, and services to be supplied under the Contract shall have their origin from reputable companies (as specified by EFL where relevant) and from various countries and all expenditures made under the Contract will be limited to such materials, equipment, and services. Upon request, bidders may be required to provide evidence of the origin of materials, equipment, and services.

For purposes of this Contract, "services" means the works and all related services including design services.

For purposes of this Contract, "origin" means the place where the materials and equipment are mined, grown, produced or manufactured, and from which the services are provided. Materials and equipment are produced when, through manufacturing, processing or substantial or major assembling of components, a commercial recognized product results that is substantially different in basic characteristics or in purpose or utility from its components.

The materials, equipment and services to be supplied under the Contract shall not infringe or violate any industrial property or intellectual property rights or claim of any third party.

1.3 One Bid per Bidder

Each bidder shall submit only one bid. A bidder who submits or participates in more than one bid will cause all those bids to be rejected.

1.4 Cost of Bidding

The bidder shall bear all costs associated with the preparation and submission of its bid and EFL will in no case be responsible or liable for those costs.

1.5 Site Visits

Bidders can visit existing EFL networks by making arrangements to visit existing EFL installations. Bidders are required to familiarize themselves with the existing EFL installations so the solutions they offer does not require modification to existing poles and support infrastructure.

1.6 Contents of Bidding Documents

The bidder is expected to examine carefully the contents of this Bidding document. Failure to comply with the requirements of bid submission will be at the bidder's own risk. Bids which are not substantially responsive to the requirements of the bidding documents will be rejected.

1.7 Clarification of Bidding Documents

A prospective bidder requiring any clarification of the bidding documents may notify EFL in writing by email, addressed to:

Jitendra Reddy
Manager Procurement, Inventory & Supply Chain
2 Marlow Street,
Suva, Fiji
Phone: +679 331 3333 Ext 2320 or
Mobile: +679 999 2400
Email: JReddy@efl.com.fj

EFL will respond to any request for clarification which it receives earlier than 10 days prior to the deadline for submission of bids.

1.8 Amendment of Bidding Document

At any time prior to the deadline for submission of bids, EFL may, for any reason, whether at its own initiative or in response to a clarification requested by a prospective bidder, modify the bidding documents by issuing addenda.

1.9 Language of Bid

The bid, and all correspondence and documents related to the bid, exchanged between the bidder and the EFL shall be written in the English language.

1.10 Bid Prices

Unless specified otherwise, Bidders shall quote for the entire facilities on a "single responsibility" basis such that the total bid price covers all the Supplier's obligations mentioned in or to be reasonably inferred from the bidding documents in respect of the design, manufacture, including procurement and subcontracting (if any), testing and delivery.

Bidders shall give a breakdown of the prices in the manner and detail called for in this bidding document, or any issued addenda.

Bids shall be given on CIF basis. The point of delivery shall be EFL's Navutu Depot in Lautoka. The term CIF shall be governed by the rules prescribed in the current edition of Incoterms, published by the International Chamber of Commerce, Paris.

EFL has a marine insurance cover for items it is required for purchase for its project and operational works. Bidders are required to comment if the marine insurance component is covered in their bids.

1.11 Bid Currencies

Prices shall be quoted in a single currency only.

1.12 Bid Validity

Bids shall remain valid for a period of **120 days** from the date of Deadline for Submission of Bids specified in Sub-Clause 21.1.

1.13 Format and Signing of Bids

The bidder shall provide one electronic copy of the Technical and Financial proposals on EFL's electronic tender hosting website; <https://www.tenderlink.com/efl>

The bid shall contain no alterations, omissions or additions, except those to comply with instructions issued by EFL, or as necessary to correct errors made by the bidder, in which case such corrections shall be initialed by the person or persons signing the bid.

1.14 Sealing and Marking of Bids

Due to the Covid19 restrictions on movements, bidders are encouraged to bid via Tender link Portal.

1.15 Deadline for Submission of Bids

Bids must be received by EFL at the address specified above no later than **1600 hours (Fiji Time) 9th April, 2025**.

EFL may, at its discretion, extend the deadline for submission of bids by issuing an addendum, in which case all rights and obligations of EFL and the bidders previously subject to the original deadline will thereafter be subject to the deadlines extended.

1.16 Late Bids

Any bid received by EFL after the deadline for submission of bids prescribed above will be rejected.

1.17 Modification and Withdrawal of Bids

The bidder may modify or withdraw its bid after bid submission, provided that written notice of the modification or withdrawal is received by EFL prior to the deadline for submission of bids.

No bid may be modified by the bidder after the deadline for submission of bids.

1.18 Rejection of One or All Bids

EFL reserves the right to accept or reject any bid, and to annul the bidding process

and reject all bids, at any time prior to award of Contract, without thereby incurring any liability to the affected bidder or bidders or any obligation to inform the affected bidder or bidders of the grounds for the rejection.

1.19 Process to be Confidential

- 1.19.1 Information relating to the examination, clarification, evaluation and comparison of bids and recommendations for the award of a contract shall not be disclosed to bidders or any other persons not officially concerned with such process.
- 1.19.2 Any effort by a bidder to influence EFL's processing of bids or award decisions may result in the rejection of the bidder's bid.
- 1.19.3 Lowest bid will not necessarily be accepted as successful bid.

1.20 Clarification of Bids

To assist in the examination, evaluation and comparison of bids, EFL may, at its discretion, ask any bidder for clarification of its bid. The request for clarification and the response shall be in writing, but no change in the price or substance of the bid shall be sought, offered or permitted except as required to confirm the correction of arithmetic errors discovered by EFL in the evaluation of the bids.

1.21 Compliance with Specifications

The tender shall be based on the equipment and work specified and shall be in accordance with the Technical Specification. It should be noted that unless departures from specifications are detailed in Schedules of the Technical Specification, the tender would be taken as conforming to the Specification in its entirety. The Bidder shall tender for the whole of the Works included in the Specification.

2. REFERENCES

2.1. Applicable Standard

The item shall be designed, manufactured and tested in accordance with the latest edition of the Standards specified below and all amendments issued prior to the date of closing of tenders except where varied by this specification.

AS/NZS 2053	Conduits and fittings for electrical installations
AS/NZS 2053.2	Conduits and fittings for electrical installations - Rigid plain conduits and fittings of insulating material
AS 1345	Identification of the contents of pipes, conduits and ducts
AS 2700	Color standards for general purpose
AS 1100	Drawing practice scales – Part 7
AS/NZS ISO 9001	Quality management systems - Requirements
AS ISO/IEC 17025	General requirements for the competence of testing and calibration laboratories

Should inconsistencies be identified between standards and/or this specification, the tenderer shall immediately refer such inconsistencies to the EFL for resolution.

3. SERVICE CONDITIONS

3.1. Environmental Conditions

The Electrical Conduits shall be designed to withstand the following service conditions.

Description		Conditions
Atmosphere	:	Saliferous, corrosive and dusty
Ambient Temperature	:	Peak: 40°C 24 Hour Average: 30°C Annual Average: 22°C Minimum: 10°C
Relative Humidity (Average)	:	85%
Rainfall	:	Annual Average: 2663mm
Isokeraunic (Thunder day) level	:	60 thunder days per year
Seismic	:	To a maximum of 7 on the open-ended Richter Scale

Note: Fiji is situated in a region where cyclones are experienced frequently. All equipment shall be designed and constructed to withstand these extreme conditions.

3.2. System Conditions

	System Voltages	
Particulars	11kV	33kV
Nominal System Voltage	11kV	33kV
Highest (Equivalent) System Voltage	12kV	36kV
Number of Phases	3	3
Impulse Withstand Voltage (peak)	28kV	70kV
Power Frequency Withstand Voltage	95kV (peak)	200kV (peak)

3.3. Underground Conditions

The electrical conduits will be exposed to the following underground, environmental conditions:

Soil	Variable soil conditions such as limestone, sandstone, sand (both dry & wet), gravel, clay (including wet clay), soil, areas exposed to salt water hence having variable resistivity. Areas near farms and chemical manufacturing plants causing soil acidity.
Temperature	37.8°C max daytime above ground 9.5°C min night time above ground 30.0°C max below ground with a 4yr average of 28°C

4. DESIGN AND CONSTRUCTION

4.1. General Design

The conduits shall be rigid non-threadable of insulating material in accordance with the requirements of AS/NZS 2053 Part 2 or Part 6. The conduits shall also be UV resistant.

4.2. Dimensions and Form

The dimensions of conduit shall be in accordance with the requirement of AS/NZS 2053 Part 2 or Part 6 and as per table below

Item No.	Description	Requirement		
		50mm HD Conduit	100mm HD Conduit	150mm HD Conduit
1	Mechanical classification	HD	HD	HD
2	Material	Unplasticised PVC (U-PVC) (UV resistant)	Unplasticised PVC (U-PVC) (UV resistant)	Unplasticised PVC (U-PVC) (UV resistant)
3	Pipe wall thickness	3.4mm minimum	5.9mm minimum	8.3mm minimum
		3.9mm maximum	6.7mm maximum	9.3mm maximum
4	Pipe outer diameter	49.7mm minimum	114.1mm minimum	160mm minimum
		50.0mm maximum	114.5mm maximum	160.45mm maximum
5	Nominal pipe length	5.8m	5.8m	5.8m

4.3. Color

The background color of the electrical conduits supplied under this specification shall be in accordance with AS 2700 and table below.

Item No.	Color	Color as per AS 2700
Conduit	Orange	Number 557, light orange, as specified in AS 1345 or X 15 as per AS 2700S

4.4. Marking

The permanent marking on the conduit shall meet the requirements specified in AS/NZS 2053.

The following are minimum details that shall be permanently marked on the conduit:

- Manufacturer's name or trade mark
- Nominal size
- Marked with the word 'electrical'
- Mechanical classification rating i.e. HD
- Manufacturing standard
- The words "PROPERTY OF ENERGY FIJI LIMITED"

The recommended printing height shall be of 5mm.

5 PERFORMANCE AND TESTING

5.1 Type & Routine Testing

Prior to delivery, the items shall have completed the type, routine and accuracy tests and inspections as required by the relevant international and AS/NZS standards. The passing of such tests shall not prejudice the right of EFL to reject the items if it does not comply with the specification when received or installed.

All testing shall be undertaken by an AS ISO/IEC 17025 accredited test house. The bidder shall submit evidence showing IEC 17025 compliance. A formal report covering the outcome of the different tests shall be made available to EFL.

Test certificates shall be provided by a NATA (or equivalent) certified testing laboratory. The testing laboratory must be certified for testing to the relevant standard for the offered products. In addition, a copy of the testing laboratories certification shall be provided. All test reports and supporting evidence shall be provided in English.

Bidders can provide type test certificates in accordance to equivalent international standards. However, this must be stated clearly in the Tender bid.

Where items of a similar design to that previously tested is offered, consideration may be given to accepting previous type test reports. Tenderers are requested to substantiate their claims of equivalent type test performance with written engineering evaluation, where full Type Test documentation is not submitted for each of the items offered. Such evaluation must provide all relevant details so that EFL can establish the validity of existing type tests.

5.2 Type Testing

Type tests shall be defined as those tests which are to be carried out to prove the design, process of manufacture and general conformity of the materials to this specification.

The supplier shall provide copies of valid and current type test reports and certificates for all of the type tests that are specified in the specifications and that have previously been performed.

Wherever the referenced test procedures or the technical specifications call for visual inspection for damage, the test report shall include a full description of observed status of the sample. (Visually inspected samples shall also be color photographed and copies of color photographs shall be included in type test report).

The following are the required (not limited to) type tests to be conducted on Electrical Conduits.

No.	Test Description	Testing Reference
1	Color	AS/NZS 2053.2:2001
2	Freedom of Defects	
3	Length	
4	Impact Testing	
5	Marking	
6	MCI Testing	
7	UV stabilisation (UV resistant)	

5.3 Acceptance Tests

The EFL may carry out acceptance test on product to prove it conforms to the requirements of this Specification. Any product showing evidence of failure to comply with the requirements of this specification will be liable to rejection.

5.4 Witnessing of Tests

The bidders shall make allowance for witnessing of routine tests on a batch of Electrical Conduits by two EFL Engineers at least once during the contract period. The return-air travel, accommodation, meals and other expenses related to routine test witnessing shall be borne by the bidder.

The Supplier shall give EFL not less than four (4) weeks' notice of when each and every type test will be carried out. Such witnessing shall be required once in the contract period, upon purchase of the first unit. A copy of inspection and test plan shall be submitted to EFL with the bid submission, which shall be used in the factory.

Note: The Factory Acceptance Testing (FAT) is a mandatory requirement by EFL.

5.5 Test Certificates

Two certified copies of all test results shall be supplied to EFL for every product that will be supplied under the contract.

5.6 Compliance

The Supplier shall state in writing that their offer complies with the relevant Standards and this specification. If the Supplier is offering product manufactured to an equivalent standard, full details of that standard must be given including a copy written in English.

6 RELIABILITY

6.1 Service Life

Bidders are required to comment on the reliability of the equipment and the performance of the materials offered for a service life of 35 years under the specified system and environmental conditions in clause 3.

6.2 Evidence in Support of Reliability

Where the specified guaranteed service life is less than 35 years Suppliers are required to provide comment and submit evidence in support of the reliability and performance claimed including detailed information on Failure Mode and Effect Analysis.

7 ENVIRONMENTAL CONSIDERATIONS

Suppliers are required to comment on the environmental soundness of the design and the materials used in the manufacture of the items offered. In particular, comments should address such issues as recyclability and disposal at end of service life and also disposal of packaging material.

8 PACKAGING AND MARKING

8.1 Packaging

The packaging of items by the bidder must ensure that they are capable of being delivered undamaged giving due consideration to the quantity, distance of transportation and the preferred method of handling at each location.

Each packaged lot shall be marked with the following information:

1. Manufacture's name
2. Manufacture's part reference number
3. EFL stock code
4. Compliance standards
5. Batch number
6. Conduit description (size, color, length)
7. Package weight

9 QUALITY REQUIREMENTS

Tenderers are required to submit evidence that the design and manufacture of the Electrical Conduits are in accordance with AS/NZS ISO 9001 and shall include the Capability Statement associated with the Quality System Certification.

If the Tenderer is a non-manufacturing supplier, the documentary evidence shall include the quality system certifications of both the supplier and the manufacturer.

10 STOCK AVAILABILITY

The bidder is required to show the size of his/her stock holding and the ability to meet the required estimate quantity per annum. The movement of the Electrical Conduits will depend on the EFL's project works and for operation and maintenance purposes. An estimate movement of the item is outlined in the table below but it will not be purchased as a lump sum quantity at once. Hence, the successful bidder will be required to carry a consignment / safety stock at times to meet EFL's demand within the three year contract period.

No.	Stock Code	Item Description	Approximate 3 Year Stock Movement
1	I06244	Electrical Conduit	175
2	I06241	Electrical Conduit	368
3	I06243	Electrical Conduit	1215

11 PRODUCT WARRANTY PERIOD

The bidders are required to provide the warranty period as part of the proposal. A minimum warranty period of twenty-four (24) months from time of dispatch from factory shall be provided.

12 INFORMATION TO BE PROVIDED BY THE BIDDER

12.1 Documentation to be supplied with the tender

To enable the EFL to fully evaluate the Electrical Conduits offered, (in addition to the completed Specification Requirement and Guaranteed Performance schedule) the bidder shall submit the following information with their tender: **(Note these are mandatory requirements)**

- List showing similar items supplied to or on order for other utilities in Australia or New Zealand or the Oceania region for the past 5 years
- Typical arrangement drawings and full details of the dimensions
- Type test certificates as per Clause 5.1
- End of service life disposal methods
- Evidence of Quality Management Systems used in the manufacturing process
- Evidence of Health, Safety and Environmental plans
- Evidence of financial ability to provide the level of service and support
- Origin of materials used in the manufacturing process
- Names and resumes of key team members who will be assigned to work with EFL upon successful award of the three-year supply contract (if bidder is successful)

Bidders may be asked to provide additional information during tender assessment period or following award of contract.

12.2 Samples

When requested, production samples of each item shall be submitted with the offer.

Each sample shall be delivered freight free (Delivery Duty Paid (DDP)), suitably packaged and labelled with the following information:

- Name of supplier and this contact number
- Tender number
- Any supporting data on features or characteristics

12.3 Training

Training material in the form of drawings, instructions and/or audio visuals (in CD format) are required to be provided for the items accepted under the tender. The Tenderers shall allow the cost of production and delivery of training material in the tendered prices.

The training materials should include but not be limited to the following topics:

- Handling
- Storage
- Application
- Installation
- Maintenance
- Environmental performance
- Electrical performance
- Mechanical performance
- Disposal

Offers of vendors who fail to furnish above particulars shall be rejected.

13 APPENDIX

13.1 Price Schedule

Bidders are required to complete the following price schedule and submit with the offer. EFL requires the bidding prices to be in CIF incoterms.

No.	Stock Code	Item Description	Unit Price (CIF)	Currency of bid
1	I06244	Electrical Conduit		
2	I06241	Electrical Conduit		
3	I06243	Electrical Conduit		

Bidders are to clearly indicate the currency of bid.

13.2 Technical Specifications – Electrical Conduits

No.	Particulars	Requirements			Bidders Response		
Manufacturers Details		50mm Conduit	100mm Conduit	150mm Conduit	50mm Conduit	100mm Conduit	150mm Conduit
1	Name of Manufacturer						
2	Address of Manufacturer						
3	Country of Manufacturer						
Electrical Conduit 150mm HD - Technical							
4	Does the conduit comply with the requirements of AS 2053.2						
5	Mechanical classification of conduit	HD					
6	Conduit type	Rigid					
7	Conduit material	Unplasticised PVC (U-PVC)					
8	Pipe wall thickness	3.4mm minimum & 3.9mm maximum	5.9mm minimum & 6.7mm maximum	8.3mm minimum & 9.3mm maximum			
9	Pipe outer diameter	49.7mm minimum & 50.0mm maximum	114.1mm minimum & 114.5mm maximum	160mm minimum & 160.45mm maximum			
10	Type of construction	Solid wall/ Sandwich/ Profile wall					
11	Nominal pipe length	5.8m					
12	Color of conduit						
13	Have UV stabilisation (UV resistant) tests been performed on the electrical conduits						
14	Are marking on conduit as specified in clause 4.4 of the technical specification						
Electrical Conduit 150mm HD - Documents and Test Reports							
15	List of type and routine test reports/certificates provided as per clause 5 of the technical specification						
16	Provide AS ISO/IEC 17025 compliance certificate						
17	List showing similar product supplied to or on order for other utilities in Australia or New Zealand or the Oceania region for the past 5 years						

18	Provide complete dimensional drawing						
19	Provide the Health, Safety and Environmental plans						
20	Provide the inspection and test plans						
21	Provide the origin of materials used in manufacture of electrical conduits						
22	Provide the disposal method of items provided after its service life						
23	Provide the quality management system used in the production of electrical conduits (provide certificate of QMS)						
24	Are the material safety datasheets (MSDS) of all items provided						
25	Has the bidder provided the company profile outlining the following;						
	Company profile						
	Company registration details						
	Company financial capability statement						
Submission Requirements							
26	Bid validity provided for 180 days						
27	Minimum warranty period of 24 months offered for the products						
28	Is the bidding price in CIF incoterm and delivery to Lautoka Wharf Fiji						
29	What will be the lead time of delivery if the bidder is successful	6 weeks from issue of PO					
30	What will be the price review period after tender award if the bidder is successful						
31	Does the bidder agree with the requirements of AS 4912-2002; General conditions of contract for periodic supply of goods (Parts 1 and 2)						
32	Does the bidder agree with the requirements of AS/NZS 4911-2003; General conditions of contract for the supply of equipment without installation						
33	Is virtual FAT included as part of the bid.						

34	Provide names of other utilities/companies in the electrical field where the conduits have been supplied to. (The bidder can provide reference letters from others companies using the electrical conduit)						
----	--	--	--	--	--	--	--

Name of Tenderer: _____

Signature of Tenderer: _____

Date: _____

13.3 Submission Requirements

All tenderers are required to complete and submit a copy of the submission requirements with their bid submissions. **(Note these are mandatory requirements)**

Requirements	Response from Bidders
Validity of bid (120 days required) (Yes/No)	
List of test reports/certificates provided. (As per Clause 5)	
Minimum warranty period offered for this product	
Price review period	
Minimum order quantity	
Completed price and technical schedules (Clause 13.1 and 13.2) (Yes/No)	
The bidding pricing to be in CIF incoterm.	
Currency of bid.	
Lead time of delivery after tender award.	
Disposal method after service life.	
Complete dimensional drawings	
Factory Acceptance Test	
Training	
Material safety datasheet to be provided for all items	
The bidder to include the following as part of the bid:	
Company profile, financial capability statement	
Company registration details	
Company financial capability statement	
Reference list of customers the same product is supplied to and contact details for reference check	
If the bidder is the manufacturer, the ISO certification shall be provided	
If the bidder is only the supplier of the product, then both the manufacturer and supplier ISO certifications shall be provided	

Name of Tenderer: _____

Signature of Tenderer: _____

Date: _____

TENDER CHECKLIST

The Bidders must ensure that the details and documentation mention below must be submitted as part of their tender Bid

Tender Number _____

Tender Name _____

1. Full Company / Business Name: _____

(Attach copy of Registration Certificate)

2. Director/Owner(s): _____

3. Postal Address: _____

4. Phone Contact: _____

5. Fax Number: _____

6. Email address: _____

7. Office Location: _____

8. TIN Number: _____

(Attach copy of the VAT/TIN Registration Certificate - Local Bidders Only (Mandatory))

9. FNPF Employer Registration Number: _____ **(For Local Bidders only) (Mandatory)**

10. **Provide a copy of Valid FNPF Compliance Certificate (Mandatory- Local Bidders only)**

11. **Provide a copy of Valid FRCS (Tax) Compliance Certificate (Mandatory Local Bidders only)**

12. **Provide a copy of Valid FNU Compliance Certificate (Mandatory Local Bidders only)**

13. Contact Person: _____

I declare that all the above information is correct.

Name: _____

Position: _____

Sign: _____

Date: _____

Tender submission

Bidders are requested to upload electronic copies via Tender Link by registering their interest at: <https://www.tenderlink.com/efl>

EFL will not accept any hard copy submission to be dropped in the tender box at EFL Head Office in Suva.

This tender closes at 4.00pm (1600hrs) on Wednesday 9th April, 2025.

For further information or clarification please contact our Supply Chain Office on phone **(+679) 3224360 or (+679) 9992400** or email us on tenders@efl.com.fj

The bidders must ensure that their bid is inclusive of all Taxes payable under Fiji Income Tax Act. Bidders are to clearly state the percentage of VAT that is applicable to the bid prices.

The lowest bid, will not necessarily be accepted as the successful bid.

The Tender Bids particularly the “Price” must be typed and not hand written.

Any request for the extension of the closing date must be addressed to EFL in writing three (3) working days prior to the tender closing date.

Tender Submission via email or fax will not be accepted.