



**ENERGY FIJI LIMITED
TENDER DOCUMENT**

**DESIGN, MANUFACTURE, TEST, SUPPLY
and INSTALL TWO (2) X 20/25MVA
33kV/11kV POWER TRANSFORMERS AT
HIBISCUS PARK SUBSTATION, SUVA**

TENDER NO: MR 140/2025

Invitation for Bids

Date : 29th March, 2025
Tender No : MR 140/2025

Energy Fiji Limited ("the Employer") invites bids from reputable transformers manufacturer companies for the design, manufacture, and supply, and transport, install and commission Two (2) x new 33kV/11kV, 20/25MVA power transformers at its Hibiscus Park Substation.

Bidders are requested to upload electronic copies via Tender Link by registering their interest at: <https://www.tenderlink.com/efl> for

The complete design, manufacture, testing, shipping and installation of 2 x 20/25MVA on the pads, 33kV/11kV, Dyn1, 50Hz, ONAN/ONAF power transformers with on-load MR Vacuum Tap diverter switch tap changer at Hibiscus Park Substation.

All tenders for the contract shall be submitted online on the appropriate tender forms provided and shall include the completed guarantees, price schedule, technical schedule and schedules of experience etc. relevant copies of which are included. The tender shall be on the basis of a lump sum contract based on firm prices.

For further information or clarification please contact our Supply Chain Office on phone (+679) 3224360 or (+679) 9992400 or email us on tenders@efl.com.fj

Site visit at Hibiscus Park Substation with EFL representatives will be at 11.00am on Tuesday, 8th April, 2025.

Deadline for submission of tenders shall be 1600 hours on 23rd April, 2025.

During evaluation of tenders, the Authority will invite a tenderer or tenderers for discussions, presentations and any necessary clarification before awarding of the contract.

TABLE OF CONTENT

SECTION 1 INSTRUCTION TO BIDDERS.....	5
SECTION 2 GENERAL CONDITIONS OF CONTRACT	18
SECTION 3 CONDITIONS OF PARTICULAR APPLICATION	19
SECTION 4 EMPLOYER’S REQUIREMENTS – PART I SCOPE OF WORKS	26
1.0 GENERAL DESCRIPTION	27
1.1 Background.....	27
1.2 Extent of Work.....	27
1.3 Cable Terminations.....	28
1.4 Training.....	28
SECTION 5 EMPLOYER’S REQUIREMENTS - PART II TECHNICAL SPECIFICATIONS.....	30
2.0 GENERAL INFORMATION	31
2.1 ASSOCIATED PLANT DETAILS	31
2.2 ELECTRICAL DESIGN CRITERIA.....	31
2.3 QUALITY OF MATERIALS AND WORKMANSHIP	32
2.4 STANDARDS	32
2.5 DETAILED DESIGN OF PLANT AND EQUIPMENT	33
2.6 PLANT AND EQUIPMENT TO BE SUPPLIED	33
2.7 INSPECTION AND TESTING.....	33
2.8 TRAINING OF EFL PERSONNEL	34
2.9 TOOLS AND EQUIPMENT	34
2.10 SPARES.....	34
2.11 TECHNICAL LITERATURE - OPERATIONS AND MAINTENANCE MANUALS.....	34
2.12 Maintenance.....	35
2.13 TYPE TEST CERTIFICATES.....	35
2.14 SITE CONDITIONS.....	35
2.15 PACKING.....	35
2.16 PROGRAMME AND PROGRESS OF WORK.....	36
3.0 SECONDARY WIRING AND ANCILLARY ELECTRICAL APPARATUS	37
3.1 SECONDARY WIRING	37
3.2 TERMINAL BOARDS.....	38
3.3 TERMINALS	39
3.4 CONTROL SWITCHES AND PUSHBUTTONS	39
3.5 ELECTRICAL MOTORS.....	40
3.6 INDICATING LAMPS AND FITTINGS.....	40
3.7 STARTERS AND CONTACTORS.....	40
3.8 JUNCTION, TERMINAL BOXES AND TRANSFORMER CUBICLES	41
3.9 TRANSFORMER MARSHALLING KIOSKS	42
3.10 GAUGE CUBICLES AND PANELS.....	42
3.11 ANTI-CONDENSATION HEATERS	42
3.12 INTERIOR LIGHTS.....	42
3.13 CABLES AND CABLE LADDERS	43
3.14 LABELS.....	43
4.0 PROTECTION, METERING AND CONTROL	44
4.1 TRANSFORMER PROTECTION	44
5.0 TRANSFORMER.....	49
5.1 TYPE OF TRANSFORMER AND OPERATING CONDITIONS	49
5.2 RATING AND OPERATION	49
5.3 TRANSFORMER CORE	50
5.4 WINDING	51

5.5	COOLING.....	52
5.6	CONTINUOUS MAXIMUM RATING	53
5.7	ELECTRICAL CONNECTION	53
5.8	ABILITY TO WITHSTAND SHORT CIRCUIT	53
5.9	Service Conditions.....	54
5.10	NOISE	54
5.11	Audible Sound Level	54
5.12	CORONA INCEPTION FIELDS.....	55
5.13	HARMONIC SUPPRESSION	55
5.14	MAGNETIC CIRCUIT AND WINDINGS	55
5.15	WINDING CONNECTIONS.....	55
5.16	THERMAL AND MOISTURE MONITORING.....	56
5.17	Internal Earthing	56
5.18	Earthing Terminals.....	57
5.19	CABLE END BOX	57
5.20	TANKS AND ANCILLARY EQUIPMENT.....	59
5.21	Galvanising	64
5.22	ANTI CORROSION DESIGN.....	65
5.23	FINISHES.....	66
5.24	RATING, DIAGRAM AND VALVE PLATES.....	68
5.25	COOLING PLANT.....	68
5.26	VOLTAGE CONTROL	71
5.27	BUSHING	73
6.0	MECHANICAL STRENGTH AND SEISMIC REQUIREMENTS	76
6.1	GENERAL.....	76
6.2	SEISMIC REQUIREMENT FOR GAS OPERATED RELAYS.....	76
6.3	WIND LOADS.....	77
6.4	ALLOWABLE STRESS.....	77
6.5	DESIGN LOAD CASES	77
6.6	Design loads (summary)	77
6.7	SEISMIC QUALIFICATION.....	77
6.8	Seismic qualification plate	78
6.9	General design requirements.....	78
7.0	COMPLIANCE REQUIREMENTS	79
7.1	QUALITY ASSURANCE.....	79
7.2	CORE AND WINDING CALCULATIONS	79
7.3	FIELD PLOTS	79
7.4	SHIPMENT AND DRYING OUT	80
8.0	TEST AT MANUFACTURE'S WORK.....	82
8.1	GENERAL.....	82
8.2	Additional Tests to be carried out during Manufacture	82
8.3	Main Transformers	83
8.4	Routine Tests	83
8.5	Type Tests	83
8.6	FACTORY ACCEPTANCE TEST	83
8.7	Main Transformer Bushings	85
8.8	Routine Test.....	86
8.9	Type test	86
8.10	MR Reinhausen VACUUM VACUTAP ON-LOAD DIVERTOR SWITCH Tap Changer	86
8.11	Type Test.....	86
8.12	Site Tests	86
9.0	PACKING	88
9.1	MAIN TANK.....	88
9.2	ELECTRONIC IMPACT RECORDERS	88
9.3	COMPONENTS AND SPARES	88

SECTION 6 FORM OF PROPOSALS AND APPENDICES 89

Form of Tender.....	90
Appendix to Tender.....	91
SECTION 7 SAMPLE FORMS	93
Form of Contract Agreement	94
Form of Performance Security (Bank Guarantee)	95
Form of Advance Payment Security (Bank Guarantee)	96
SECTION 8 SCHEDULES - PART I SCHEDULE OF PRICES	97
10.0 NOTES ON SCHEDULES.....	98
10.1 SCHEDULE OF PRICES & CONDITIONS OF PAYMENT.....	98
10.2 SCHEDULES OF RATES & PRICES.....	99
10.3 PART A - PLANT AND EQUIPMENT INCLUDING MANDATORY SPARE PARTS.....	100
10.4 PART B - INSTALLATION AND OTHER SERVICES – Local Component.....	101
10.5 GRAND SUMMARY.....	102
10.6 BIDDERS TOOLS & TEST EQUIPMENT.....	102
10.7 RECOMMENDED TOOLS & SPARE PARTS.....	103
10.8 RATES FOR VARIATION.....	104
SECTION 9 SCHEDULES - PART II SCHEDULE OF SUPPLEMENTARY INFORMATION	105
11.0 TECHNICAL PARAMETERS	106
11.1 MANUFACTURERS, PLACES OF MANUFACTURE & TESTING.....	106
11.2 TECHNICAL PARTICULARS AND GUARANTEES – ELECTRICAL WORKS.....	107
11.3 TIMES FOR DELIVERY & COMPLETION AND CONTRACT COMPLETION TIMES.....	123
11.4 DEPARTURES FROM SPECIFICATIONS	124
11.5 MANUFACTURERS' STATEMENT OF EXPERIENCE	125
11.6 CONTRACTOR HEALTH & SAFETY PLAN	126
11.7 PLANT & EQUIPMENT REGISTER.....	131
11.8 CONTRACTOR CHEMICAL REGISTER.....	132
11.9 OTHER DOCUMENTS & DRAWINGS TO BE SUBMITTED WITH BID	133
11.10 TENDER SUBMISSION CHECK LIST.....	134

Section 1 Instruction to Bidders

	<p>A. General</p> <p>1. Scope of Bid</p> <p>1.1 Energy Fiji Limited (hereinafter referred to as "the Employer"), wishes to receive bids for Design, Manufacture, Supply and Installation of Two (2) 20/25MVA, Dyn1, 50Hz, ONAN/ONAF on-load power transformers as defined in these bidding documents (hereinafter referred to as "the Works").</p> <p>1.2 The successful bidder will be expected to complete the Works within 18 months from the date of commencement of the Works, which is the date of contract sign-off.</p> <p>2. Source of Funds</p> <p>2.1 Energy Fiji Limited has a capital works program which is self-funded and intends to use part of the funds for the contract ("the Contract") for which this Invitation to Bid is issued.</p> <p>3. Eligible Bidders</p> <p>3.1 This Invitation to Bid is open to transformer manufacturers, or an installation contractor preferred by a reputable manufacturer with written approval.</p> <p>3.2 Bidders shall provide such evidence of their continued eligibility satisfactory to the Employer as the Employer shall reasonably request.</p> <p>3.3 Bidders shall not be under a declaration of ineligibility for corrupt or fraudulent.</p> <p>4. Eligible Materials, Equipment and Services</p> <p>4.1 The materials, equipment, and services to be supplied under the Contract shall have their origin from reputable companies from various countries and all expenditures made under the Contract will be limited to such materials, equipment, and services. At the Employer's request, bidders may be required to provide evidence of the origin of materials, equipment, and services.</p> <p>Asbestos materials, materials or insulants containing PCB's, or other materials prohibited by the Fiji Laws shall not be used in the construction of the transformer.</p> <p>4.2 For purposes of Sub-Clause 4.1 above, "services" means the works and all project-related services including design services.</p> <p>4.3 For purposes of Sub-Clause 4.1 above, "origin" means the place where the materials and equipment are mined, grown, produced or manufactured, and from which the services are provided. Materials and equipment are produced when, through manufacturing, processing or substantial or major assembling of components, a commercial recognized product results that is substantially different in basic characteristics or in purpose or utility from its components.</p> <p>4.4 The materials, equipment and services to be supplied under the Contract shall not infringe or violate any industrial property or intellectual property rights or claim of any third party.</p>
--	--

5. Qualification of the Bidder

- 5.1 To be qualified for award of Contract, bidders shall:
- (a) Submit a written power of attorney authorizing the signatory of the bid to commit the bidder; and
 - (b) Specify joint venture memberships, certification and qualification as equipment manufacturer and subcontractor, financial capability, technical capability, supply and installation facilities with comparable technical parameters, manufacturing and installation capability, work in hand, future commitments and current litigation.
 - (c) Submit proposals regarding work methods, scheduling and resourcing which shall be, provided in sufficient detail to confirm the bidder's capability to complete the works in accordance with the specifications and the time for completion.
- 5.2 Bids submitted by a joint venture of two or more firms as partners shall comply with the following requirements:
- (a) the bid, and in case of a successful bid, the Form of Contract Agreement, shall be signed so as to be legally binding on all partners;
 - (b) one of the partners shall be authorized to be in charge; and this authorization shall be evidenced by submitting a power of attorney signed by legally authorized signatories of all the partners;
 - (c) The partner in charge shall be authorized to incur liabilities, receive payments and receive instructions for and on behalf of any or all partners of the joint venture and the entire execution of the Contract. All contract payments to be made by the Employer will be remitted to the authorized partner in charge, and it shall be their responsibility to disburse the payments to the other partners;
 - (d) all partners of the joint venture shall be jointly and severally liable for the execution of the Contract in accordance with the Contract terms, and a relevant statement to this effect shall be included in the authorization mentioned under (b) above as well as in the Bid Form and the Form of Contract Agreement (in case of a successful bid); and
 - (e) A copy of the agreement entered into by the joint venture partners shall be submitted with the bid.
- 5.3 Bidders shall also submit proposals of work methods and schedule in sufficient detail to demonstrate the adequacy of the bidders' proposals to meet the Employer's Requirements and the completion time referred to in Sub-Clause 1.2 above.

6. One Bid per Bidder

- 6.1 Each bidder shall submit only one bid either by itself, or as a partner in a joint venture. A bidder who submits or participates in more than one bid will cause all those bids to be rejected.

7. Cost of Bidding

- 7.1 The bidder shall bear all costs associated with the preparation and submission of its bid and the Employer will in no case be responsible or liable for those costs.

8. Site Visit

- 8.1 The bidder is advised to visit and examine the Site of Works and its surroundings and obtain for itself on its own responsibility all information that may be necessary for preparing the bid and entering into a contract for the design-build and completion of the Works. The costs of visiting the Site shall be at the bidder's own expense. The site can be visited on the following date and locations at:

Hibiscus Park Substation 11.00am on 8th March, 2025.

- 8.2 The bidder and any of its personnel or agents will be granted permission by the Employer to enter upon its premises and lands for the purpose of such inspection, but only upon the express condition that the bidder, its personnel and agents, will release and indemnify the Employer and its personnel and agents from and against all liability in respect thereof and will be responsible for death or personal injury, loss of or damage to property and any other loss, damage, costs and expenses incurred as a result of the inspection.

9. Content of Bidding Documents

B. Bidding Documents

9.1 The bidding documents are those stated below, and should be read in conjunction with any Addenda issued in accordance with Clause 11:

Section	<u>Invitation for Bids</u>
1	Instructions to Bidders
2	Part I - General Conditions
3	Part II - Conditions of Particular Application
4	Employer's Requirements Part I – Scope of Works
5	Employer's Requirements Part II – Technical Specification
6	Forms of Proposals and Appendices
7	Sample Forms
8	Schedules Part I – Schedule of Prices
9	Schedules Part II – Schedule of Supplementary Information

9.2 The bidder is expected to examine carefully the contents of the Bidding documents. Failure to comply with the requirements of bid submission will be at the bidder's own risk. Pursuant to Clause 29, bids which are not substantially responsive to the requirements of the bidding documents will be rejected.

10. Clarification of Bidding Documents

10.1 A prospective bidder requiring any clarification of the bidding documents may notify the Employer in writing by via email at the Employer's address indicated in the Invitation for Bids. Copies of the Employer's response, including a description of the inquiry, will be forwarded to all Employers of the bidding documents.

11. Amendment of Bidding Documents

11.1 At any time prior to the deadline for submission of bids, the Employer may, for any reason, whether at its own initiative or in response to a clarification requested by a prospective bidder, modify the bidding documents by issuing addenda.

11.2 Any addendum thus issued shall be part of the bidding documents pursuant to Sub-Clause 9.1, and shall be communicated in writing via email to all Employers of the bidding documents. Prospective bidders shall acknowledge receipt of each addendum by email to the Employer.

11.3 To afford prospective bidders reasonable time in which to take an addendum into account in preparing their bids, the Employer may extend the deadline for submission of bids, in accordance with Clause 23.

<p>12. Language of Bid</p> <p>13. Documents Comprising the Bid</p> <p>14. Bid Form and Price Schedules</p> <p>15. Bid Prices</p>	<p>C. Preparation of Bids</p>
	<p>12.1 The bid, and all correspondence and documents related to the bid, exchanged between the bidder and the Employer shall be written in the English language only.</p>
	<p>13.1 The bid submitted by the bidder shall be uploaded on the Tenderlink.</p>
	<p>The technical proposal shall contain the following:</p> <p>13.2</p> <ul style="list-style-type: none"> i. Form of Tender and Appendix to Tender; ii. Power of Attorney; iii. Information on Qualification; iv. Confirmation of Eligibility; v. Schedules of Prices: vi. Schedule of Major Items of Equipment; vii. Schedule of Manufacturers, Place of Manufacture and Testing viii. Schedule of Technical Particulars & Guarantees ix. Schedule of Times for Delivery & Completion and Contract completion times x. Schedule for Departures from Specification xi. Schedule of Manufacturers Statement of Experience xii. Schedule of Contractors Health & Safety Plan xiii. Schedule of Other Documents and Drawings to be submitted with the bid xiv. Any other materials required to be completed and submitted by bidders in accordance with these Instructions to Bidders.
	<p>14.1 The Bidder shall complete the Bid Form and the appropriate Price Schedules furnished in the bidding documents in the manner and detail indicated therein, following the requirements of Clauses 15 and 16.</p>
	<p>15.1 Unless specified otherwise in Employer's Requirements, Bidders shall quote for the entire facilities on a "single responsibility" basis such that the total bid price covers all the Contractor's obligations mentioned in or to be reasonably inferred from the bidding documents in respect of the design, manufacture, including procurement and subcontracting (if any), delivery, construction, installation and completion of the facilities. This includes all requirements under the Contractor's responsibilities for testing, pre-commissioning and commissioning of the facilities and, where so required by the bidding documents, the acquisition of all permits, approvals and licenses, etc., operation maintenance and training services and such other items and services as may be specified in the bidding documents, all in accordance with the requirements of the Conditions of Contract.</p> <p>15.2 Bidders shall give a breakdown of the prices in the manner and detail called for in the Schedules of Prices.</p> <p>15.3 In the Schedules, Bidders shall give the required details and a breakdown of their prices, including all taxes, With Holding Tax, duties, levies, and charges payable in the Employer's country as of twenty eight (28) days prior to the deadline for submission of bids, as follows:</p>

	<p>(a) Design including all necessary drawings and documentation for the Work.</p> <p>(b) Plant and equipment to be supplied from outside the Employer's country shall be quoted on a DDU to Site. In addition, estimated ocean freight charges, local transport, insurance, installation charges, and import duties and taxes shall also be indicated separately in foreign currency and in local currency.</p> <p>(c) Installation work and Other Services shall be quoted separately and shall include rates or prices for all labour, contractor's equipment, temporary works, materials, consumables and all matters and things of whatsoever nature, including local transportation, operations and maintenance services, the provision of operations and maintenance manuals, training, etc. where identified in the bidding documents, as necessary for the proper execution of the Civil Works, Installation and Other Services.</p> <p>(d) Recommended spare parts shall be quoted separately as specified in either subparagraph (b) or (c) above in accordance with the origin of the spare parts.</p> <p>(e) Tenderers are strongly advised to check with the Fiji Islands Revenue and Customs Authority, 5th Floor Dominion House, Suva, Private Mail Bag, Suva, regarding income tax, With Holding Tax and corporate tax which may become payable in Fiji, and to make particular note of arrangements and procedures which are necessary because of the existence or non-existence of taxation agreements between Fiji and other countries. Tel No. (679) 3301551.</p>
	<p>15.4 The term DDU shall be governed by the rules prescribed in the current edition of "Incoterms", published by the International Chamber of Commerce, Paris.</p> <p>15.5 Prices quoted by the bidder shall be on a fixed lump sum basis with no forex exchange variation and shall not be adjusted for changes in the cost of labour, material or other matters except only for changes in legislation in accordance to Sub-Clause 13.16 of the General Conditions of Contract.</p>
16. Bid Currencies	<p>16.1 Prices shall be quoted in the following currencies:</p> <p>(a) the prices shall be quoted in the Fijian currency and either in the currency of the bidder's home country, or in Australian and New Zealand Dollars only:</p> <p>(b) a bidder expecting to incur a portion of its expenditures in the performance of the Contract in more than one currency, and wishing to be paid accordingly, shall so indicate in its Bid; and.</p> <p>16.2 Bidders shall not indicate there any foreign currency requirements in the Appendix to Price Proposal as the price is fixed lump sum.</p>

17. Bid Validity	16.3	Bidders may be required by the Employer to clarify their local and foreign currency requirements, and to substantiate that the amounts included in the Schedule of Prices and shown in the Appendix to Price Proposal are reasonable and responsive to Sub-Clause 15.1 in which case a detailed breakdown of its foreign currency requirements shall be provided by the bidder.
	17.1	Bids shall remain valid for a period of 120 days after the date of opening of technical proposals specified in Sub-Clause 26.1.
	17.2	In exceptional circumstances, prior to expiry of the original bid validity period, the Employer may request that the bidders extend the period of validity for a specified additional period. The request and the responses thereto shall be made in writing via email. A bidder may refuse the request without forfeiting its bid security. A bidder agreeing to the request will not be required or permitted to modify its bid, but will be required to extend the validity of its bid security for the period of the extension, and in compliance with Clause 18 in all respects.
18. Alternative Proposals by Bidders	18.1	Bidders wishing to offer technical alternatives to the Employer's Requirements of the bidding documents must first price the Employer's Requirements as described in the bidding documents and shall further provide all information necessary for a complete evaluation of the alternative by the Employer, including drawings, design calculations, technical specifications, breakdown of prices, and proposed construction methods. Only the technical alternatives, if any, of the best value for money bidder conforming to the basic technical requirements shall be considered by the Employer.
19. Format and Signing of Bid	19.1	The original and all copies of the bid shall be typed or written in indelible ink (in the case of copies, Photostats are also acceptable) and shall be signed by a person or persons duly authorized to sign on behalf of the bidder, pursuant to Sub-Clauses 5.1 (a) or 5.2 (b), as the case may be. All pages of the bid where entries or amendments have been made shall be initialled by the person or persons signing the bid.
	19.2	The bidder shall furnish information as described in the Form of Bid on commission or gratuities, if any, paid or to be paid relating to this Bid, and to Contract execution if the bidder is awarded the Contract.
20. Sealing and Marking of Bids	D.	Submission of Bids
	20.1	Bidders are requested to upload electronic copies via Tender Link by registering their interest at: https://www.tenderlink.com/efl
	21.1	Bids must be received by the Employer at the address specified above no later than 1600 hours (Fiji Time) 23 rd March, 2025.
21. Deadline for Submission of Bids	22.2	The Employer may, at its discretion, extend the deadline for submission of bids by issuing an addendum in accordance with Clause 11, in which case all rights and obligations of the Employer and the bidders previously subject to the original deadline will thereafter be subject to the deadlines extended.

22. Late Bids	23.1	Any bid received by the Employer after the deadline for submission of bids prescribed in Clause 21 will be not accepted
23. Modification and Withdrawal of Bids	23.1	The bidder may modify or withdraw its bid after bid submission on the Tenderlink by editing submission.
	23.3	No bid may be modified by the bidder after the deadline for submission of bids.
24. Opening of Technical Proposals	E.	Bid Opening and Evaluation
	25.1	The Employer will open the bids, including modifications made pursuant to Clause 23, at the earliest suitable date and time after closing of the bids, at the following location: <i>Energy Fiji Limited 2 Marlow Street, Suva, Fiji</i>
25. Process to Be Confidential	25.1	Information relating to the examination, clarification, evaluation and comparison of bids and recommendations for the award of a contract shall not be disclosed to bidders or any other persons not officially concerned with such process. Any effort by a bidder to influence the Employer's processing of bids or award decisions may result in the rejection of the bidder's bid.
26. Clarification of Bids and Contacting the Employer	26.1	To assist in the examination, evaluation and comparison of bids, the Employer may, at its discretion, ask any bidder for clarification of its bid. The request for clarification and the response shall be in writing via email, but no change in the price or substance of the bid shall be sought, offered or permitted except as required to confirm the correction of arithmetic errors discovered by the Employer in the evaluation of the bids in, accordance with Clause 28.
	26.2	Subject to Sub-clause 27.1, no bidder shall contact the Employer on any matter relating to its bid from the time of the bid opening to the time the Contract is awarded. If the bidder wishes to bring additional information to the notice of the Employer, it should do so in writing.
	26.3	Any effort by the bidder to influence the Employer in the Employer's bid evaluation, bid comparison or Contract award decisions may result in the rejection of the bidder's bid.
27. Preliminary Examination of Bids and Determination of Responsiveness	27.1	Prior to the detailed evaluation of bids, the Employer will determine whether each bid (i) meets the eligibility criteria; (ii) has been properly signed; (iii) is accompanied by the required securities; (iv) is substantially responsive to the requirements of the bidding documents; (v) is conforming to Clause 15; and (vi) provides any clarification and/or substantiation that the Employer may require pursuant to Clause 26.
	27.2	A substantially responsive bid is one, which conforms to all the terms, conditions and requirements of the bidding documents, without material deviation or reservation. A material deviation or reservation is one (i) which affects in any substantial way the scope, quality or performance of the Works; (ii) which limits in any substantial way, inconsistent with the

		bidding documents, the Employer's rights or the bidder's obligations under the Contract; or (iii) whose rectification would affect unfairly the competitive position of other bidders presenting substantially responsive bids.
	27.3	If a bid is not substantially responsive, it will be rejected by the Employer, and may not subsequently be made responsive by correction or withdrawal of the nonconforming deviation or reservation.
28. Correction of Errors	28.1	Bids determined to be substantially responsive will be checked by the Employer for any arithmetic errors. Arithmetic errors will be rectified on the following basis. If there is a discrepancy between the unit rate and the total cost that is obtained by multiplying the unit rate and quantity, the unit rate shall prevail and the total cost will be corrected unless in the opinion of the Employer there is an obvious misplacement of the decimal point in the unit rate, in which case the total cost as quoted will govern and the unit rate corrected. If there is a discrepancy between the total bid amount and the sum of total costs, the sum of the total costs shall prevail and the total bid amount will be corrected.
	28.2	The amount stated in the Form of Bid will be adjusted by the Employer in accordance with the above procedure for the correction of errors and, shall be considered as binding upon the bidder. If the bidder does not accept the corrected amount of bid, its bid will be rejected, and the bid security may be forfeited in accordance with Sub-Clause 17.6 (b).
29. Conversion to Single Currency	29.1	The Employer will convert the amounts in various currencies in which the Bid Price is payable to the currency of the Employer's country at the selling exchange rates officially prescribed for similar transactions as established by the Reserve Bank of Fiji on the date of opening of bids.
30. Evaluation and Comparison of Bid	30.1	The Employer will evaluate and compare only the bids determined to be substantially responsive in accordance with Clause 27.
	30.2	For plant and equipment, the comparison shall be of the DDU to Site price of plant and equipment offered. The Employer's comparison will also include the costs resulting from application of the evaluation procedures described in Sub-Clause 30.4.
	30.3	<p>The Employer will carry out a detailed evaluation of the bids in order to determine whether the bidders confirm to meet the prequalification requirements and whether the bids are substantially responsive to the requirements set forth in the bidding documents. In order to reach such a determination, the Employer will examine the information supplied by the Bidders and other requirements in the bidding documents, taking into account the following factors.</p> <p>(a) Qualification</p> <p>(i) the determination will take into account the Bidder's updated financial, technical and production capabilities and past performance; it will be based upon an examination of the documentary evidence submitted by the Bidder, pursuant to Sub-Clause 5.1(b), as well as such other information as the Employer deems necessary and appropriate; and</p>

- (ii) An affirmative determination will be a prerequisite for the Employer to continue with the evaluation of the bid; a negative determination will result in rejection of bid.

(b) Technical

- (i) overall completeness and compliance with the Employer's Requirements; the technical merits of plant and equipment offered and deviations from the Employer's Requirements; suitability of the facilities offered in relation to the environmental and climatic conditions prevailing at the site; quality, function and operation of any process control concept included in the bid;
- (ii) achievement of specified performance criteria by the facilities;
- (iii) type, quantity and long-term availability of spare parts and maintenance services;

(c) Commercial

- (i) the cost of all quantifiable deviation and omissions from the contractual and commercial conditions and the Employer's Requirements as identified in the bid, and other deviations and omissions not so identified;
- (ii) compliance with the time schedule called for in Appendix to Bid and evidenced as needed milestone schedule provided in the bid;
- (iii) the functional guarantees of the facilities offered; and
- (iv) the extra cost of work, services, facilities etc., required to be provided by the Employer or their parties.

30.4 Pursuant to Sub-Clause 30.3, the following evaluation methods will be followed:

- (a) **Contractual and commercial deviations:** The evaluation shall be based on the evaluated cost for fulfilling the Contract in compliance with all commercial, contractual and technical obligations under this bidding document. The Employer will make its own assessment of the cost of any deviations for the purpose of ensuring fair comparison of bids.
- (b) **Time Schedule:** The plant and equipment covered by this bidding are required to be shipped, installed and the facilities completed within the period specified in Sub-Clause 1.2 and the Appendix to the Bid.
Bidders submitting bids which deviate from the time schedule specified will be rejected.
- (c) The price of recommended spare parts quoted in Schedule of Prices shall not be considered for evaluation.
- (d) **Functional Guarantee of the facilities:**

31. Domestic Preference

- (i) Bidders shall state the functional guarantees (e.g. performance, efficiency, consumption) of the proposed facilities in response to the Employer's Requirements. Plant and equipment offered shall have a minimum (or a maximum, as the case may be) level of functional guarantees specified in the Employer's Requirements to be considered responsive. Bids offering plant and equipment with functional guarantees less (or more) than the minimum (or maximum) specified shall be rejected.
 - (e) **Work, services, facilities etc., to be provided by the Employer:** Where bids include for the undertaking of work or the provision of services or facilities by the Employer in excess of the provisions allowed for in the bidding documents, the Employer shall assess the costs of such additional work, services and/or facilities during the duration of the Contract. Such costs shall be added to the bid price for evaluation.
- 30.5
- (a) Any adjustments in price which result from the above procedures shall be added, for purposes of Comparative evaluation only, to arrive at an "Evaluated Bid Price". Bid prices quoted by Bidders shall remain unaltered.
 - (b) The Employer reserves the right to accept or reject any variation, deviation or alternative offer. Variations, deviations, and other factors which are in excess of the requirements of the bidding documents or otherwise result in the accrual of unsolicited benefits to the Employer shall not be taken into account in bid evaluation.
 - (c) The estimated effect of the price adjustment provisions of the Conditions of Particular Application, applied over the period or execution of the Contract, shall not be taken into account in bid evaluation.
 - (d) If the bid of the successful bidder is substantially below the Employer's estimate for the Contract, the Employer may require the bidder to produce detailed price analyses to demonstrate the internal consistency of those prices. After evaluation of the price analysis, the Employer may require that the amount of the performance security set forth in Clause 37 be increased at the expense of the successful bidder to a level sufficient to protect the Employer against financial loss in the event of default of the successful bidder under the Contract.
- 31.1
- No preference shall be given for domestic contractor or joint venture partners.

	F.	Award of Contract
32. Award	32.1	Subject to Clause 35, the Employer will award the Contract to the bidder whose bid has been determined to be substantially responsive to the bidding documents and who has offered the Best Value for Money, provided that such bidder has been determined to be (i) eligible in accordance with the provisions of Clause 3; and (ii) qualified in accordance with the provisions of Clause 5.
	32.2	The bidder may be required to attend meetings at the Employer's office for techno-commercial discussions prior to the signing of the Contract at no cost to the Employer.
33. Employer's Right to Accept any Bid and to Reject any or all Bids	33.1	Notwithstanding Clause 32, the Employer reserves the right to accept or reject any bid, and to annul the bidding process and reject all bids, at any time prior to award of Contract, without thereby incurring any liability to the affected bidder or bidders or any obligation to inform the affected bidder or bidders of the grounds for the Employer's action.
34. Notification of Award	34.1	Prior to expiration of the period of bid validity prescribed by the Employer, the Employer will notify the successful bidder by e-mail that its bid has been accepted. This letter (hereinafter and in the Conditions of Contract called the "Letter of Acceptance") shall name the sum which the Employer will pay the Contractor in consideration of the execution, completion and maintenance of the Works by the Contractor as prescribed by the Contract (hereinafter and in the Conditions of Contract called "the Contract Price").
	34.2	The notification of award will constitute the formation of the Contract.
	34.3	Upon the furnishing by the successful bidder of a performance security, the Employer will promptly notify the other bidders that their bids have been unsuccessful
35. Signing of Contract Agreement	35.1	At the same time that he notifies the successful bidder that its bid has been accepted, the Employer will send the bidder the Form of Contract Agreement provided in the bidding documents, incorporating all agreements between the parties.
	35.2	Within 28 days of receipt of the Form of Agreement, the successful bidder shall sign the Form and return it to the Employer.
36. Performance Security	36.1	Within 28 days of receipt of the notification of award from the Employer, the successful bidder shall furnish to the Employer a performance security in an amount of 10 percent of the Contract Price in accordance with the Conditions of Contract. The form of performance security provided in Section 6 of the bidding documents shall be used.
	36.2	Failure of the successful bidder to comply with the requirements of Clauses 35 or 36 shall constitute sufficient grounds for the annulment of the award and forfeiture of the bid security.

**37. Corrupt or
Fraudulent
Practices**

37.1

The Employer requires that the Contractor observe the highest standard of ethics during the procurement and execution of such contracts. In Pursuance of this policy, the Employer:

- (a) defines, for the purposes of this provision, the terms set forth below as follows:
 - i) "corrupt practice" means behaviour on the part of officials in the public or private sectors by which they improperly and unlawfully enrich themselves and/or those close to them, or induce others to do so, by misusing the position in which they are placed, and it includes the offering, giving, receiving or soliciting of anything of value to influence the action of any such official in the procurement process or in contract execution; and
 - ii) "fraudulent practice" means a misrepresentation of facts in order to influence a procurement process or the execution of a contract to the detriment of the Employer, and includes collusive practice among bidders (prior to or after bid submission) designed to establish bid prices at artificial non-competitive levels and to deprive the Employer of the benefits of free and open competition;
- (b) will reject a proposal for award if it determines that the bidder recommended for award has engaged in corrupt or fraudulent practices in competing for the contract in question;

37.2

Furthermore, bidders shall be aware of the provision stated in Sub-Clause 1.16 and Sub-Clause 15.5 of the Conditions of Contract, Part II - Conditions of Particular Application.

Section 2 General Conditions of Contract

FIDIC CONDITIONS OF CONTRACT

For

DESIGN, BUILD & TURNKEY

First Edition, 1995

A Publication of the International Federation of Consulting Engineers

Notes on the Conditions of Contract

The Conditions of Contract comprise two parts: Part I – General Conditions (Section 2 of this document), and Part II – Conditions of Particular Application (Section 3 of this document).

The International Federation of Consulting Engineers (FIDIC) has recently prepared the First Edition (1995) of Conditions of Contract for Design-Build and Turnkey Contracts. FIDIC Part I – General Conditions is included herein, complete and without any changes as Section 2 of these documents.

Copies of the FIDIC Conditions of Contract can be obtained from:

FIDIC Secretariat
P.O. Box 86
1000 Lausanne 12
Switzerland
Facsimile: 41 21 653 5432
Telephone: 41 21 653 5003

Section 3 Conditions of Particular Application

Sub-Clause 1.1 Definitions

Amend subpara 1.1.1.3 of Sub-Clause 1.1 by adding the following words at the end:

"The word 'tender' is synonymous with bid'."

Amend subpara 1.1.1.4 of Sub-Clause 1.1 by adding the following words at the end:

"The words 'Appendix to Tender' are synonymous with the words 'Appendix to Technical Proposal' and 'Appendix to Price Proposal'."

Add the following subparagraph to Sub-Clause 1.1:

"1.1.2.7 "EFL" means the Energy Fiji Limited

Sub-Clause 1.4 Law and Language

Replace the text of Sub-Clause 1.4 and add the following:

"The Contract shall be governed by and construed in accordance with the Laws of Fiji.

The language is the English language."

Sub-Clause 1.5 Contract Agreement

Substitute the wordings in Part I with the following:

"A Contract Agreement in the form annexed, with such modifications as may be necessary to record the agreement reached shall be executed. The costs of stamp duties and similar charges imposed by the law shall be borne by the Employer."

Sub-Clause 1.6 Priority of Documents

Replace the list of documents listed under (a) to (j) and add the following:

- (a) the Contract Agreement;
- (b) the Letter of Acceptance;
- (c) the Employer's Requirements;
- (d) the Bid;
- (e) the Conditions of Contract, Part II;
- (f) the Conditions of Contract, Part I;
- (g) the Schedules;
- (h) the Drawings;
- (i) the Contractor's Proposal; and
- (j) the Correspondences During Tender Evaluation"

Sub-Clause 1.15 Confidentiality

Additional sub-clause:

"The Contractor shall treat the details of the Contract as private and confidential, except to the extent necessary to carry out its obligations under it. The Contractor shall not publish, permit to be published or disclose any particulars of the Contract in any trade or technical paper or elsewhere without the prior consent in writing of the Employer."

**Sub-Clause 1.16
Inspections and
Audit by the
Employer**

**Sub Clause 2.5
Customs and Import
Duties**

**Sub-Clause 3.1
Employer
Representative's
Duties and
Authority**

Add the following sub-clause:

"The Contractor shall permit the Employer to inspect the Contractor's accounts and records relating to the performance of the Contract and to have them audited by auditors appointed by the Employer, if so required by the Employer."

(a) The Contractor shall pay for all customs and import duties including clearing, handling charges, port dues and demurrage except only for customs and import duties in respect of Plant, Transformer and spare parts to be supplied under the Contract, which shall be the responsibility of the Employer.

(b) Customs and import duties if any in respect of the Contractor's Equipment shall be borne by the Contractor.

(c) Notwithstanding Sub Clauses 2.5(a) and 2.5 (b) above, the Contractor shall ensure that all customs and import duties and taxes are paid on time (including making payment for duties and taxes that are the responsibility of the Employer and invoicing the Employer therefor after the fact). For the avoidance of doubt the Contractor shall not be entitled to any extension of time as a result of any delayed payments of import duties and taxes which was within its control.

Add the following clause as required:

"The Employer's Representative shall obtain the specific approval of the Employer before taking action under the following clauses of the Conditions of Contract Part I.

- (a) approving sub-contracting of any part of the Works under Sub-Clause 4.5.
- (b) certifying additional cost to the Contract Price.
- (c) granting an extension of time for completion under Sub-Clause 8.3.
- (d) suspending progress of part or all of the Works under Sub-Clause 8.8.
- (e) issuing a variation under Clause 14, except if such a variation would increase the Contract Price by no more than FJD 50,000.
- (f) issuing Taking-Over Certificate for the whole of the Works under Sub-Clause 10.1.
- (g) issuing Performance Certificate for the Works under Sub-Clause 12.9.

Notwithstanding the obligation to obtain approval as set out above, if in the opinion of the Employer's Representative, an emergency occurs affecting the safety of life or of the Works or of adjoining property, it may, without relieving the Contractor of any of its duties and responsibilities under the Contract, instruct the Contractor to execute all such work or to do all such things as may, in the opinion of the Employer's Representative be necessary to abate or reduce the risk. The Contractor shall forthwith comply with the instructions of the Employer's Representative despite the absence of approval of the Employer. The Employer's Representative shall determine the extra cost to the Contractor for carrying out of such instruction and obtain the Employer's approval for an addition to the Contract Price."

Sub-Clause 4.1 General Obligations	<p>Add the following sentence to precede the existing text under Sub-Clause 4.1:</p> <p>"Notwithstanding any other provision to the contrary, the Contractor is required to check the design criteria and calculations (if any) included in the Employer's Requirements, to confirm their correctness, in its bid and to assume full responsibility for them."</p>
Sub-Clause 4.2 Performance Security	<p>Replace the first paragraph of Sub-Clause 4.2 with the following:</p> <p>"The Contractor Shall provide security for its proper performance of the Contract to the Employer within 28 days after the receipt of the Letter of Acceptance. The performance security shall be in the form of a bank guarantee from a commercial bank and not Financial Service Institution, issued either (a) by a bank located in the country of the Employer or a foreign commercial bank through a correspondent bank located in the country of the Employer, or (b) directly by a foreign bank acceptable to the Employer. The performance security shall be denominated in the types and proportions of currencies in which the Contract Price is payable. When providing such security to the Employer, the Contractor shall notify the Employer's Representative of so doing."</p>
Sub-Clause 4.3 Contractor's Representative	<p>At the end of Sub-Clause 4.3 add:</p> <p>"The Contractor's Representative must be fluent (both spoken and written) in the English language."</p>
Sub-Clause 4.4 Co-ordination of the Works	<p>Modify the first sentence of Sub-Clause 4.4 to read:</p> <p>"The Contractor shall be responsible for the co-ordination and proper execution of the Works, including co-ordination with other contractors and organizations to the extent specified in the Employer's Requirements."</p>
Sub-Clause 4.9 Site Data	<p>Modify the last sentence of paragraph 1 of Sub-Clause 4.9 to read:</p> <p>"The Contractor shall be responsible for interpreting all data including data listed elsewhere in the Contract as open for inspection at EFL, Hibiscus Park Substation, Fiji".</p>
Sub-Clause 4.14 Program	<p>Delete the third sentence of Sub-Clause 4.14 indicated below:</p> <p>"Unless otherwise stated and late finish dates".</p>
Sub-Clause 5.2 Construction Documents	<p>In the fifth line of the second paragraph of sub-clause 5.2 replace "21" with "28".</p> <p>In Sub-Clause 5.2 delete sub-paragraph (a) and substitute:</p> <p>"(a) Construction shall not commence until the Contractor receives from the Employer's Representative approval of the Construction Documents relevant to the design and construction of such parts; provided always that:</p> <ul style="list-style-type: none"> (i) if the Employer's Representative fails to give his ruling within 21 days, the Contractor shall give written notice (for the purpose of this sub-clause "Contractor's Notice") to the Employer's Representative of such failure; and (ii) if the Employer's Representative fails to give his ruling within 7 days of receipt of the Contractor's Notice, then the Contractor may

	<p>proceed with the construction as though approval had been given".</p>
<p>Sub-Clause 5.4 Technical Standards & Regulations</p>	<p>Add the following sentence to the end of the Sub-Clause 5.4:</p> <p>"In respect of technical specifications and standards, IEC (International Electrotechnical Commission based in 3, rue de Varembe, PO Box 131, CH-1211 Geneva 20, Switzerland) standards are to be adopted in general. Any national or international standards which promise to confer equal or better quality than the standards specified will also be acceptable. In all instances a copy of the relevant standards should be forwarded to the Employer's Representative".</p>
<p>Sub-Clause 6.7 Health and Safety</p>	<p>To sub-clause 6.7 add the following paragraph:</p> <p>The Contractor must, at all times during the execution of the Work, comply with the Health and Safety at Work Act 1996, the Electricity Act Cap 180, Energy Fiji Limited "Safety Manual" – Safety Rules and First aid For Employees Of the Authority.</p>
<p>Sub-Clause 6.8 Contractor's Superintendence</p>	<p>At the end of Sub-Clause 6.8 add:</p> <p>"All the Contractors superintending staff shall have a working knowledge of the English language."</p>
<p>Sub-Clause 6.11 Foreign staff and Labour</p>	<p>"The Contractor may import such staff, and labourers as are required in order to execute the Works. The Contractor must ensure that all such staff and labour are provided with the required visas and work permits. The Contractor shall be responsible for the return to the place where they were recruited or to their domicile of all persons whom the Contractor recruited and employed for the purpose of or in connection with the Contract and the cost of all business visa requirements. The Contractor shall be responsible for such persons as are to be returned until they shall have left the Site or, in the case of foreign nationals who have been recruited outside the Country, shall have left it."</p>
<p>Sub-Clause 6.12 Measures against Insect & Pest Nuisance</p>	<p>"The Contractor shall at all times take the necessary precautions to protect all staff and labour employed on the Site from insect and pest nuisance, and to reduce the dangers to health and the general nuisance occasioned by the same. The Contractor shall provide its staff and labour with suitable prophylactics for the prevention of malaria and dengue fever and take steps to prevent the formation of stagnant pools of water. The Contractor shall comply with all the regulations of the local health authorities and shall arrange to spray thoroughly with approved insecticide all buildings erected on the Site. Such treatment shall be carried out at least once a year or as instructed by such authorities."</p>
<p>Sub-Clause 6.13 Epidemics</p>	<p>"In the event of any outbreak of illness of an epidemic nature, the Contractor shall comply with and carry out such regulations, orders and requirements as may be made by the Government or the local medical or sanitary authorities, for the purpose of dealing and overcoming the same."</p>
<p>Sub-Clause 6.14 Alcoholic Liquors or Drug</p>	<p>"The Contractor shall not import, sell, give, barter or otherwise dispose of any alcoholic liquor or drugs, or permit or suffer any such importation, sale, gift, barter or disposal by his Subcontractors, agents staff or labour."</p>

Sub-Clause 6.15 Arms and Ammunition	<p>"The Contractor shall not give, barter or otherwise dispose of to any person or persons, any arms or ammunition of any kind or permit or suffer to the same as aforesaid."</p>
Sub-Clause 6.16 Burial of the Dead	<p>The Contractor shall make all necessary arrangements for the transport, to any place as required for burial, of any of his expatriate employees or members of their families who may die in the Country.</p>
Sub-Clause 6.17 Festivals and Religious Customs	<p>The Contractor shall also be responsible, to the extent required by local regulations, for making any arrangements with regard to burial of any of his local employees who may die while engaged upon the Works.</p>
Sub-Clause 7.3 Inspection	<p>"The Contractor shall in all dealings with his staff and labour have due regard to all recognized festivals, days of rest and religious or other customs."</p>
Sub-Clause 7.7 Restriction on Eligibility	<p>To sub – clause 7.3 add the following paragraphs:</p> <p>The Employer and the Contractor shall carry out a joint walk through inspection to identify and document any defects/ deficiencies of the Works prior to commissioning, after which the Contractor shall rectify all the identified defects.</p> <p>The Employer and the Employer's Representative shall be entitled at any time during the term of this Contract to inspect any part of the Works and the Contractor shall give them full opportunity and access to conduct such inspection.</p>
Sub-Clause 13.2 Advance Payment	<p>(a) Any materials, equipment, services or design services which will be incorporated in or required for the Contract, as well as the Contractor's Equipment and other supplies, shall have their origin from reputable source countries acceptable to the Employer.</p> <p>(b) For the purpose of this clause, "services" means the works and all project-related services including design services.</p> <p>(c) For the purposes of this clause, "origin" means the place where the materials and equipment were mined, grown, produced, or manufactured, or from which the services are provided.</p> <p>(d) The origin of Goods and Services is distinct from the nationality of the Supplier."</p>
Sub-Clause 13.2 Advance Payment	<p>Modify the third sentence of this Sub-Clause to read:</p> <p>"The Employer's Representative shall issue an Interim Payment Certificate for the first instalment after (i) execution of the Contract Agreement by the parties hereto (ii) provision of the Performance Security in accordance with Sub-Clause 4.2 by the Contractor and (iii) provision of an unconditional commercial bank guarantee by the Contractor in a form and by a bank acceptable to the Employer in amounts and currencies equal to the advance payment."</p>
Sub-Clause 13.15 Calculation of Payments in Foreign Currency	<p>Delete Clause 13.15 and add the following:</p> <p>"The Contract shall be paid in the currencies stated in the Appendix to Bid and shall be in accordance with Schedule of Prices and Conditions of Payment.</p>

**Sub-Clause 13.15
Calculation of
Payments in
Foreign Currency**

The foreign and local currency portions of the balance of the Contract Price shall be amended by agreement between the Employer and the Contractor to reflect any substantial changes in the expected foreign and local currency requirements of the Contractor during the execution of the Works, provided that:

- (a) the Contractor shall inform the Employer and the Employer's Representative whenever any such substantial change may occur; or
- (b) the Employer's Representative may recommend a review of such expected requirements if in its judgment there is evidence of a change in the country of origin of equipment, materials, plants, or services to be provided under the Contract which should result in any substantial change of such expected requirements.

Any such amendment shall be affected by comparing the amounts quoted in the bid with the amounts already used in the Works and the Contractor's future needs for imported items."

To sub-clause 13.15 add the following paragraph:

The local (Fijian) and foreign component of the Contract Price shall not be subjected to any currency exchange rate variation.

**Sub-Clause 13.17
Taxation**

"(i) The prices bid by the Contractor shall include all taxes, duties and other changes imposed outside the Employer's country on the production, manufacture, sale and transport of the Contractor's equipment, Plant, materials and supplies to be used on or furnished under the Contract, and on the services performance under the Contract.

- (ii) The prices bid by the Contractor shall include all customs duties, import duties, with Holding Tax, business taxes, income and other taxes that may be levied in accordance to the laws and regulations in being as of the date 28 days prior to the closing date for submission of bids in the Employer's country on the Contractor's Equipment, Plant, materials and supplies (permanent, temporary and consumable) acquired for the purpose of the Contract and on the services performed under the Contract. Nothing in the Contract shall relieve the Contractor from its responsibility to pay any tax that may be levied in the Employer's country on profits made by it in respect of the Contract."

**Sub-Clause 15.5
Corrupt or
Fraudulent
Practices**

Delete the existing Sub-Clause 15.5 and substitute the following:

"If in the judgment of the Employer the Contractor has engaged in corrupt or fraudulent practices, in competing for or in executing the Contract, then the Employer may, after having given 14 days notice to the Contractor, terminate the Contractor's employment under the Contract and expel the Contractor from the Site, and the provisions of Clause 15 shall apply as if such expulsion had been made under Sub-Clause 15.2."

**Sub-Clause 17.3
Employer's
Risks**

This sub-clause is amended to read as follows:

"The Employer's risks are:

- (a) insofar as they directly affect the execution of the Works in the country where the Permanent Works are to be executed:
 - (i) war and hostilities (whether war be declared or not), invasion, act of foreign enemies in the Country;
 - (ii) rebellion, revolution, insurrection, or military or usurped power, or civil war in the Country;
 - (iii) ionizing radiations, or contamination by radioactivity from any nuclear fuel, or from any nuclear waste from the combustion of nuclear fuel, radioactive toxic explosive or hazardous properties of any explosive nuclear assembly or nuclear component thereof in the Country;
 - (iv) pressure waves caused by aircraft or other aerial devised travelling at sonic or supersonic speeds in the Country;
 - (v) riot, commotion or disorder, unless solely restricted to the employees of the Contractor or of its Subcontractors and arising from the conduct of the Works in the Country;
- (b) loss or damage due to the use or occupation by the Employer of any Section or part of the Permanent Works, except as may be provided for in the Contract;
- (c) any operation of the forces of nature (insofar as it occurs on the Site) which an experienced Contractor:
 - (i) could not have reasonably foreseen, or
 - (ii) could reasonably have foreseen, but against which he could not reasonably have taken appropriate measures to prevent loss or damage to physical property occurring."

**Sub-Clause 18.2
Insurance for
Works and
Contractor's
Equipment**

- (i) Amend the second sentence of the first and second paragraphs to read:

"This insurance shall cover loss or damage from any cause other than the Employer's risks listed in amended Sub-Clause 17.3 paras. (a)(i) to (iv) in Part II of the Conditions of Contracts".

- (ii) Amend the fourth sentence of the first paragraph to read:

"Such insurance shall cover the Employer and the Contractor from the first working day after the Commencement Date until the date of issue of the Taking-Over Certificate for the Works."

Section 4 Employer's Requirements – Part I Scope of Works

1.0 GENERAL DESCRIPTION

1.1 Background

Energy Fiji Limited is a statutory body that has its business in generating, transmission, distribution and retail of electricity in the Fiji Islands. The authority's Wailoa Hydro Power Station comprises of 4 x 20MW units which are located in the centre of the main island, Vitilevu. The generation from Wailoa is transmitted via 132kV transmission lines to two regional 132/33kV substations on the Western and Central sides of Viti Levu through to Wailao Substation.

At Hibiscus Park Substation, Energy Fiji Limited would like to seek to procure and install Two(2) x 33kV/11kV, (HV/LV), 20/25MVA, 50Hz three phase ONAN/ONAF Power Transformers. The transformers shall be fitted with a MR Maschinenfabrik Reinhausen Vacuum **VACUTAP on-load diverter switch tap-changer (OLTC)** with 33kV and 11kV cable end box.

The transformers shall conform to the requirements of IEC 60076. The transformers shall also match to the requirements of this specification and if there is difference between this specification and the above-mentioned standard, this specification shall prevail.

1.2 Extent of Work

This tender is suitable for **Transformer manufacturers and their recommended contracting arms** and includes the design, manufacture, supply, inspecting and testing, packing for export, shipment to site, complete erection, site testing, commissioning and training of the Plant described herein.

The Contractor shall be responsible for making good for any defective material design or workmanship for a period of **forty eight (48) months warranty** after taking over. The Contractor is to co-operate with other contractors and EFL operating staff as may be necessary. Works must fully interact with each other in every respect. Additionally, they must properly interact with any other Contractor's work as far as an interfacing is specified or mentioned herein. In case the Contractor finds any parts of these Specifications incomplete, contradictory or defective, he shall be responsible to immediately bring this to the notice of the Employer and make a proposal for the Employer's approval, for making good such incompleteness or defect at the stage of bidding. No additional cost to the Employer shall arise out of such rectification.

The contractor shall provide an experienced installation Engineer from the Manufacturer's own factory to fully supervise all stages of the transformer installation at site from the time of arrival at site through to completion of assembly, oil filling and handing over for commissioning to the Employer. This shall include:

1. Check and remove the impact recorder and provide a copy of the impact recorder readings to the Employer.
2. The Contractor shall be responsible for removing the transformer from the delivery vehicle and lowering it onto the foundation pad.
3. The Contractor shall remove the bolts, lift the transformer back up (either by jacks or by using the delivery crane)
4. The Contractor shall lower the transformer back down on to its final position on the foundation pad and fully install all holding down bolts.
5. Fully assemble the complete transformer.
6. Silicon sealant shall be applied to prevent corrosion between the mating surfaces during installation of the conservator tank onto their main tank support brackets.
7. All damage to the paint work caused during transport to site and during installation shall be fully repaired using the complete four layer paint system.
8. Carry out pre-commissioning and acceptance tests of the complete transformer in accordance with the Contractor's own Instruction Manual and EFL tender requirements.

The new 20/25MVA 33/11kV power transformers for Hibiscus Park Substation shall consist of as specifications outlined below:

Rating	20/25 MVA
High voltage winding	33kV + 4*1.25% kV, - 10*1.25%kV
Low voltage winding	11kV
Frequency	50 Hz
Vector group	Dyn 1
Cooling	ONAN/ ONAF
Tap Changer	MR ON-load Vacuum Divertor Switch
Impedance	~ 12%
HV bushings	Enclosed in cable end box
NV Neutral bushing	Enclosed in cable end box
LV bushings	Enclosed in cable end box

1 x Neutral CT – Class 0.1PX, ratio 300:1 for HV Restricted earth Fault and HV standby earth fault.

The Contractor shall be responsible for delivery to site, installation, site tests and pre-commissioning of the 33/11kV transformers. The contractor shall not be responsible for interfacing of the transformer controls to the existing protection and control wiring. The contractor also shall not be responsible for the 11kV and 33kV connections to existing grid as well as any civil works required for the new transformers foundation.

Note :-

- 1. Contractor will be required to plan and take responsibility of transportation from Port till site.**
- 2. Contractor will be required to offload the transformer from transportation trailer onto the pad using the best suited method to them such as Jack & Skid or using Crawler Cranes.**
- 3. Contractor to ensure their familiarise themselves properly with the site during site visit.**
- 4. Bidder to ensure that the transformer is designed and constructed as compact as possible due to site restrictions.**

1.3 Cable Terminations

The contractor shall submit details of the transformer LV and HV bushings for ordering of termination kits and clamps. All power cabling works and cable terminations as well as connections to the existing network will be supplied and installed by the Employer.

1.4 Training

Training shall be provided for installation, commissioning and maintenance of the relevant equipment at site. The contractor shall therefore submit the training program for each category along with the installation/erection and commissioning program.

A fully documented training shall be prepared and delivered into two sets:

- 1. Pre-Commissioning of Power Transformers** (Objectives highlighted in clause 1.4.1)
- 2. Operation & Maintenance of Power transformers** (One Day session in Kinoya)

1.4.1 Objective of Training Modules

The Training Document shall cover the installation, commissioning and maintenance aspects of the transformers and associated equipment as the trainee personnel will be responsible for commissioning witness by approving the tests & practices from the client's side during the project implementation period and they also will be responsible for maintenance of such equipment after the expiry of defect liability period of the project. The training shall be held at the Employer's office in Fiji and shall be conducted by an authority approved by the Manufacturer, if not the Manufacturer itself.

Training Module No 1: Power Transformers

Basic Contents:

- Erection and installation of power transformers and tap changers
- Testing and commissioning of power transformers and tap changers
- Maintenance practices for the supplied power transformer as recommended by the Manufacturer as well as adjustment of connected devices and replacement of major parts
- Maintenance practices for the on-load tap changer as recommended by the manufacturer
- Installation and removal of online Digital Temperature Monitoring equipment and Automatic Voltage Regulator (AVR).
- Hands on training on test equipment, which are required for maintenance of installed equipment.
- Procedures for oil filling and vacuuming the transformers.
- Pre-commissioning Electrical testing of power transformers
- Applicable standards for design/construction of power transformers
- Test procedures and relevant equipment training.

Training Module No 2: MR Instruments, ZIEHL- ABEGG AG fan control and any other intelligent Instrument and DRMCC.

Basic Contents:

- Introduction to the product
- Operating principle
- Overview of hardware and software
- Input and output connections
- Programming of the product
- Front panel (manual) operations
- Maintenance practices
- Commissioning
- Fault finding

Section 5 Employer's Requirements - Part II Technical Specifications

2.0 GENERAL INFORMATION

2.1 ASSOCIATED PLANT DETAILS

The given particulars elsewhere in this document are those anticipated for plant being provided under other Contracts or already existing and should be used in the preparation of the Bid. They are, however, subject to confirmation and where they are considered to have an effect on the final design of equipment being provided under this Contract, the Contractor is to obtain figures from the Engineer before proceeding with designs.

2.2 ELECTRICAL DESIGN CRITERIA

2.2.1 System Conditions

System Particulars for 132kV, 33kV and 11kV system applicable in Fiji Islands are stated below:

	132kV	33 kV	11 kV
Normal system voltage	132kV	33 kV	11 kV
System Highest voltage	145kV	36 kV	12 kV
Frequency	50 Hz	50 Hz	50 Hz
Earthing of Neutral point	Directly earthed	Earthed through earthing Transformer	Directly earthed with or without resistor
Design Symmetrical fault level	31.5 kA	31.5 kA	31.5 kA

2.2.2 Service Conditions

The Service Conditions applicable in Fiji Islands, at the location of substation site are given below:

	Value	Unit
Altitude of site above sea level not exceeding	300	M
Maximum ambient air temperature	35.6	°C
Minimum ambient air temperature	22.0	°C
Average ambient air temperature over 24 hours	28.5	°C
Average yearly temperature	29.5	°C
Relative humidity (24 Hours)	95	%
Average annual rainfall	202	Mm
Maximum recorded rainfall for 24 hours	390	Mm
Maximum Wind Speed	70 m/sec	
Average isokeraunic level	175	

Note: Fiji is situated in a region where cyclones are experienced frequently. All plant and equipment shall be designed and constructed to withstand these extreme conditions.

All plant and equipment shall be rust proof, vermin proof and weather proof and designed to be suitable for a damp, tropical climate, which may be experienced simultaneously.

2.2.3 Power supply for electrical operation

1.0 Control /alarm /emergency	DC Voltage	110 V
2.0 Supply voltage of auxiliary equipment	AC Voltage	415/240V
3.0 Supply voltage for auxiliary equipment	DC Voltage	110V

2.2.4 Radio Interference and Noise Level

The transformer shall be designed with particular attention to the suppression of the harmonic currents, especially the third and fifth, so as to minimize interference with communications circuits. Transformer noise level when energized at normal voltage and frequency with fans running shall be as per IEC 60076-10.

2.2.5 Minimum Substation Clearances

The transformer and its connections shall have electrical clearances as per IEC 60071 part 2 as listed in the following table: -

Highest system voltages between phases	145kV	36 kV	12 kV
Minimum clearance between live metal and earth and between live metal to neutral bushing	1300 mm	320 mm	120 mm
Minimum clearance between live metal of different phases and between high and low voltage windings	1300 mm	370 mm	120 mm

2.2.6 Pollution levels of Insulators and Bushings

For substations with Heavy pollution level as per table 1 of IEC 60815,

Phase to ground: **53.7mm/kV (at max operating voltage of 33kV)**

2.2.7 Insulation Co-ordination

The design of plant and equipment shall be such that insulation co-ordination is provided not only between different items of plant such as transmission line, surge arrestors, transformers, circuit breakers, but also between different components of items within a particular item of equipment.

2.2.8 Inter-Changeability

Corresponding items or parts shall be interchangeable as far as possible.

2.2.9 Maintainability

All plant and equipment supplied under this contract shall be maintainable. The contractor in adequate number of copies shall provide all necessary tools and equipment and operations and maintenance manuals required for this purpose. All special tools shall be supplied by the Contractor in 2 sets per transformer.

2.2.10 Ventilation

Junction Box, cubicles and similar enclosed compartments shall be adequately ventilated to restrict condensation. All contactors, relay coils, etc. shall be suitably protected against corrosion and fully tropicalized.

2.2.11 Risk of Fire

All apparatus, connections and cabling shall be designed and arranged to minimize the risk of fire and any damage, which might be caused in the event of fire.

2.3 QUALITY OF MATERIALS AND WORKMANSHIP

All materials used under this contract shall be new and of the quality and highest class most suitable for working under the conditions specified and shall withstand the variations of temperature, atmospheric conditions arising under working conditions without distortion or deterioration or the setting up of undue stresses in any part and also without affecting the strength and suitability of the various parts of the work which they have to perform.

All work shall be carried out and completed in a neat and professional manner to the approval of the Employer's Representative.

2.4 STANDARDS

IEC Standards are to be adopted in general. British, IEEE or Australian standards too may be applied wherever necessary. Any other national or international standard may be used if such standards are not less exacting than corresponding IEC Standard. In all instances a copy of the relevant standard adopted should be forwarded to the Engineer.

All works shall be carried out in accordance with the laws of Fiji and associated Acts and Regulations. These include:

The Electricity Act (Chapter 180) – 2017
Health and Safety at Work Act – 1996
Environment Management Act

In order to achieve Regulatory compliance under the Fiji Electricity Act, the Works shall comply with the Electricity Regulations and AS/NZS 3000:2018 "Wiring Rules".

2.5 DETAILED DESIGN OF PLANT AND EQUIPMENT

The contractor in accordance with acceptable standards and codes of practice shall carry out the detailed design of plant and equipment including plant layout, protection, control, supervisory interface equipment, earthing, civil works designs requirement etc.

Notwithstanding the specifications, technical schedules or plant requirements specified by the tender document, the successful contractor shall be fully responsible for ensuring that the design, manufacture or construction of all items of plant and equipment under this contract to be fully functional, compatible with each other technically and otherwise, complying with IEC and/or other relevant standards, and other safety regulations applicable, and to have the installation complete in all respects including finishing, painting, labelling etc.

The successful contractor shall from the commencement of his contract submit to the Employer's Representative, his conceptual design, detailed designs, technical submissions, design, manufacture and construction drawings, etc. for approval at each stage until the completion of the project.

The Employer's Representative will ensure that any revisions required, or in the absence of any such revisions the approval for such drawings technical submissions, designs or proposals shall be notified to the contractor within a reasonable time period.

2.6 PLANT AND EQUIPMENT TO BE SUPPLIED

All items of plant and equipment supplied under this contract shall be of proven design, manufacture and construction, and shall have been in commercial operation for at least **thirty (35) years**. Tenderer should furnish a list of past orders, indicating the type of equipment, location, country etc. in support of this. Type test certificates or other certificates from independent international organizations may also be furnished.

The Contractor shall guarantee the availability of spare parts for all items of plant and equipment for a period of at least 15 years.

2.7 INSPECTION AND TESTING

Type test certificates shall be furnished for all items of plant and equipment with the tender. The Contractor at his cost shall carry out all routine tests as per relevant IEC or other standards.

EFL will require two (2) of its representative to finalise the design with the factory Engineers at the factory offered by the successful tenderer, before approval for construction.

EFL will also require two (2) of its representative to inspect and carry out Factory Acceptance test the plant/equipment offered by the successful tenderer, before shipment, under this contract and to witness.

ALL of the type tests (if type test reports of the particular model are not provided, then they shall be carried out for the plant manufactured and supplied) including routine tests and test specified in the specification.

The associated cost, including return airfare including domestic, accommodation, meals, and transportation from the hotel to the factory test site and airports shall be included in the tender price in the appropriate section.

All commissioning tests shall be carried out in accordance with the relevant IEC or other standards and tender specification. All tools and equipment and instruments for carrying out such tests shall be made available by the Contractor to Employer. The contractor shall provide the employer with a list of tools, equipment and test equipment required for commissioning the transformers.

The preparation of a list of pre-commissioning and commissioning tests for each item of plant and equipment will be agreed upon with the Employer's Representative at a later stage of the project. The pre-commissioning test and commissioning tests shall be carried out by the Contractor and the Employer's representative. Results of the pre-commissioning tests shall be forwarded to the Employer for approval prior to commissioning of the transformers. All costs of carrying out the pre-commissioning and commissioning tests shall be borne by the Contractor.

The Contractor shall provide all facilities for such tests or inspections to be carried out by the EFL's representatives.

The associated cost of return air travel, local travel and transportation to and from the factory and airport, meals, accommodation, phone charges and internet shall be paid by the contractor as part of the submission and shall be similar to the standard United Nations requirements for all overseas travels.

2.8 TRAINING OF EFL PERSONNEL

The Employer requires its personnel (engineers and technicians) to be attached to be trained on installation, operation, maintenance of primary and secondary equipment to be supplied under this contract.

2.9 TOOLS AND EQUIPMENT

The tenderer shall forward a list of tools and equipment required for operation and maintenance of the installation and include the cost of supplying such tools and equipment in the price Schedules.

2.10 SPARES

The tenderer shall forward a list of manufacturer's mandatory operational spare parts required for operation and maintenance of the plant and equipment supplied under this contract for a period of 15 years. The cost of supply of these spare parts shall form part of the contract. The tenderer shall also forward a list of optional spare parts which shall not form part of the contract but should be shown in a separate price schedule.

The successful contractor shall ensure the availability of spare parts for operation and maintenance of all the items of equipment for a period of at least 15 years.

2.11 TECHNICAL LITERATURE - OPERATIONS AND MAINTENANCE MANUALS

Tenderers shall furnish all technical literature, including catalogues, test certificates etc. in support of plant and equipment offered by him with the tender. The successful tenderer is to interface existing and new equipment drawings and a set of original drawings.

Successful contractor shall forward **four (4) bonded hard copies** of all operations and maintenance manuals, spare parts catalogues, detailed schematic and wiring diagrams and all other documents required for satisfactory operation and maintenance of the plant. The originals of the drawings in **AutoCAD format** (.DWG 2020 or above version) are required to be handed over. As built drawings are required to be furnished in **4 copies** before the works are taken over as per Clause 5.6 & 5.7 of FIDIC Document (Conditions of Contract for Design – Build And Turnkey) edition 1.

During the design and manufacture stage the contractor shall submit all design calculations, design drawings, technical submissions at each stage of design or manufacture for the approval of the Employer's Representative.

The manuals shall include the following sections:

2.11.1 Plant Specification and Description

The Plant Specification and Description Section shall include the specification and description of each plant item and system.

2.11.2 Installation and Commissioning

The Installation and Commissioning Section shall include step-by-step procedures for the unloading, unpacking, transport, handling, assembly, erection, adjustment, alignment, preparation for service and testing of the plant.

2.11.3 Operation

The Operation Section shall describe in detail the procedures for the preparation into service, setting, adjusting, checking before and during operation, routine testing and operating of the plant to be supplied. It shall provide complete information on operating limitations, allowable rates of temperature change, allowable temperature differentials and any other information required by operating staff to ensure the safe and efficient operation of the plant.

2.12 Maintenance

The Maintenance Section shall contain sufficient detail to enable maintenance personnel to maintain the plant in good working condition and overhaul the plant from time to time. It shall describe and include pictorial representation of step-by-step procedures for dismantling, reassembly, alignment, replacement and adjustment of all components of the plant.

This Section shall also include standards of workmanship, tolerances, air gaps, electrical resistance values, limits of wear, periodic adjustments, material specifications including special procedures (eg, heat treatment), weights of large items, details and uses of special tools, test equipment, jigs, gauges and tightening torque values for bolts.

The Tenderer shall set down recommendations for preventive or condition based maintenance, including frequency of inspection and guidance in locating and rectifying faults and condition monitoring or diagnostic testing, which may be performed on a regular basis.

Similarly lubrication routines shall be specified including locations, recommended frequency and recommended type of lubricants.

2.13 TYPE TEST CERTIFICATES

Copies of Type Test certificates for all plant and equipment shall be furnished as evidence in support of compliance with the specification.

The Contractor shall furnish copies of certificates of all routine tests, inspection tests and any other type tests, which would have to be performed at a later stage.

2.14 SITE CONDITIONS

The tenderer is required to ascertain for himself the Site Conditions, including limitations of space, access road, geographical, climatic or other considerations. The tenderer shall satisfy himself of the suitability of the sites for the erection of the plant and equipment to be supplied.

2.15 PACKING

Equipment shall be carefully packed for transport and shipment in such a manner that it is protected from all dust and climatic conditions during loading, transport, unloading and subsequent storage in the open. Equipment shall be suitably packed and protected against vibration, movement and shock which may occur during loading and transport. Particular care in packing shall be taken when the apparatus is transported by ship and road.

Before dispatch from the factory the transformer shall be equipped with **electronic impact recorders** with GPS to monitor the impacts the transformer is subjected to while being transported from the factory to the site. The impact recorders shall not be dismantled until the transformer has been delivered to site and final reading has been taken. The electronic impact recorders should have capability of recording shock and vibration history with date and time stamping, together with GPS coordinates and have provision for extraction of the logs so that the data can be analysed on either vendor's software, or on a spread sheet format. The impact recorder's battery should have enough capacity to power up the device for a minimum of 3 months. Upon completion of the project, the impact recorders will be handed over to EFL.

Instruments and fragile items shall be packed separately. All items, which include delicate equipment, shall be sealed in polythene sheeting and silica gel desiccant or vapour corrosion preventive shall be inserted within the polythene packing. Straw shall not be used as packing material.

2.16 PROGRAMME AND PROGRESS OF WORK

2.16.1 Programme

Within 14 days of acceptance of the Tender, the Contractor shall provide the Employer's Representative with Programme of work covering design, manufacture, delivery and erection.

The programme shall separately detail each item of equipment that is to be transported and delivered separately.

3.0 SECONDARY WIRING AND ANCILLARY ELECTRICAL APPARATUS

3.1 SECONDARY WIRING

Secondary wires shall either be colour-coded or the terminals uniquely identified in compliance with AS/NZS 3000.

If wires are numbered, they shall be fitted with 'Critchley Type O' ferrules (or their equivalent). Generally, the number identifying a particular wire shall change at the point of interconnection. If, however, the number is not to be changed, then this fact shall be clearly indicated on the ferrules at the end of each wire. No wires may be teed or jointed between terminal points.

All metallic cases of instruments, control switches, relays, etc., mounted on control panels or in cubicles, (Aluminium, 316 marine Grade stainless steel or otherwise) shall be connected by means of green or green with yellow stripes PVC-insulated copper conductors of at least 2.5 mm² section to the nearest earth bar.

Control and indication cables mounted on the surface of transformers, for example between the Buchholz relay and the marshalling box, shall be suitable for continuous operation at sheath temperatures up to and including 105°C. They shall, in addition, be protected against mechanical damage and ultraviolet radiation using flexible stainless steel wrap. Multi-core cables shall be terminated with weatherproof glands to BS 6121. Armoured cables shall be used for secondary wiring control cables at all times. All control panel wiring, secondary control wiring in motor starters, control gear and the like shall be carried out in a neat and systematic manner with cable supported clear of the panels and other surfaces at all points to obtain free circulation of air.

In all cases, the sequence of the wiring terminals shall be such that the junction between multi-core and terminals is affected without crossover. Except where terminals are approved by the Employer's Representative for use with bare conductors, claw washers or crimped connectors of approved type shall be used to terminate all small wiring. Insulating bushes shall be provided where necessary to prevent the chafing of wiring.

All panel wiring shall comply with the requirements of BS.6231, Type A or B, as appropriate. Conductors shall be copper and have a minimum cross section equivalent to 50/0.25 mm (2.5 sq. mm), 7/0.67 mm (2.5sq. mm) or 1/1.78 mm (2.5 sq. mm) but single stranded conductors should only be employed for rigid connections which are not subject to movement or vibration during shipment, operating or maintenance. Flexible conductor's equivalent to 30/0.25 mm (1.5 sq. mm) or smaller sizes generally shall only be employed with written approval.

For low voltage cabling and wiring, separate cables shall be used for each of the following groups:

1. auxiliary power supply
2. control and check back
3. measuring
4. communication

All control and power cables shall be armoured and all cables except those for auxiliary power supply must be in additional shielded with annealed copper tape. Cables shall conform to IEC 60228, IEC 60228A, IEC 60287, IEC 60811 & IEC 60885.

Wire colours are preferably to comply with British Standard 158:

Colour of wire	Circuit particulars
Red	Red-phase connections in current and voltage transformer circuits only.
Yellow	Yellow-phase connections in current and voltage transformer circuits only.
Blue	Blue- phase connections in current and voltage transformer circuits only.
Green/Yellow	Connections to earth.
Black	AC neutral connections, earthed or unearthed, connected to the secondary circuit of current and voltage transformers. AC connections other than those above and connections in AC/DC circuits.
Brown	DC indication circuits.
Grey	All other DC circuits.

Alternatively, where equipment is wired in accordance with a manufacturer's standard diagram, wiring may be carried out in a single colour except that all connections to earth shall be green. Wiring diagrams must indicate wire colours, numbers designated to all equipment/ instruments and shall be drawn as viewed from the back of the panel.

All wires shall be fitted with numbered ferrules (hand written numbers are not accepted) of approved type at each termination. At points of inter-connection between wiring, where a change of numbering cannot be avoided, double ferrules shall be provided. Such points shall be clearly indicated on the wiring diagram.

All secondary wiring to be performed at Site shall enter the terminal block at one side only. The panel wiring shall terminate in one or more terminal blocks accommodated at the side or bottom of each panel or compartment. Internal wiring between instruments or other devices not using the terminal block shall be permitted within the same compartment only.

The markers on all wiring directly connected to circuit breaker trip coils, tripping switches, etc., shall be of a colour, preferably red, different from that of the remainder and marked "trip". No wires may be teed or jointed between terminal points. Electrical wiring and instruments shall be so located that leakage of oil or water cannot affect them. Bus wiring between control panels, etc., shall be fully insulated and to be completely segregated from the main panel wiring.

Generally, all signal, monitoring and protection circuits as well as shunt trips of circuit breakers shall be fed by DC. All other circuits may be controlled by AC. Also, contactor operating circuits shall be controlled by AC with the contactor solenoids preferably designed for DC with a pre-connected rectifier bridge.

3.2 TERMINAL BOARDS

All terminal boards shall be mounted in accessible positions and, when in enclosed cubicles, are preferably to be inclined towards the door. Spacing of adjacent terminal boards shall be not less than 100mm and bottom of each board shall be more than 200mm above the incoming cable gland plate.

Separate terminations shall be provided on terminal boards for the cores of incoming and outgoing cables including all spare cores. Where cores of multicore cables and internal cubicle wires have crimped ends, not more than two may be connected to any one terminal. When left bare, they shall have individual terminals and where bridging connections are necessary, these shall be incorporated in the terminal boards.

Acceptable types of terminals are:

- (i) Screw or stud type used with crimped ring type termination. Screws and studs shall be not less than of size M6, but stainless steel and bronze down to size M5 may be used, provided that the current carrying capacity is adequate. All studs shall be provided with nuts, washers and lock washers.
- (ii) Inspection clamp type whereby the standard conductor or crimped termination is clamped between plates by a screw having a suitable locking device. Terminal entries shall be shrouded such that not less than three full threads. Screws shall be of plated steel, stainless steel or phosphor bronze and size M3 or M4.

Terminal assemblies shall be to be of the unit form suitable for mounting collectively on a standard assembly rail, secured from the front and giving the required number of ways plus ten percent spare.

LV AC and DC power circuit terminals shall be segregated from other terminals and shall be fitted with non-flammable plastic covers to prevent contact with any live parts. They shall have warning labels, with red lettering, mounted thereon in a conspicuous position.

All connections shall be made at the front of the terminal boards and no live metal shall be exposed at the back.

Insulating barriers shall be provided between each group of power circuit terminals and between the terminal categories, the height and the spacing being such as to give adequate protection to the terminals.

3.3 TERMINALS

All terminals shall be mounted and positioned such that they are readily accessible and circuit numbers can be easily read. Terminations shall comply with ENA TS 50-18 for type "C" blocks and shall be of a type approved by the Employer.

To simplify the identification of circuit numbers, all terminal blocks shall be tilted towards the cubicle door by means of angle brackets. Shorting straps shall be used between terminal blocks to bridge identical conductor terminals. The AC and DC supply connections, and trip connections, shall be shielded at the terminal block by means of transparent insulated covers.

All terminals having a circuit voltage of 240 V or higher shall be shielded with an insulated cover marked with a warning notice "Danger volts".

The minimum thickness of the terminal blocks shall be as follows:

Cable Size mm ²	1.3	1.5	2.5	4	10
Minimum thickness of terminal block mm	6	6.5	6.5	8	10

The cooling control cubicle shall have at least 20% spare terminals fitted and enough extra space on mounting bars for another 20% terminals.

3.4 CONTROL SWITCHES AND PUSHBUTTONS

Control switches and pushbuttons shall comply with BS EN 60947-5-1 OF 1992 or the relevant IEC standards.

3.4.1 General

Control switches for electrically operated circuit-breakers and motor operated disconnectors shall be of pistol grip or other approved discrepancy type and arranged to operate clockwise when closing the circuit-breakers and anti-clockwise when opening them. They shall be designed to prevent accidental operation. When switches of the discrepancy type are approved, operation is to be effected by two independent movements.

Switches for other apparatus shall be operated by shrouded pushbuttons or to have handles of the spade type, the pistol grip type being reserved for circuit-breaker operation only. Control, reversing, selector and test switches shall be mounted, constructed and wired so as to facilitate the maintenance of contacts without the necessity for disconnecting wiring. Where necessary, control switches shall be capable of being locked in appropriate positions but control switches for circuit breakers and for motor operated setting devices shall be of the non-locking type with spring return to the "neutral" position. Such switches shall be controlled by independent springs, the use of contact springs alone for restoring not being acceptable. All pushbuttons shall be of non-retaining type made of non-hygroscopic, materials, non-swelling and fitted to avoid any possibility of sticking. The contacts of all switches and pushbuttons shall be strong and to have a positive wiping action when operated. Control switches for use in direct control schemes shall be rated for substation battery voltage. All control switches shall be provided with labels in addition to clear indication as to the direction of each operation, for example, "open", "close", "raise", "lower", etc.

3.4.2 Electrical Control Locations

Equipment may be electrically controlled from a number of different control points as specified in the appropriate chapters of this Specification. The control positions shall be designated as follows:

Local Control:	Located adjacent to the item of plant to facilitate maintenance, inspection and emergency operation.
Remote Control:	Located at a substation control room where specified items of Plant are monitored and controlled by direct wire connection.
Supervisory Control:	located at a System Control Centre or where principal items of plant at a number of substations are remotely controlled via a SCADA (Supervisory Control and Data Acquisition) system.

3.5 ELECTRICAL MOTORS

All AC motors shall be of the induction type in accordance with BS 5000: PART 99 OF 1973 and BS.5000, Part II, or IEC.60034, IEC 70072 and, unless otherwise specified shall have cooling type ICOL suitable for continuous operation and direct on-line starting. They shall be suitable in all respects for service under the conditions at site. Main conductor and slot insulation shall be non-hygroscopic and in accordance with Class B of BS 2757 or E of IEC 60085. If any motors supplied under this Contract shall be located outdoors, such motors shall be weatherproof and, where necessary, protected from overheating by the sun with a canopy of approved design.

Motors shall be capable of operating continuously at rated output at any frequency between 48 and 51 cycles per second and at any voltage within 6% of nominal value. Motors shall be designed to operate for a period of not less than five minutes at a voltage of 25% below the nominal value and at normal frequency without injurious overheating. If required by the Employer's Representative, the Contractor shall demonstrate that the motors comply with this requirement. Each motor shall be protected by a motor protective unit with adjustable thermal overcurrent and short circuit device. The starting current at full voltage is not to exceed six times the rated full load current. Motor bearings shall be of the rolling type and the cage locating the balls or rollers is not to be in contact with the racers. Vertical shaft motors shall have approved thrust bearings. The ends of motor windings shall be brought out to terminal boxes and the arrangement is such as to permit easy changing over of any two-phase leads. All terminals shall be fitted with an approved sealing chamber, conduit entry or adaptor plate, as required, together with the necessary fittings to suit the type of cable supplied.

Terminal boxes for motor housing shall be weatherproof to IP55 classification in IEC 60529. Terminals shall be of the stud type, of adequate size for the particular duty, marked in accordance with an approved standard. All terminal boxes shall be fitted with an approved sealing chamber, conduit entry or adaptor plate, as required, together with the necessary fittings to suit the type of cable specified. The terminal boxes shall be mounted below the motor to prevent ingress of moisture.

3.6 INDICATING LAMPS AND FITTINGS

Indicating lamps shall be of LED type and fitted into the fascias of switch and instrument cubicles or panels shall be adequately ventilated and shall be of LED type lamps for all indications. Lamps shall be easily removed and replaced from the front of the panel by manual means preferably not requiring the use of extractors. The bezel of metal or other approved material holding the lamp glass shall be of an approved finish so as to permit access to the lamp and lamp glass.

The lamps shall be clear and shall fit into a standard form of lamp holder. The rated lamp voltage should be ten percent in excess of the auxiliary supply voltage, whether AC or DC. Alternatively, low voltage lamps with series resistors will be acceptable.

The lamp glasses shall comply with BS 1376 and BS. 4039 and shall be in standard colours, red, green, blue, white and amber. The colour is to be in the glass and not to be interchangeable. Transparent synthetic materials may be used instead of glass, provided such materials have fast colours and are completely suitable for use in tropical climates. Lamps and relays incorporated in alarm fascia equipment may be arranged for normal operation from the station battery, subject to the approval of the Employer's Representative.

Lamp test facilities shall be provided so that all lamps on one panel can be tested simultaneously by operation of a common push-button. Where alarm fascias are specified, all alarm and monitoring indications (apart from circuit breaker and disconnector position indications) shall be incorporated in the fascia.

3.7 STARTERS AND CONTACTORS

Contactors shall be of robust design and shall comply with IEC 60947. They shall operate without undue noise or vibration. Contactors shall be mounted in ventilated metal cubicles, to IP 65 classification in IEC 60529. The cubicles shall be complete with all locks, cable sealing boxes, busbars, internal wiring, terminal boards and accessories. All bare copper connections shall be taped and all secondary wiring shall be so arranged and protected to prevent damage from arcing.

Electrically held-in starters with integral interlocked isolators shall be used. If needed, auxiliary switches shall be included, for operating "red" and "green" indicating lights on remote instrument panels.

All motor contactors and their associated apparatus shall be designed to operate, without undue heating, for at least 5 minutes, at a voltage of 25% below the nominal value, and at normal frequency. If soft starters are used for the pumps there shall be one soft starter per pump circuit. The soft starter shall use frequency control only and not voltage control.

3.8 JUNCTION, TERMINAL BOXES AND TRANSFORMER CUBICLES

All junction boxes, terminal boxes and marshalling kiosks shall be constructed of 4mm 316 Grade stainless steel or cast iron and shall be IP65 rated. Each shall be provided with an earth stud. All main equipment shall be arranged so that it is accessible from the front of the box or kiosk. All junction boxes, terminal boxes and marshalling kiosks shall be properly labelled as per the wiring diagrams.

Enclosures for electrical apparatus are to afford the following degrees of protection classified in IEC.60529 of 1992 (BS.5490).

- a) The cubicle shall be supplied mounted on the transformer.
- b) It shall be made of stainless steel at least 4 mm thick to grade AISI stainless steel type 316 fully welded on the inside and outside to minimise corrosion.
- c) It shall be fitted with a hinged door with a device that holds the door open at least 120 degrees. It shall be ventilated, have a drain and be weatherproof to IP 65 classification in IEC 60529. The ventilation and drain shall be insect and ant proof. The cubicle shall not be painted, but the outside surfaces shall be buffed.
- d) The cubicle door shall be fitted with a multi-point locking device and handle suitable for padlocking.
- e) All cubicles shall be mechanically isolated from the main tank via anti-vibration mounts.
- f) The cubicle shall be equipped with a gear plate for mounting of all equipment.
- g) The cubicle shall be equipped with terminals of the type detailed in this specification.
- h) The cubicle shall have a cut out, not less than 150 mm x 80 mm at the bottom and covered with a detachable aluminium gland plate not less than 4 mm thick.
- i) All 3-phase relays, contactors, isolating switches and thermal devices shall be marked with appropriate phase colours. Apparatus in which the phase elements are mounted horizontally shall be coloured red, yellow, blue from left to right when viewed from the front of the panel, and when mounted vertically they shall be coloured red, yellow, and blue from top to bottom.
- j) The cubicle shall provide a clear space of at least 300mm high by the width of the cubicle for mounting of equipment.
- k) Outdoor marshalling boxes or kiosks – IP65- also provision of a thermostatically controlled 240 VAC anti-condensation heater and having screened drainage holes.
- l) Auxiliary switches and associated terminals - IP65 -
- m) Outdoor junction boxes - IP65.
- n) Outdoor instruments - IP65
- o) Outdoor motors - IP65.
- p) Indoor control relay and low voltage AC & DC cubicles - IP65 – also thermostatically controlled 240V AC anti-condensation heater and indicating light common to a group of cubicles.

3.9 TRANSFORMER MARSHALLING KIOSKS

The transformer ancillary apparatus shall be mounted in an approved heated and ventilated cubicle, attached to the transformer for the accommodation of the following equipment: -

- Temperature indicators (SEL2414), cooler control “Auto-Hand” selector switch and test links and ammeter for the winding temperature indicator circuits as specified.
- Control and protection equipment for the tap change gear including an isolating switch in the incoming circuit capable of carrying and breaking the full load current of the motor and of being locked in the open position. Provision shall also be made for termination of secondary wiring of current transformers.
- Control and protection equipment for the cooling plant including isolating switches in the incoming circuit each capable of carrying and breaking the full current of all cooling plant motor of one radiator bank and of being locked in the open position.
- The control facilities shall include a cooler selector switch, which can be padlocked in either position to select either cooler for remote control. Local control of the selected cooler shall be provided.
- Terminal boards and gland plates including glands where specified for incoming and outgoing cables as per specification.
- All doors shall be fastened by integral handle with provision for locking each door.
- To prevent internal condensation an approved type of metal clad heater shall be provided, controlled by a watertight rotary switch mounted on the outside of the cubicle and a 5A fuse inside the cubicle.
- A 240V AC single phase and three phase weather proof outlet shall be provided inside the transformer cubicle fitted with Residual Current Protection (RCD). The approved outlet is PDL and HPM brand. The outlet shall be fitted with a permanent label identifying it as being fitted with Residual Current Protection.
- Lamp indications (RED) shall be provided for DC supply and AC supply into the transformer cubicle. The indications shall be wired from the main AC and DC supply wiring into the transformer cubicle.
- All internal wiring shall be so placed as not to obstruct access. All wiring, connections, terminals, boards, and links shall be in accordance with the specification.
- Labels in addition to those specified in General Technical Specification shall be provided on the outside of the kiosks to identify the compartments.
- All three-phase relays, contactors, isolating switches and thermal devices shall be marked with appropriate phase colour. Apparatus in which the phase elements are mounted vertically they shall be coloured red, yellow, and blue from top to bottom.

3.10 GAUGE CUBICLES AND PANELS

Gauge and instruments shall be grouped whenever possible and housed in suitable cubicles. Where circumstances do not justify cubicle accommodation, they may be secured to flat back panels but in such cases the approval of the Employer's Representative is first to be obtained.

Cubicles shall be 316 marine grade stainless steel sheet metal having a minimum thickness of 4 mm. The construction shall employ folding techniques with the use of standard rolled sections or other reinforcement where necessary. The stiffness shall be such as to prevent mal-operation of relays or other apparatus by impact. The front of the panel shall have a smooth well-finished surface.

3.11 ANTI-CONDENSATION HEATERS

All major items of electrical equipment susceptible to suffer from internal condensation from atmospheric or load variations shall be fitted with heating devices, suitable for electrical operation at 240VAC 50 Hz single phase of sufficient capacity to prevent condensation. The electrical apparatus shall be designed not to exceed the maximum permitted rise in temperature if the heaters are energised while the apparatus is in operation. The supply to each heater shall have a fuse and an enclosed switch. The switch shall be arranged to switch the phase conductor only. There shall be no exposed live terminals. Thermostats shall not be fitted.

3.12 INTERIOR LIGHTS

Each cubicle shall have a 13W LED, 240 VAC miniature fluorescent light fitting mounted horizontally or a heat resistant bayonet cap button holder complying with BS EN 61184 for a 240 VAC, 60 W lamp. The light shall be mounted at the top of the cubicle and controlled by a door-activated switch.

3.13 CABLES AND CABLE LADDERS

All 240/415V power cables and control/indication/protection/alarm cables run along the external tank wall shall be securely fastened with stainless 316 Marine Grade steel cable ties on stainless steel cable ladders. The struts fixing the cable ladders to the tank shall also be stainless steel.

Plastic cable ties and fully enclosed plastic or metal cable conduits with intermediate joints shall not be used. The external sheaths of the cables shall not be painted.

3.14 LABELS

Labels shall be provided inside each junction box or kiosk to describe the functions of the various items of equipment. Where the kiosk is divided into compartments each door shall have an external label to identify the compartment.

3.14.1 Labels and Instruction Plates on Instruments

Labels written in the language(s) indicated by the Employer's Representative shall be provided for all instruments, relays, control switches, push buttons, indication lights, breakers, etc. In the case of instruments, switches and control switches where the function is indicated on the dial plate or on the switch escutcheon plate, no label is required. Relays shall be clearly labelled according to their function in the circuits, and to their related equipment, which shall be identical to the designations as used in the circuit manuals. Instruction plates in English language showing the sequence diagrams or cautions for maintenance shall be fitted inside of the front door of the electrical switchboards.

Sample of writings shall be submitted beforehand for approval to the Employer's Representative.

3.14.2 Labels and Identification for Transformer, Conduits, Boxes, etc.

The interior of each piece of equipment shall be clearly marked to show the phases and, for this purpose, either coloured plastic discs screwed to fixed components, or identification by means of plastic sleeving, or tape shall be used.

All conductors shall have their outer covering coloured to the phase colour or, alternatively, appropriately coloured plastic sleeves may be utilized at all cable terminations in fuse-boards, switchgear, etc.

Both Transformers shall have labels on the HV and LV termination box which shall be labelled as T1 and T2. The labels shall be visible from the ground

4.0 PROTECTION, METERING AND CONTROL

4.1 TRANSFORMER PROTECTION

The transformers shall be protected by the usually applied gas- and oil-surge and pressure release devices (PRD) (Qualitrol) detectors, oil- and winding temperature monitoring devices, including the monitoring and protection of the tap changer, conservator tank and/or the cable connection chambers in the similar manner, all as specified below of this Specification.

SEL2414 electronic transformer monitor shall be used for direct winding-temperature monitoring of HV and LW windings using Messko PT100. This equipment can also incorporate monitoring of **top and bottom oil temperatures of main tank, ambient temperature, using MR TRASY2 MT-ST160F; Oil temperature and for winding TRASY2 MT-STW160F2, load tap changer oil temperature, tank pressure, etc.**

The transformer monitoring equipment (eg, buchholz relay, oil level indicators, pressure relay) shall be wired through any intelligent monitoring device for **local and remote indication** for necessary flag indications, tripping and alarm relays through the SEL2533 annunciators, and high quality indication lamps associated with the relevant protection. Provisions shall also be made for such alarm and trip indications to be wired to the control panel located inside the 33kV substation building.


4.1.1 Buchholz Protection

The transformers shall be fitted with Buchholz devices from MR Reinhausen Messko's Germany of type, Msafe with two-element type giving operation under gassing and under surge conditions.

M Safe®

The new Buchholz Relay from Messko

Arguments for long-term cost savings



The Buchholz relay shall be equipped with gas sampling and testing devices to be operated from the ground level at a convenient height. Our preferred is **CEDASPE RG3**. All necessary flag indication, tripping relays and alarm relays associated with this protection shall be supplied and under this Contract. Each transformer shall be fitted with gas and oil-actuated Bucholz relay equipment having alarm contacts, which close on collection of gas or low oil level, and tripping contacts, which close following oil surge conditions. The gas and oil actuated relay shall be connected on the piping connection from the main conservator to the tank. Each gas and oil-actuated relay shall be provided with a test cock to take a flexible pipe connection for checking the operation of the relay. Each relay shall be fitted with a calibrated glass window for indication of gas volume.

To allow gas to be collected at ground level, a small bore pipe shall be connected to the gas release cock of the gas and oil-actuated relay and brought down to a point approximately 1400 mm above ground level, where it shall be terminated by a cock which shall have provision for locking to prevent unauthorised operation.

The design of the relay mounting arrangements, the associated pipe work and the cooling plant shall be such that mal-operation of the buchholz relays will not take place under normal service conditions under all operating temperatures. The pipe work shall be so arranged that all gas arising from the transformer will pass into the gas and oil-actuated relay. The oil circuit through the relay must not form a delivery path in parallel with any circulating oil pipe, or is to be tied into or connected through the pressure relief vent. Sharp bends in the pipe work shall be avoided and not permissible. When a transformer is provided with two conservators the gas and oil-actuated relays shall be arranged as follows: -

- (a) If the two conservators are connected to the transformer by a common oil pipe one relay shall be installed in the common pipe.
- (b) If the two conservators are piped separately to the transformer two relays shall be installed, one in each pipe connection.

The clearance between oil pipe work and live metal is to comply with the specifications as specified. The connection pipe between the conservator tank and the transformer main tank shall be fitted with a gas operated (Buchholz) relay for the protection of the transformer. The connection pipe shall have the same bore as the relay. Buchholz relays shall not operate under any of the following conditions:

- a) Due to the operation of the pumps.
- b) Due to movement of the transformer by earthquakes.
- c) Due to magnetic fields either on energising the transformer or due to the fault currents in conductors creating field intensities in air of up to 0.07 Tesla.

Stop valves shall be provided on both sides of the relay, and as near as possible to the Buchholz relay. The stop valves shall have clearly marked 'open' and 'closed' positions **visible from ground level**. A means of securing the valves in the 'open' position is required, preferably without needing to use key locking devices.

Transformer construction shall allow any rising gas to readily reach the Buchholz relay(s) and not be trapped. If necessary, piping shall be provided to lead away any gas that could be trapped in any part of the main tank. The relay shall be provided with both "Trip" and "Alarm" contacts wired to the cooling control cubicle.

Piping and petcocks shall be provided so that gas and air can be released from the Buchholz relay and air can be injected into the top and bottom of the relay (this tests the operation of the contacts). Petcock movement shall be prevented by securing them to the transformer tank. The gas bleed pipe shall be fitted with a readily accessible gas trap suitable for taking gas samples from a height of 1.4 m above ground level. The required pressure of the air injected through the bottom connection to test the trip contact shall not exceed 2,000 mbar. The piping shall be 10 mm diameter and all threads shall comply with ISO 7/1:1994.

4.1.2 Temperature Indicating Devices and Alarms

The transformers shall be provided with a **SEL2414 model or similar model of SEL brand** for oil and winding temperature meter with alarm and tripping function.

4.1.3 Oil Level Indicators

Oil level indicators shall be supplied for both main tank and OLTC conservator tanks. The oil level indication shall be clearly visible to an observer on the ground.

Each indicator shall have contacts for high and low oil level alarms. The contacts shall be wired to the cooling control cubicle.

Dial type magnetic oil level indicators shall be used, not a prismatic type. The indicated range of oil levels shall correspond to average oil temperatures of -20°C to 140°C.

The oil level at 20°C, 40°C, 60°C, 80°C, and 100°C shall be marked on the gauge. A separate plate giving temperature/graduation equivalence is not acceptable.

Employer's preference is MESSKO of Germany

TRASY2 MT-ST160F; Oil temperature



COMPACT MT-ST160W/WRM

The compact series consists of two types of temperature measuring instruments which are compact and complete in themselves, providing:

- + temperature measurement
- + display of the measured values
- + alarm messages
- + remote indication of the measured values



4.1.4 For the Main Conservator TANK

MTO SERIES

MTO-ST(F)160(G) oil level indicators are measuring devices with and without switching contacts. They are ideally suited to measuring the liquid level in the conservators of transformers. The level indicator consists of a sensor and a display unit, which are linked separately. The sensor unit consists of a sealed flange plate and is installed directly in the wall of the conservator. The float arm transfers the rise and fall of the float to the spindle. This spindle is connected via a magnetic clutch to a pointer spindle in the display unit.



[Download](#)

The movement of the float is normally radial to the casing. The "G" version is recommended for installation in narrow or flat conservators in which only limited movement is possible; in this case the float movement is axial to the casing and the display can be scaled at a ratio of 1:1, 1:2, 1:3 or 1:4.

These level indicators can be supplied with either one or two microswitches:

- + MTO-ST160(G): Adjustable limit switch (max. 2 changeover contacts)
- + MTO-STF160(G): Fixed limit switch (max. 3 changeover contacts)

4.1.5 Automatic Timer Fan Control

The fan control circuit shall be fitted with an automatic timer to turn on all the cooling fans for any selectable 30 minute time period during the day. The automatic timer shall be fitted with fail safe protection such that failure of the automatic timer does not prevent operation of the fans by the WTI or cause the fans to run continuously.

4.1.6 Dissolve Gas Sampling Equipment

A minimum of one valve at the bottom tank shall be provided on the main tank for future connection of dissolved gas sampling equipment. The height of the valves shall be 1m above ground. The pipes shall be 316 stainless steel grade and provision to take oil samples out on yearly basis. Valve shall be fitted with stainless steel flanges each with quick connect coupler adaptor.

4.1.7 Pressure Relief Device

An approved pressure relief device of Qualitrol brand or MESSKO MPreC, which shall be independent of electrical power, of sufficient size, shall be provided for the rapid release of any pressure that may be generated in the tank and designed to operate at a static pressure lower than the hydraulic test pressure called for in Schedule of Works Tests. In the event that the device is a spring operated valve type, it shall be provided with at least two normally open signalling contacts to trip the transformer and remote alarm/indication purposes.

The relief device is to be mounted on the main walls above the level of the winding and is to be provided with a skirt to project at least 25 mm into the tank to prevent gas accumulation. The device shall be capable of maintaining oil tightness of the transformer under all conditions of normal service.

A cover or other arrangement shall be provided so that any oil discharges are in a downward direction avoiding adjacent or ancillary equipment. The design of the device shall be such that gas cannot accumulate around it inside the tank, nor moisture can enter it from the outside of the tank. This cover must not impair the function of the device and the openings shall be protected by suitable sized mesh to prevent birds nesting.

A resettable indicator **visible to a person on the ground** shall be provided to show that the relief valve has operated. Overpressure device shall not generate invalid trip signals by tank vibrations and by the magnetic fields generated during normal operation and during through-faults. Each device shall:

1. Maintain its oil tightness under a static oil pressure equal to the static operating head of oil plus 50kPa;
2. Attain its full opening in not more than 2.5 ms when subjected to an internal pressure impulse equal to the static operating head of oil plus 50kPa;
3. Be capable of withstanding full internal vacuum at sea level;
4. Be fitted with a visual operation indicator plainly visible and accessible from ground level, and arranged for manual resetting;

5.0 **TRANSFORMER**

5.1 **TYPE OF TRANSFORMER AND OPERATING CONDITIONS**

5.1.1 **General**

All transformers shall be oil immersed and suitable for outdoor installation and shall comply with IEC 60076, IEC 60137, 60214 & 60289. Only transformers from manufactures with a **minimum of thirty years** successful experience on manufacturing transformers with comparable size will be accepted. Each item or function which is obviously necessary for the proper completion of the work, it's full functionality and safety as well as complete interfacing with other work, whether especially specified in the tender documents or not, shall be included in the tender price.

5.1.2 **Prohibited Materials**

Asbestos materials, materials containing PCB's, or other materials prohibited by the Fiji Statutory Regulations shall not be used in the construction of the transformer. A certificate to this effect shall be included in the transformer manual.

5.1.3 **Design Review**

The Employer may arrange for an independent confidential design verification review to be carried out. The Manufacturer shall provide all the requested design and construction data required to enable the Employer to adequately evaluate the transformer to be supplied.

5.1.4 **Component Approvals**

- a) The components and fittings associated with transformers covered in this specification shall be nominated in the Tender Schedules and is subject to approval of the Employer.
- b) Samples, technical literature, drawings, test reports and lists of the names of the principal users, with experience gained, shall be supplied.
- c) The manufacturer shall submit components to the Employer for approval only after these have been initially approved by the manufacturer for use on the transformer. The use of standardised and approved components already in use on the Employer's existing power transformers is preferred to minimize the variety of spares required.
- d) All contactors, switches, circuit-breakers, relays and contacts incorporated in the electrical control of tap-changers shall be subject to the Employer's approval.

5.2 **RATING AND OPERATION**

5.2.1 **Transformer Capacity**

5.2.2 **Rating**

The transformer shall be rated for continuous operation as follows under the service conditions.

1. IEC 60076 33/11 kV Rating
2. The HV/LV, 33/11 kV continuous rating shall be 25 MVA on all tapings with ONAN cooling to the temperature rise limits of IEC 60076 Part 2.
3. IEC 60076 Rating Maximum Hot Spot Temperature
The maximum allowable winding hot spot temperature shall not exceed 68°C at an ambient temperature of 35°C, using a winding temperature hot spot gradient factor as determined by magnetic leakage field plots at the IEC 60076 Part 2 continuous ONAN rating on all tapings.
IEC 60076 33 kV/11kV Minimum ONAN Rating

The HV/LV, 33kV/11 kV minimum continuous rating shall be 20/25 MVA on all tapping's with ONAN cooling to the temperature rise limits of IEC 60076 Part 2.

5.2.3 Overload 33kV/11 kV Rating

The HV/LV, 33kV/11 kV continuous long time emergency cyclic load rating shall be:

25 MVA on all tapings with ONAF cooling with a maximum winding hot spot temperature of 115°C at an ambient temperature of 35°C using a winding temperature hot spot gradient factor as determined by magnetic leakage field plots.

(i) Short-Time Emergency Overload Capacity

The transformer and all its components shall comply with the requirements of IEC 60076-7 except that the maximum allowable temperature limits under these conditions for an ambient temperature of 25°C, using a winding temperature hot spot gradient factor as determined by magnetic leakage field plots, shall not exceed the figures given in the following table:

Hot-spot temperature and metallic parts in contact with insulating material	115°C
Top Oil temperature	100°C
Metallic parts in contact with oil	125°C

The transformer 33kV HV & 11 kV LV ratings shall be capable of operating at a stable operating temperature at the rated ONAF continuous load to IEC 60076 Part 2 followed by an increase to a short-time emergency overload rating of 1.5 times this rated continuous load for ½ hour duration. To meet the above requirements:

- a) All current carrying components (except the windings and tap-changer) shall be rated for 1.5 times the rated continuous current.
- b) All the internal connections to the HV and LV bushings and all the metal parts in contact with the oil including the tank wall, shall not exceed the above temperature limits.

5.2.4 Voltage Ratios and Tapings

The nominal voltage ratio shall be 33/11 kV. On-load tap-changer tapings on the HV 33kV winding shall be provided as follows:

33 kV + 4 X 1.25% up, down from 33 kV in 10 x 1.25% steps. The tapings shall be numbered from the highest ratio no. 1 to the lowest ratio no. 15.

The principal voltage ratio shall be 33 kV at tap position no. 5

The category of voltage variation shall be constant flux voltage variation in accordance with clause 3 of IEC 60076-1

5.2.5 Impedance

The HV - LV impedance shall be ~12% at principal voltage ratio 33 kV at tap position no.5 at reference temperature 75° C on a 25 MVA base.

The value of impedance measured on principal and extreme tapings shall be as stated in the Schedule and minimum and maximum values where stated in the Employer's Requirements shall not be subject to tolerance. Where transformers are required to operate in parallel with existing units the appropriate data will be stated in the Employer's Requirements.

5.2.6 Zero Sequence Impedances

The Contractor shall nominate the zero sequence impedances in Technical Data Schedule of this specification.

5.3 TRANSFORMER CORE

The construction method shall be of the core type and shall be from Japan JEF or equivalent. Core laminations shall be of the highest quality non-ageing grain-orientated steel or better. The nominal flux density at any part of

the core shall not exceed 1.5Tesla at rated voltage and frequency at principal tap, and there shall be no risk of saturation under the above and all other operating conditions.

All parts of the core and fixings shall withstand any shock to which they may be subjected during lifting, transport, installation and service (including switching and external short circuits) and earthquakes. Permanent lifting eyes and other suitable means shall be provided to enable the core and windings to be lifted.

The core and frames shall be single-point earthed as follows:

All internal metal parts of the transformer, with the exception of the individual core laminations, core bolts and associated individual clamping plates shall be bonded and earthed.

A single connection from the core and another single connection from the frame shall be brought out separately via cables to two 5kV bushing terminals, complete with shorting links, mounted in an external box located next to a hand hole cover in the tank top. The bushings shall be labelled "C" for the core and "F" for the frames in a permanent manner. To allow for testing of the insulation of the core and frame, the connections shall be earthed via a removable bolted link to an earthed stud on the tank. The cables, bushings and links shall be rated for the maximum circulating current in the event the core of the frame becomes inadvertently grounded.

In the event that the core or frame becomes inadvertently grounded, the single-point earth cables, bushings and links shall be rated for a circulating current rating equivalent in number of Amperes to three times the value of the three phase transformer MVA power rating to IEC 60076.

The bottom frame supporting the core shall have two metal feet on each longitudinal axis side extending to the full width of the tank to stabilise the complete core and winding assembly when de-tanked and resting unsupported on the ground. The complete core and winding assembly shall not be attached to the transformer tank cover. The insulation within the core (cooling ducts), between the core and end frames and between the core and support feet shall be Class H insulation. Cellulose insulation shall not be used.

A detailed drawings and design of the earthing shall be part of the Transformer manual.

5.4 WINDING

All windings shall have **copper** conductors from SAM DONG KOREA or better alternative. Transformer 33kV delta connected windings may have graded insulation as defined in IEC 60076-3 and 11 kV winding shall have uniform insulation as defined in IEC 60076. All neutral points shall be insulated to withstand an applied voltage test specified in the Employer's Requirements. The windings shall also be thoroughly seasoned during manufacture by the application of axial pressure at a high temperature for such length of time as will ensure that further shrinkage is unlikely to occur in service. The windings and leads of all transformers shall be braced to withstand the shocks, which may occur through rough handling and vibration during transport, switching and other transient service conditions including external short circuit. If the winding is built up of sections or of disc coils splitted by spacers, the clamping arrangements shall ensure that equal pressures are applied to all columns of spacers.

Regardless of the mode of cooling specified in accordance with IEC 60076-2 Clause 3, the transformer windings shall have fully directed oil flow consisting of the following:

1. Oil from the radiators directed into the bottom of each winding.
2. Directed oil flow within each winding by means of zig zag cooling directed flow washers. Klakbands shall not be used.
3. The transformer winding conductors and conductor connections shall be constructed from high conductivity copper and shall be burr free and profiled.
4. All electrical connections within windings shall be brazed or welded to withstand shocks of the type that might occur through handling, vibration during transport, switching, earthquakes and other transient fault service conditions. Soft soldered connections are not acceptable.
5. All connections from windings shall be mechanically sound, supported and fastened to prevent movement and damage under transport, site erection, and normal and abnormal operating conditions.

6. If a brazed crimp or crimp joint is used to connect the winding lead-out and the lead connection, the Contractor shall state the type of joint to be used and the method of stress relieving; both of which shall be subject to the approval of the Employer.
7. All cylinders/wraps shall be made of pre-compressed transformer board. Machined wrapped paper cylinders/wraps are not acceptable.
8. Scarfed overlap shall be used for forming cylinders and angle collars. Overlaps shall be formed on duct strips
9. Only moulded angle collars/caps shall be used from high density pre-compressed boards with contoured edges. Pedalled collars/caps are not acceptable.
10. Metal backed paper shall not be used in the stress relieving of winding to lead connections.
11. Metal backed paper shall not be used in the manufacture of the stress shields without the express approval of the Employer.
12. Enamel covered wires shall only be used when approved by the Employer and shall also meet the following additional criteria:
 - (a) The particular enamel and method of use has a proven history.
 - (b) For continuously transposed cable the radial thickness of the enamel shall be 0.1 mm.
 - (c) For helical windings that are transposed by hand, the cross-over/transposition shall be mechanically and electrically protected.
13. There shall not be any electrical out of balance of turns between the phase windings.
14. Duct strips shall be of a solid construction one piece and have contoured edges– duct strips made of multiple strips tied together are not acceptable. All duct strips and spacers shall have contoured edges.
15. All paper covered conductors shall use thermally upgraded paper.
16. Continuously transposed cable shall:
17. Be epoxy bonded to withstand free buckling short-circuit forces unless it can be proved otherwise in accordance with Clause 6.2.
18. Utilise a spacer between strand stacks to keep the stacks separate.
19. All crossovers and transpositions are to be under bent so that after compression, the crossover/transposition does not protrude into the adjacent radial duct.
20. All crossovers, transpositions and winding lead outs are to be effected by a pre-set bender to ensure that they are correctly bent and are uniformly identical.
21. Winding conductors shall use butt lapped insulation papers for all layers except for the final outer layer which shall be overlapped.
22. All internal winding and bushing lead support structures shall use fibreglass nuts and bolts. Wooden or cellulose based nuts and bolts shall not be used. The winding and lead support structures shall not rely on the shear strength of the fibreglass nuts and bolts.
23. All winding coils shall be sized for correct height in a vapour phase oven.
24. Paperless LV windings are not acceptable.
25. Winding Assemblies shall be prepared as follows:
 - a. The individual cylinders/wraps and their associated duct strips shall be pre-dried to minimize shrinkage.
 - b. Each winding shall be clamped under the design load (kN) as determined from the short circuit loadings and the design pressures as used in compressing the complete active part.
 - c. A single ring shall be used to compress all windings for each limb
 - d. Any blocking required shall be distributed such that the HV, FR and LV windings retain their design force balance
 - e. Each winding shall be clamped complete with the entire end blocking in place.

5.5 COOLING

The types of cooling shall be as stated in the Employer's Requirements and the letters relating to the method of oil circulating and cooling used in this Specification and Employer's Requirements shall be in accordance with IEC 60076. Where a combination of two methods of cooling is applied to one transformer as for ONAN/ONAF units, the transformer shall be capable of operating under the ONAN condition as stated in the Employer's Requirements, after which the cooling equipment is to come into operation and the Transformer will operate as an ONAF unit.

Transformers shall be fitted with tank mounted radiators. They shall be capable of remaining at the operation of full load for 60 minutes in the event of failure of blowers associated with both coolers without the calculated winding

hot spot temperature exceeding 130°C. Failure of one fan in each group of blowers shall not reduce the continuous maximum rating of the transformer.

5.6 CONTINUOUS MAXIMUM RATING

Transformers shall have the continuous maximum rating as stated in the Employer's Requirements and shall comply with the requirements as regards temperature rise and overloads on all tapings irrespective of the direction of power flow and with the voltage of the lower voltage winding at the normal voltage stated in the Employer's Requirements. To allow for high atmospheric temperatures, the allowable temperature rise shall be reduced as stated in this Specification. The overload capability shall be in accordance with IEC 60354.

5.7 ELECTRICAL CONNECTION

Transformer windings shall be connected in accordance with the IEC 60076 group symbol specified in the Employer's Requirements. The neutral point shall be brought out of the tank and earthed outside of the tank. All electrical connections within windings shall be brazed but subject to approval, mechanically crimped joints may be used for round stranded conductors on tapping, bushing or earthing connections and on bundle conductors when design has been proved by the type test and application is subject to rigorous quality control.

5.8 ABILITY TO WITHSTAND SHORT CIRCUIT

5.8.1 General

All transformers shall be capable of withstanding on any tapping and without damage the thermal and dynamic effects of external short circuits under the conditions stated in IEC 60076 Part 5. For at least 3 seconds at rated conditions and after all loading conditions as specified in IEC 60354.

5.8.2 Calculations and Tests

Evidence shall be submitted with the Tender as to the extent to which the manufacturer has proved or is able to prove either by calculation or test the ability of the specified Transformers to withstand thermal and mechanical effects under short circuit. The transformer shall be designed to ensure that leakage flux does not cause overheating in any part of the transformer.

The Tenderer shall submit a **reference list** of at least ten (10) transformers of same or similar design and rating manufactured and supplied by the manufacturer for orders from outside the country of the manufacture. Offered transformer will only be accepted if transformers identical/similar in design have a **minimum of eight years** field experience.

5.8.3 EXTERNAL SHORT-CIRCUIT WITHSTAND

Transformers shall be designed and constructed to withstand, without damage, the thermal and dynamic effects of external short-circuit under the conditions specified in IEC 60076-5. The appropriate value of short-circuit apparent power shall be taken from the following table:

System Highest Voltage (kV)	Short Circuit Apparent Power (MVA)
12	2,000
36	2,500

A current of 3 seconds duration shall be used to calculate the thermal ability to withstand short-circuits. The radial short circuit strength of windings shall be based on the free buckling mode.

The interior parts of transformer shall be designed and constructed to withstand without damage the mechanical forces caused by the following:

- Short-circuit currents as detailed above.
- Transportation impact forces of 1 g or greater.
- Seismic earthquake loadings as detailed in specification.

5.8.4 LOSSES AND EVALUATION OF LOSSES

The Tenderer shall state in the Technical Particulars and Guarantees, guaranteed values for component losses of the total loss which shall be as low as is consistent with transport restrictions, reliability and economic use of materials. Tenders will be assessed on the basis of the least 'Present Worth' of capital cost plus guaranteed losses, being the sum of the installed Tender Price of the transformers plus:

No load losses	-	6000 Fijian Dollars/kW, less than 15kW
Copper losses	-	3000 Fijian Dollars/kW

The acceptance of transformers yielding component losses higher than the guaranteed values shall be governed by either of the following: -

- (A) Component losses in excess of guaranteed values but within the tolerance permitted under IEC 60076 Part 1.
Transformers shall be accepted subject to full compliance with all technical particulars including temperature rises at CMR and subject to the Tenderer accepting deduction from the Contract Price of charges for each kW on part thereof of component losses in excess of the guaranteed values, at the above evaluation rates.
- (B) Component losses in excess of guaranteed values and exceeding the tolerance permitted under IEC 60076 Part 1. The acceptance of transformers shall be entirely at the discretion of the Employer's Representative/Employer and subject to the Tenderer accepting the deduction from the Contract Price of charges for each kW on part thereof of component losses in excess of the guaranteed values, at the above loss evaluation rates.
In the event of transformers, which are, either equal to or below the guaranteed losses values, the Tenderer will not be entitled to any premium in respect of reduction in losses below the guaranteed values.

5.9 Service Conditions

The transformers shall be constructed for directly connected to an overhead transmission circuit and switched into or out of service together with its associated transmission circuit.

The service conditions are:

- The ambient temperature range is -10°C to +50°C.
- 100% humidity, with very rapid temperature fall, can occur.
- The altitude does not exceed 1200m.
- Earthquakes are expected.
- Lightning are expected.
- Atmosphere can be heavily polluted with salt, dust and products from agricultural spraying.

5.10 NOISE

The transformer noise levels shall be measured as a type test and in accordance with IEC 60551. The noise level of the transformers shall be as stated in the Employer's Requirements.

When the bottom plate of the transformer tank will be in direct contact with the surface of the foundation **anti-vibration pads** shall be provided for insertion between the transformer and its foundation. The anti-vibration pads to be made from high quality electrometric rubber specially compounded to resist ageing, oil and water.

5.11 Audible Sound Level

- Measurement and calculation of sound power levels shall comply IEC 60076-10
- The permissible maximum sound pressure level for the transformer operating at 25MVA measured 5 metres from the transformer shall not exceed 60 dB(A) with the transformer energised to 100% voltage on the principal tap and rated frequency with ONAN.
- The permissible maximum sound power level for the transformer operating at maximum rating of 25MVA measured 5 metres from the transformer shall not exceed 60 dB(A) with the transformer energised to 100% voltage on the principal tap and supplied auxiliaries operating (i.e. fans, etc).

5.12 CORONA INCEPTION FIELDS

Under Induced and Impulse test voltage conditions, there shall be at any particular stress point a minimum 35% safety margin between the corona inception field strength and the actual figure determined from the field plots supplied by the Contractor for all oil ducts in both axial and radial dimensions. The corona inception field strength shall be referenced to the published curves A 41-5 (2) and A 41-6 (2) in Weidmann Book Band 1, Volume 1.

5.13 HARMONIC SUPPRESSION

Transformers shall be designed with particular attention to the suppression of harmonic voltages, especially the third, fifth and seventh harmonics and to minimize the detrimental effects resulting there from and as to minimise waveform distortion and any possibility of high frequency disturbances, inductive effects or of circulating current between the neutral points at different transforming stations reaching such a magnitude as to cause interference with telecommunications circuits.

5.14 MAGNETIC CIRCUIT AND WINDINGS

5.14.1 Magnetic Circuit

The design of the magnetic circuit shall be such as to avoid static discharges development of short circuit paths internally or to the earthed clamping structure, and the production of flux components normal to the plane of the laminations. Each lamination shall be insulated with a material stable under the action of pressure and hot oil.

The winding structure and major insulation shall be designed to permit an unobstructed flow of cooling oil through core cooling ducts to ensure efficient core cooling.

The magnetic circuit shall be insulated from all structural parts, and shall be capable of withstanding a test voltage to core bolts and to the frame of 2,500 volts RMS for one minute. In order to allow testing, **the magnetic core shall be earthed to the tank cover at one point only through removable links in an appropriate terminal box, placed in an accessible position on the tank cover.**

The core shall be free from over-fluxing liable to cause damage or mal-operation of the protection equipment when operating under continuous over-voltage operation specified in the schedule.

5.14.2 Flux Density

Core shall be constructed from cold rolled grain oriented steel sheets. Design shall be such that there will be no adverse effects due to core or stray flux heating with the quality of steel employed, and that when operating under the most onerous conditions envisaged in IEC 60076 and IEC 60354, flux density in any part of the magnetic circuit does not exceed 19,000 lines per square centimetre (i.e. **1.5 Tesla**). The maximum flux density in the legs and yokes of the core shall not exceed 1.5 Tesla at rated voltage and frequency during normal operation; that is, with the rated primary voltage applied to the primary terminals at the principal tap and rated frequency. Over-fluxing of the core shall not occur under this condition. The cores, framework, clamping arrangement and general structure of the transformer shall be capable of withstanding any shocks to which they may be subjected during transportation, installation and service. Adequate provisions shall be made to prevent movement of internal parts of the transformer relative to the tank and the method of supporting the core structure in the tank.

5.15 WINDING CONNECTIONS

The HV 33 kV windings shall be connected in delta and the LV 11 kV windings shall be connected in y. The HV/LV connection symbol shall be as follows:

Dyn1

The winding reconnection facilities for the LV winding shall be achieved via removable bolted links under oil inside the main tank. A removable access hatch on the main tank shall be provided to allow the LV winding to be re-connected from Standard to Non Standard operation.

The transformer LV winding connections prior to shipping from the manufacturer's factory shall be confirmed by Employer prior to final factory acceptance testing.

5.16 THERMAL AND MOISTURE MONITORING

Transformers shall be dried by vapour phase and the maximum temperature shall not exceed 130°C. For the transformers and coils subject to air drying and vacuum dry-out, the maximum temperature in air shall be limited to 105°C and under vacuum 110°C.

A roll of 25 mm wide insulating paper, about 100 mm in diameter (the same as the paper used in the windings and leads) shall be attached to and dried out with the windings.

The insulating paper roll shall be fastened in an accessible position on the top yoke near the centre limb and above the windings, to ensure the roll is as close to the hottest spot as possible.

Samples of this roll shall be taken before and after dry-out to measure the change in the Degree of Polymerisation (DP) with minimum acceptable value of 1250.

This roll shall stay in the transformer during the transformer's life and shall be used to monitor insulation moisture content levels during commissioning and during the life of the transformer.

Likewise, samples of the insulation board are required for monitoring insulation moisture content levels during commissioning and during the life of the transformer. Six such samples shall be secured at a readily accessible position near a hand-hole cover within the transformer tank. Each sample shall be approximately 100 mm².

5.17 Internal Earthing

- (i) General - All metal parts of the transformer with the exception of the individual core laminations, core bolts and associated individual clamping plates shall be maintained at same fixed potential.
- (ii) Earthing of Core Clamping Structure - The top main core clamping structure shall be connected to the tank body by a copper strap. The bottom main core clamping structure shall be earthed by one or more of the following methods.
 - (a) by connection through vertically tie rods to the top structure;
 - (b) by direct metal to metal contact with the tank base maintained by the weight of the core and windings;
 - (c) by connection to the top structure of the same side of the core as the main earth connection to the Tank.
- (iii) Earthing of Magnetic Circuits - The magnetic circuit shall be earthed to the clamping structure at one point only through a **removable link** placed in an accessible position just beneath an inspection opening in the tank cover and which, by disconnection, will enable the insulation between the core and clamping plates, etc., to be tested at voltages up to 2.5 kV. The link shall have no detachable components and the connection to the link shall be on the same side of the core and the main earth connection. These requirements are compulsory.

Magnetic circuits having insulated sectional construction shall be provided with a separate link for each individual section. The arrangement of the connections shall be subjected to the plane of the laminations divide the magnetic circuit into two or more electrically separate parts, the ducts and insulating barriers which have a thickness greater than 0.25 mm are to be bridged with tinned copper strips so inserted as to maintain electrical continuity.

- (iv) Earthing of Coil Clamping Rings - Where coil clamping rings are of metal at earth potential, each ring shall be connected to the adjacent core clamping structure on the same side of the Transformer as the main earth connection.
- (iv) Size of Earthing Connections - Main earthing connections shall have a cross-sectional area of not less than 200 sq. mm. but connections inserted between laminations may have cross-sectional areas reduced to 150 sq. mm. when in close thermal contact with the core.

5.18 Earthing Terminals

External earthing terminals shall be provided as follows:

- a) Two earthing terminals located on the transformer tank, each one on opposite sides of the tank wall and located near to ground level for connection to the substation earth grid.
- b) One earthing terminal located on any separate associated radiator bank and located near to ground level.
- c) One earthing terminal for the neutral current transformer mounting bracket. The earthing terminal shall be located near the top of the tank wall, underneath the neutral current transformer mounting bracket.
- d) The external earthing terminals shall be a flat vertical lug, 100 mm x 50 mm, and drilled with two 14 mm diameter holes for M12 bolts, at 45 mm vertical centres. The terminals shall be stainless steel, suitable for use with copper earthing connections, rated for 3s of at least 31.5 kA. The earth terminals shall be located so they are readily accessible from both sides of the foundation pads. Dimension details of the arrangement offered shall be supplied with the tender.
- e) Every part of the equipment intended to be earthed shall be electrically continuous with the earthing terminals without relying upon fortuitous contacts. The earth lug shall be marked with an 'earth' symbol. An adequately rated electrical bond shall be provided across all bolted joints of the tank.

5.19 CABLE END BOX

33kV and 11kV HV/LV cable box shall be air insulated. The box shall have connections for single core, 630 mm² XLPE-insulated, copper wire screened, PVC-sheathed cables per phase.

The 33 kV cable box shall be supplied with one piece gland plates having 6 x 89mm diameter holes (2 per phase) for power cable glands (suitable for CFTS-5). The gland plates shall be marine grade 8 mm thick aluminium.

The 11 kV cable box shall be supplied with one piece gland plates having 9 x 89mm diameter holes (3 per phase) for power cable glands (suitable for CFTS-5). The gland plates shall be marine grade 8 mm thick aluminium.

The arrangement shall allow cables to be connected to a separate terminal plate mounted on stand-off insulators on the back of the cable box. Each terminal plate shall be connected, by easily removable copper links, to the HV winding bushing.

The cable box shall have an open front design such that the cables can be slid into their final termination position. The top of the front opening in the cable box shall be equal to or greater than the height of the internal main busbars to allow easy access for bolting of the cable termination palms at site.

The front bolted cover of the cable box shall be marine grade 8 mm thick aluminium and fitted with two lifting handles. One lifting handle shall be positioned on the left hand side of the cover and one on the right hand side of the cover such that two people can lift the cover off for regular maintenance access inside the cable box.

The cable box design shall be such that with the cables supported at the gland plate (the support is part of this Contract), then with the cable box access cover removed and the gland plate unbolted, that the transformer and cable box can be removed.

The front of the cable box shall have an *infra-red window* to enable cable termination temperature checks to be performed while the transformer is in service.

The cable box shall have sufficient support structures between the main tank and the cable box such that the cable box can bear the additional weight of two 100 kg people standing on or in the cable box without the need for additional vertical supports installed under the bottom of the cable box.

Removable insulated barriers shall be provided between the phases.

The cable box shall be as compact as possible. However, it shall not compromise the internal air electrical clearances which shall be in accordance with the system highest voltage requirements.

Except for the internal electrical clearances, the cable boxes shall comply with the requirements of BS 6435: 1984, and also the following specific requirements:

- a. They shall be suitable for through currents determined from this specification.
- b. They shall be suitable for earth fault currents equivalent to the system MVA fault levels.
- c. Electrical clearances with cables connected to the terminals shall be such as to provide the impulse withstand strength.
- d. A pressure relief vent such as a square panel of at least 0.2 m². The sides shall be sufficiently strong such that the vent panel cannot become detached from the cable box. The panel shall open at a pressure of at least 50 kPa lower than the internal withstand pressure of the cable box.
- e. The air filled cable box shall be fitted with one dehydrating breather to prevent internal condensation. The breather shall be from MR Reinhausen Germany and shall be accessible to a person standing at ground level and fitted with 2 kg of dehydrating material. **The breathers to be fitted using quick disconnect fittings for ease of changing silica gel during inspections.**
- f. The bottom of the cable box shall be at least 1000 mm from the bottom of the transformer tank.
- g. The bushing to cable connections (solid or flexible) shall be supplied by the Contractor and the Employers **mandatory** requires from **ABB/Hitachi Sweden MICAFIL**.
- h. The positioning of the cable to bushing connections shall be mechanically restrained in such a manner as to meet the short circuit conditions as specified in this specification.
- i. The cable box shall have the following earthing facilities:
 - i. An earth bar for the separate connection of each individual cable's screen. The earth bar shall be mounted on stand-off insulators with a removable connection from the earth bar to an earth stud on the cable box wall to facilitate testing. The earth bar shall be located outside the cable box no more than 300 mm from the cable entry to enable in service cable testing. Each cable screen shall be brought outside the cable box through an insulation gland to connect separately onto the earth bar.
 - ii. The cable box earthing points mentioned above shall be bonded together, and then connected to the transformer tank.
 - iii. The cable box shall be weatherproof to IP 55 classification in IEC 60529.

Where the cable box is bolted on to the main transformer tank, flange mountings for the gasket seal shall be provided.

HV and LV Cable Box Air Clearances:

System Highest Voltage (kV rms)	Minimum Phase to Earth Clearance (mm)	Minimum Phase to Phase Clearance (mm)
12 kV	120	140
36 kV	320	370

5.20 TANKS AND ANCILLARY EQUIPMENT

5.20.1 Transformer Tanks

Each transformer shall be enclosed in a suitable stiffened welded steel tank such that the complete transformer with oil can be lifted by crane and transported without any and permanent deformation or oil leakage. The construction shall employ weldable mild steel and shall be of sufficient strength and rigidity to withstand moving, shipping and handling without deformation. Lifting lugs shall be provided, suitable for the weight of the transformer, including core and windings, fittings, and with the tank filled with oil. Each tank shall be provided with at least four jacking lugs suitably positioned to enable the transformer, complete with all tank mounted accessories and filled with oil, to be raised or lowered by jacks. The transformer tank shall be capable of withstanding full vacuum without deflection exceeding the value stated in the Schedule of Tests. Where the design of the tank is such that the bottom plate will be in direct contact with the surface of the foundations, the plates shall have the following minimum thickness: -

<u>Length of Transformer</u>	<u>Minimum Thickness</u>	
	<u>Side Plates</u>	<u>Bottom Plates</u>
Less than 2500 mm	6 mm	19 mm
Greater than 2500 mm	12 mm	25 mm
Greater than 7500 mm	32 mm	40 mm

Where skid type bases are provided, the plates shall have the following minimum thickness: -

<u>Length of Transformer</u>	<u>Minimum Thickness</u>	
	<u>Side Plates</u>	<u>Bottom Plates</u>
Less than 2500 mm	6 mm	9 mm
Greater than 2500 mm	19 mm	25 mm

In case of a self-supporting tank bottom of the power transformer without steel crossbeams, the bottom plate shall have a minimum thickness of 40 mm. The base of each tank shall be so designed that it is possible to move the complete transformer unit in any direction without injury when using rollers, plates, or rails. Transformers may have flat, skid or wheel bases subject to the approval of Employer's Representative, but, detachable under bases must not be used unless specifically approved by the Employer's Representative. All joints other than those, which may have to be opened, shall be welded. Caulking of defective welded joints may be re-welded subject to the written approval of the Employer's Representative. The tank and cover shall be designed in such a manner as to leave no external pockets in which water can lodge, no internal pockets in which oil can remain when draining the tank or in which air can be trapped when filling the tank, and to provide easy access to all external surfaces for painting.

When built-on radiators are used, each radiator bank shall be connected to the main tank through flanged valves mounted on the tank at top and bottom and each bank shall be fitted with drain valve and air release plug.

5.20.2 Construction

Weldable structural steel of an approved grade to BS 7668, BS EN 10029, BS EN 10025 and BS EN 10210 or equivalent shall be used in construction. Each transformer shall be enclosed in a suitably stiffened welded steel tank suitable for outdoor service and designed so the transformer can be transported. When fully oil filled, the transformer shall be able to be jacked, lifted, and hauled into place without permanent deformation or leakage.

Tank wall stiffeners shall be of the vertical type to minimise corrosion of the surfaces and to allow for the option of sand filling inside the stiffeners for noise control. Sand filling inside the tank wall stiffeners for additional noise control shall be agreed during the Design Review at the manufacturers' works.

The design of the tank and cover shall not have any external pockets or dips in which water can lodge or pond, or internal pockets in which oil can remain when draining the tank or in which air can be trapped when filling the tank. The same applies to spaces under access covers.

The tank design shall provide for easy access to all external surfaces for painting. Joints around access openings, bushings and any other removable accessories shall be bolted, and an electrical bond provided across the bolted joint.

All external edges shall have a minimum 3 mm radius to ensure adequate paint thickness.

5.20.3 Cover

Each tank cover shall be of adequate strength, must not distort when lifted and shall be provided with suitable flanges having sufficient and properly spaced bolts. Inspection openings shall be provided to give access to the internal connections of bushings, winding connections and earthing links. Each opening shall be correctly located and must be of ample size for the purpose of which it is intended. All inspection covers shall be provided with lifting handles. **Tank covers with low level welded flanged joints are preferred, but contractors may offer alternative designs with high level covers. It must be possible to remove any bushing without removing the tank cover and adequate access chambers shall be provided for this purpose.**

A bolted or welded cover may be used for the main tank cover. If a welded cover is used 'MIG' welding shall be used to weld the cover to the main tank. The core and windings shall not be suspended from the main tank cover.

The top of the tank cover shall be fitted with two Uni-Anchor Plates with Tie-Off Anchors, manufactured by Unique Concepts Ltd (Part No. 17415 - stainless steel version), for safety harness attachments.

5.20.4 Thermometer Pockets

Pockets shall be provided for a stem type thermometer and for the bulbs of temperature indicators where specified. These pockets shall be located in the position of maximum oil temperature and it must be possible to remove any bulb without lowering the oil level in the tank. Captive screwed caps shall be provided to prevent the ingress of water to the thermometer pockets when they are not in use. Thermometer pockets shall comply with the requirements of BS 2765 and be located according to IEC 60076-2.

5.20.5 Access Openings

Openings shall be provided in the main tank to give access for in-situ tightening of the core and windings without removing the main tank or the main tank cover. Openings shall be provided in the tank to give access to the internal connections of all bushings, earthing connections, CT secondaries, and tap-changers. The opening shall give unimpeded internal access and shall be of ample size for the purpose intended.

All access openings shall have flanges welded to them by means of continuous welds both on the inside and the outside of the flange. To make it easy to fit covers to the openings, the flanges shall have drilled and tapped blind holes to accommodate the studs.

All access covers shall be provided with lifting handles.

5.20.6 Lifting Jacking and Haulage

The transformer tank shall be provided with attachments (front, rear, and both sides) for lifting, jacking, and haulage. Lifting lugs shall be strong enough to lift, without distortion, the complete transformer when full of oil.

Jacking pads shall be provided, two on each side of the tank, extending perpendicularly from the tank, with a minimum effective size of 200 mm length and 150 mm width. The jacking pads shall have a minimum clearance from the tank base of 300 mm.

Haulage eyes shall be provided on each side and each end of the transformer tank. They shall be located symmetrically about the tank centre line, 200 mm to 300 mm above the base of the tank and perpendicular to the tank. A hole, at least 50 mm in diameter, shall be provided for the eye, and at least 100 mm of free working space shall be provided above and below each haulage eye.

5.20.7 Pressure and Vacuum Withstand

The complete tank with all fittings and pipework shall withstand full vacuum (-1014 millibars gauge), and an internal pressure of 50 kPa without permanent deformation or leaks. The Contractor shall test the tank in accordance with Clauses 6.5.7 and 6.5.8 to prove compliance with the above.

5.20.8 Mounting of Bushings

- a. Each bushing shall be mounted on an annular steel ring equipped with studs and designed to the following specifications:
- b. Outside diameter = flange diameter of the bushing.
- c. Inside diameter = lower portion bushing diameter plus 12 mm
- d. Minimum thickness = 1.5 x diameter of fixing studs
- e. Each ring shall be fixed to the outside surface of the cover or tank by means of continuous welding around both the internal and external circumferences.
- f. Stainless steel studs shall be fitted to the mounting ring.

5.20.9 Bushing Turret Bleeds

Air bleed pipework for trapped air and combustible gases shall be provided for all bushing turrets. The air bleed and trapped gas pipework shall be connected to the main tank Buchholz relay.

5.20.10 Gun Studs

Stainless steel gun studs shall be used for all stud fittings on the external surfaces of the main tank. Subject to the approval of the Employer, the following alternative method of stud installation may be used: Stainless steel threaded rods inserted into tapped blind holes - provided a suitable method for preventing moisture ingress into the tapped blind holes is used.

5.20.11 Conservator Tank

Each transformer shall be provided with an overhead conservator tank formed of substantial steel plates and arranged above the highest point of the oil circulating system. Connections into the main tank shall be at the highest point to prevent the trapping of air or gas under the main tank cover. Main tank conservator vessels shall be equipped with elastic diaphragms of the air-bag type. The capacity of each conservator tank shall be adequate for the expansion and contraction of oil in the whole system under the specified operating conditions. Conservator tanks shall also be provided with a cleaning door, filling cap, filter and drain valve with captive cap and a prismatic type oil level indicator of MR Reinhausen MESSKO brand or equivalent in each compartment. Each oil level indicator shall have the minimum and maximum levels indication and alarm contacts.

The main conservator tank shall be provided with a partitioned chamber, with the same diameter as the main tank conservator, for the tap change conservator. The tap change conservator shall also be fitted with a VE Series Cedaspe Brand and an oil level gauge with alarm contacts.

All bolted connection plates of the conservator tank supports shall be a non-corrosive material that does not require painting. The material may be either a non-magnetic black steel or stainless steel. The conservator tank supports that are bolted to the side wall of the main tank shall have bottom stops welded on the tank side wall to hold the supports in place when bolted into position during site assembly. Access for inspection, cleaning and painting of the main tank and tap change conservator chambers shall be provided via one of the following two options:

1. Removable end plates, or
2. Sealed end plates but with an opening at the top of the main tank chamber of a sufficient size to allow entry and for the tap changer chamber removal of the oil level gauge to allow entry.

The second of the above two options is preferred.

Conservator tanks shall be provided with a filling cap, drain valve with captive cap, and oil level gauge. The conservator shall have the same pressure and vacuum withstand, and be tested in the same manner as the transformer tank specified.

Gusset plates or other reinforcing members shall be so arranged as to ensure the free passage of oil along the bottom of the conservator. The location of the conservator tank shall not obstruct the removal from the tank of equipment such as the tap-changer.

The conservator for the main tank shall be of the fully sealed type to prevent oxygen, moisture, and particles from entering into the transformer oil. It shall consist of:

- i. An impermeable synthetic cell type rubber membrane that separates the oil from the air.
- ii. A breather connected to the airside of the rubber membrane at 1400mm above the transformer base.
- iii. A sump.
- iv. An oil level gauge with alarm contacts.
- v. An air release valve to permit bleeding off air during filling of the transformer or when in service.
- vi. An oil handling facility.

Inspection covers shall be provided to permit inspection of the rubber membrane without dismantling the conservator. The internal surfaces of the conservator shall be varnished to resist corrosion. The design of the conservator shall be such that internal re-treatment (of the conservator) and replacement of the rubber membrane can be easily carried out. The conservators shall have sufficient capacity to accommodate expansion and contraction of the oil due to temperature changes from -5°C to 120°C.

5.20.12 MTRAB Self Dehydrating Breathers DB200

The location of the conservator tank shall be so arranged that it does comply with the requirements and a valve shall be provided at the conservator to cut off the oil supply to the tank. Each conservator shall be fitted with or equivalent. Due to the climatic conditions at site, this breather shall be larger than what would be fitted for use in a temperate climate. All (two units) breathers MTRAB Self Dehydrating breathers of MR Brand shall be mounted at a height of approximately 1400 mm above ground level. The pipe work between the conservator and the transformer tank shall comply with the requirements and a valve shall be provided at the conservator to cut off the oil supply to the tank.

5.20.13 Valves and Location

All valves up to and including 75 mm bore shall be made of gunmetal. Each Transformer shall be fitted with the following valves as required for:-

- a) Draining the case (flanged-gate valve)
- b) Sampling oil from the extreme bottom and top of the case.
- c) Lower filter press connection and complete drain.
- d) Upper filter press connection.
- e) Isolating each radiator.
- f) Air relief or venting from each radiator.
- g) Draining oil from each radiator.
- h) Nitrogen.
- i) Conservator oil removal and filling.
- j) Tap Changer.
- k) Isolation of Buchholz relay for main tank.
- l) Transformer conservator main valve.
- m) Vacuum line connection.
- n) Gas analysis sampling.

The omission of any, or the provision of alternative arrangements to the above requirements, will not be accepted unless approved in writing by the Employer's Representative before manufacture.

Valves shall be arranged so that the hand wheel moves in a clockwise direction to close the valve. The face of each hand wheel shall be clearly marked with the words "open" and "shut" and be provided with an arrow to indicate direction for opening and shutting. Valves shall not be fitted in an inverted position. Unless the valve is one that can only be either fully open or fully closed, valves of 50 mm nominal bore or larger shall have position indicators. These show the amount by which the valve is open or closed in relation to its full travel.

All valve hand wheels shall be fitted with nameplates. Suitable means shall be provided to protect the operating mechanisms of all valves against mechanical damage and dust or dirt. Adequate provision shall be made for the lubrication of the mechanism and guides and this shall be of the pressure type.

All valves that are part of the oil flow circuit, either via the radiators or to and from the conservator, shall be of the indicating lockable type.

Precautions shall be taken to prevent corrosion of the valve spindles in contact with the gland packing. Isolating valves for the radiators shall be the Butterfly type with lockable positions.

Radiator isolating valves, oil inlet valves, oil outlet valves, oil sampling valves and any on-line monitoring valves fitted to the main tank, conservators and radiators shall use bolted flange connections and be easily removable for maintenance purposes.

Isolating valves shall be Gate type valves with lockable positions.

5.20.14 Oil Handling Facilities

Each transformer shall be provided with the following female gate valves and fittings that, with the exception of sampling outlets, shall where necessary be brought down to a height of 1.5 m or less from ground level, with 40 mm galvanised C Grade pipe complying with ISO 65.

All threads in valves, fittings, and on pipes shall comply with ISO7/1. The valve and fitting sizes shall be the metric equivalent of the sizes given in the table below:

Item	Description	Requirements	Size
1	Main Tank:		
1.1	Inlet filter connection valve	Drains the tank to within 15 mm of the tank bottom	Rc 1½
1.2	Outlet filter connection valve		Rc 1½
1.3	Drain plug	Samples from top & bottom of tank	Rc 1½
1.4	Oil sampling valve		Rc ½
2	Transformer Conservator Tank:		
2.1	Inlet filter connection valve		Rc 1½
2.2	Outlet filter connection valve		Rc 1½
2.3	Drain valve		Rc 1½
3	On-load Tap-changer Conservator Tank:		
3.1	Inlet filter connection valve		Rc 1½
3.2	Outlet filter connection valve		Rc 1½
3.3	Drain valve		Rc ½
4	Radiators:		
4.1	Drain plug		Rc 1½
4.2	Bleeder Valve		Rc 1½
5	Radiator Bank:		
5.1	Inlet filter connection valve	Drains tank to within 40 mm of its bottom	Rc 1½
5.2	Outlet filter valve		Rc 1½
5.3	Drain plug		Rc 1½

Item	Description	Requirements	Size
6	Tap-changer Switch Chamber:		
6.1	Drain valve		Rc 1½
6.2	Oil sampling valve		Rc ½

5.21 Galvanising

5.21.1 General

- a. Galvanising shall be in accordance with BS 729 and shall consist of a thickness of zinc coating of between 100 to 120µm.
- b. Hot dip galvanising of metal, including the threads of bolts and screwed rods shall be carried out after all machining, bending, cutting, drilling, punching, marking and welding operations have been carried out.
- c. Nuts shall be tapped up to 0.4 mm oversize after galvanising and the threads shall be lubricated by water-resisting rust-inhibiting oil.
- d. Where punching is used the draw shall be removed together with all burrs from drilling, punching etc prior to galvanising.
- e. The zinc coating shall be smooth, clean and of uniform thickness and free from defect.
- f. The preparation for galvanising and the galvanising itself shall not adversely affect the mechanical properties of the coated material. Surfaces in contact with oil shall not be galvanised.
- g. Galvanising Damage and Shipping Corrosion - If the extent of damage found on site to a galvanised part appears capable of repair, the Manufacturer may, after receiving agreement from the Employer, attempt to effect such repair by approved methods.
- h. This agreement shall not bind the Employer to accept the repaired part when it is reoffered for inspection.
- i. In the event that it is found that galvanised parts are subject to the formation of white rust during shipment or storage on site, the Employer shall either :
 - a. Approve a system of scrubbing and protective painting to be applied on site if, in his opinion, this is expedient, or
 - b. Reject the affected parts. Replacement parts shall be given special dip or spray treatment without extra charge to the Employer. Replacement parts are subject to the Employer's inspection and approval.

5.21.2 Castings

- a. All castings shall be true to pattern, of uniform quality and condition, and free from blowholes, flaws, and cracks. No welding, filling or plugging of defective parts is to be done under any circumstances.
- b. The surfaces of castings, which do not undergo machining, shall be free from foundry irregularities and burrs.

5.21.3 Iron Castings

All cast iron is to be of close-grained quality approved by the Employer. Iron casting material shall be in accordance with ASTM A 126 Class B, and shall be subject to appropriate tests and inspection as detailed therein.

5.21.4 Steel Castings

Steel castings shall be manufactured in accordance with ASTM A27, and shall be subject to appropriate tests and inspection as detailed therein.

5.21.5 Non-ferrous Castings

Non-ferrous casting material and castings shall be manufactured in accordance with the appropriate ASTM standards for the material concerned.

5.21.6 Welding

- a. Welds across oil tight joints shall be subject to the approval of the Employer. Such welds may be allowed providing the joining process is by automatic submerged arc welding with welding from both sides of the plate.
- b. Where gussets are provided cut-outs shall be provided and of sufficient size to allow welding behind. All tanks, fittings and flanges shall be double welded.
- c. No Space welding is allowed externally. No end-to-end jointing of steel sections shall be allowed. Joints between members connected by welding shall be completely sealed by a continuous weld.
- d. The Manufacturer is to submit evidence, satisfactory to the Employer, that the welding operations are qualified in accordance with the requirements of the appropriate section of BS 4871, or such other standard approved by the Employer
- e. In all cases where welds are liable to be highly stressed such as in the case of containing short-circuit forces; the Manufacturer shall supply to the Employer a general arrangement drawing of the proposed welding and the supporting evidence that the structure will contain the above mentioned forces.
- f. Subsequently, and before fabrication commences, a detailed drawing of all proposed weld preparations on the fabrication shall be supplied to the Employer for approval.

5.22 ANTI CORROSION DESIGN

The design shall be based severe marine on worst atmospheric classification with a durability of minimum 20 years in accordance AS/NZS 2312.

In choosing materials and their finishes, due regard shall be given to the conditions under which equipment is to work, particularly since the corrosion of outdoor equipment is of continuing and serious concern to the Employer. The equipment offered shall be constructed of suitable high-grade materials to minimise corrosion.

- I. Metals of iron or steel shall be painted or galvanised as appropriate in accordance with this specification. Alternatively, indoor parts may have chromium or copper-nickel plated or other approved protective finishes. Materials and combinations of materials used to construct the equipment shall be selected and arranged to prevent bimetallic corrosion. Aluminium alloys containing Cu or Mg shall not be used. Current carrying parts shall be made from non-ferrous metal. Where practicable, all surfaces shall be self-draining, and all air filled enclosures (e.g., terminal boxes) shall have an insect-proof drain hole. All surfaces, openings and flanges shall be designed and constructed to avoid the settling or accumulation of moisture, including condensation, and any other corrosive material.

- II. Bolts, Screws, Nuts, Springs, Pivots, etc.

Any cover bolts, nuts, washers etc shall be galvanised, and all others shall be 316 stainless steel bolts mated with 308 stainless steel nuts together with an anti-seize compound.

When used, stainless steel screws shall be used when plating is not possible owing to tolerance limitations, be of corrosion-resisting steel. Instrument screws (except those forming part of a magnetic circuit) shall be brass or bronze. Springs shall be of non-rusting material, e.g., phosphor-bronze, or nickel silver.

- III. Fabrics, Cork, Paper, etc.

These materials, which are not to be protected subsequently by impregnation, shall be adequately treated with an approved fungicide. Sleeving and fabrics treated with linseed oil or linseed varnishes shall not be used.

- IV. Gaskets

All joint faces shall be arranged to prevent the ingress of water or leakage of oil with a minimum of gasket surface exposed to the action of oil or air. **Oil resisting synthetic rubber is not permissible except where metal inserts are provided to limit compression.**

Gaskets shall be as thin as is possible consistent with the provision of a good seal and full details of all gasket sealing arrangements shall be shown on the Plant drawings. ALL Gaskets shall single piece without joints. Where joints are inevitable then dovetail or other approved joints shall be used.

All "O" Ring gaskets shall be of the Green (or other nonblack colour) Viton high temperature type. Any alternative gasket type supplied shall be to the approval of the Employer.

All flat gaskets (including the LV Cable Box) shall be of the Klingerite type or the Green (or other nonblack colour) Viton high temperature type. NEBAR Cork/Rubber Gasket is also acceptable. Any alternative gasket type supplied shall be to the approval of the Employer.

Welded lid gaskets and all Control Cubicle gaskets may be of a suitable type at the discretion of the Contractor. Gaskets shall not deteriorate due to weathering or when exposed to transformer oil at operating temperature of 130°C.

If sealing rings are used for the main oil retention control:

a. Machined flanges

The machined flanges shall be painted with the same external paint system as the main tank, excluding "O" ring seats and sealing surfaces. The method of effecting the above in relation to the sealing ring shall be to the Employer's approval.

It is required from the "O" ring outwards that a sealant be used to prevent ingress of moisture between faces after assembly of the flange. This can be in the form of a thin gasket or sealant to the approval of the Engineer and shall cover the surface from the "O" ring to the outside of the flange.

b. Non-machined flanges

Non-machined flanges shall be painted with the same external paint system as the main tank. The use of gaskets each side of the bolts in any flange is not acceptable. The flange shall have its mating surface fully covered by the gasket.

c. Main Flange

The joint shall be sealed by a restrained "O" ring, or full flange gasket that prevents moisture ingress.

5.23 FINISHES

Special attention shall be given to ensure the integrity of all protective coatings during sea freight.

5.23.1 Tanks, Accessories, Pipe-work

Painting shall commence with the least possible delay after inspection of the cleaned surfaces by the Employer. No visible deterioration as compared to a freshly cleaned area shall be allowed. A blast-cleaned surface shall not stand overnight without being coated. The tank base underside shall have the same paint system applied as other tank surfaces.

5.23.2 Zinc Spraying of Main Tank Base

The outside of the main tank base and all sides of the main tank wall up to a level of 500 mm from the bottom of the tank base shall be zinc sprayed prior to painting. The zinc spray applied shall have a minimum dry coating thickness of 120 µm.

5.23.3 External Surface Preparation

1. Air Filled Cable Box shall have only external surfaces painted to the same standard as the main tank external surface requirements
2. Exterior surfaces to be painted shall be prepared by a dry method of blast-cleaning to one of the following standards :
 - a) "First Quality" in accordance with BS 7079, with the metallic abrasive

conforming to BS EN ISO 11124-3 & 4.

- b) "Class 2.5" in accordance with AS 1627.
 - c) "Sa 2.5" in accordance with Swedish Standard SIS 05 59 00.
3. The external colour of outdoor equipment shall be Neutral to BS 4800, reference 00A05. Each coat of paint shall have a contrasting colour to all the adjacent coats of paint.
- A) First Coat
Exterior surfaces shall have an inorganic zinc silicate primer applied, "Dulux ICI" Zinkanode 304, or equivalent, with a dry film thickness between 65 to 75 microns, and with no porosity.
 - B) Second Coat
The second coat shall be "Dulux ICI" Ferreko No 3 Micaceous Iron Oxide Mid Grey, or equivalent, with a dry film thickness ranging between 80 to 100 microns.
 - C) Third Coat
The third coat shall be "Dulux ICI" Luxepoxy 4 White Primer, or equivalent, with a dry film thickness ranging between 30 to 40 microns.
 - D) Fourth Coat
The fourth coat shall be "Dulux ICI" Urethane or epoxy Enamel, or equivalent, with a dry film thickness ranging between 30 to 40 microns.
4. The total thickness shall range between 205 microns and 255 microns.
5. All corners, nuts, bolts, tap changer, fan and pump housings shall be covered to the above specified paint thickness.
6. Interior Surfaces
Interior voids and surfaces of all oil-filled chambers shall be free from all rust, scale and other detritus. Accessible interior surfaces shall be power brushed.

The interior of all oil filled chambers (except for radiators), shall be painted with an oil resistant white anti-tracking varnish or enamel.

5.23.4 Radiators

- a) Surface Preparation
Internal surfaces of radiators shall be hot acid flushed and shall be free of all rust, scale and detritus. Alternatively, a nitrogen lance shall be used to purge the atmosphere of oxygen during welding and fitting. A non-return valve shall be used to prevent the entry of air into the radiator during galvanising.

External radiator surfaces shall be hot-dip galvanised.
- b) Painting
 - i. Clean galvanised surfaces of all grease, oil and fluxing residues using galvanising-preparation solution and hot water blast.
 - ii. Phosphate and pre-treat all surfaces to ensure proper adhesion of primer and subsequent coats and allow sufficient time to dry.
 - iii. Apply full immersion prime in ZP zinc phosphate to 50 um DFT.
 - iv. Apply intermediate coat to 100 um DFT using epoxy hi-build.
 - v. Apply top coat in acrylic urethane to 60 um DFT (Colour: 00A05 to BS5252).
 - vi. Provide Quality Control documentation.
 - vii. No damaged radiator shall be acceptable on site.
 - viii. The transformer manufacturer shall supply sufficient spare amounts of all four layers of transformer paint for the repair work at site of all damaged transformer surfaces - with the exception of the radiators.

5.23.5 Galvanising Damage and Shipping Corrosion

If the Employer considers that on-site damage to a galvanised part is repairable, then the contractor may attempt repair by using approved methods. Any agreement to attempt repair shall not bind the Employer to accept the repaired part when it is re-offered for inspection. If galvanised parts are found to be subject to the formation of white rust during shipment or storage on site, the Employer shall either:

- i. Approve a system of scrubbing and protective painting to be applied on site if, the Employer considers this expedient, or,
- ii. Reject the affected parts. Then, before any future shipments are dispatched from the works, replacement parts shall be given special dip or spray treatment at no extra cost to the Employer. Replacement parts are then to the Employer's inspection and approval.

5.23.6 INTERNAL FASTENINGS

Spring washers shall not be used. The preferred method of locking nuts is to use a full nut and a half nut. After tightening a nut and washer or nut and lock nut assembly, the steel thread shall be "popped" with a sharp pointed punch to prevent loosening of the nut. Non-steel bolts and nuts shall use a locking system together with glue or ties.

5.24 RATING, DIAGRAM AND VALVE PLATES

The following plates, or an approved combined plate, shall be fixed to each Transformer tank at an average height of 1500 mm above the ground level:-

- a. Plates are to be of stainless steel 316 marine grade with minimum 4mm thick capable for continuous outdoor service and withstanding the climatic conditions of the site.
- b. A rating plate with the data specified in IEC 60076 Part 1. This plate shall also include a space for the Employer's serial number and in addition include the short-circuit current rating and time-factor for each winding.
- c. A diagram plate showing in an approved manner, the internal connections and the voltage relationship of the several windings, in accordance with IEC 60076 Part 1 with the Transformer voltage ratio for each tap and, in addition, a plan view of the Transformer giving the correct physical relationship of the terminals.
- d. A plate showing the location and function of all valves and air release cocks or plugs. This plate shall also, if necessary, warn operators to refer to the Maintenance instructions before applying vacuum.
- e. The recommended electric strength and moisture content at the reference temperature of the oil for both the initial fill and in service.
- f. Vacuum withstand in negative millibars (gauge) of the transformer tank, conservator tanks and radiators/coolers.
- g. The internal and external connection arrangements for the transformer in both of its possible winding connection orientations.
- h. The type and quantity of oil to be used for filling as IEC 60296.
- i. Metrosils or other type of voltage limiting devices installed across the tapping windings.
- j. A plate showing the location and function of all valves, vents, cocks and plugs. This plate shall also warn operators to refer to the maintenance manual before applying vacuum treatment.
- k. The above plates shall be located adjacent to each other on the tank wall.

5.25 COOLING PLANT

5.25.1 Cooling Plant – General

Radiators and cooling fans shall be hot dip galvanized in accordance with ISO 1459. The design shall also avoid pockets in which water can collect and shall be capable of withstanding the pressure tests specified in Schedule of Works Tests for the transformer main tank.

The clearance between any oil or other pipe work and live parts shall be not less than the minimum clearances as specified in the specification.

5.25.2 Radiators

Honeycomb-tube type radiators are not acceptable to the Employer. The radiators shall have the same pressure and vacuum withstand, and be tested in the same manner as the transformer tank. Radiators shall have the following features:

- a. Oil handling facilities.
- b. Two lifting lugs per radiator.
- c. Isolating gate valves to permit uncoupling of the radiator from the transformer or the separate radiator bank, without draining the oil from the transformer or the separate radiator bank. These valves shall withstand full vacuum.
- d. Braced to withstand the seismic forces detailed in this specification.
- e. If a separate radiator bank is supplied there shall be two bolted earth bonds to the support structure, one on each diagonally opposite corner of the radiator.
- f. If the radiators are attached to a manifold welded to the tank then this manifold shall have:
 - Removable end plates.
 - Drain Plug and an air admission vent.

If the manifold is detachable it shall have all the fittings with the gate valves attached to the tank indicating and lockable. Any radiator shall be able to be removed from a bank without first removing any other item such as conservator or other radiators.

5.25.3 Pipe Supports

All pipe-work and accessories included in this contract shall be supported and mounted in a manner approved by the Employer. The Contractor shall supply all necessary saddles, structural steelwork, foundation bolts, fixing bolts and all other attachments.

The number and positions of all intermediate flexible supports between anchor points shall be determined by the weights to be carried and by the steelwork available for the purpose. All this shall be subject to the Employer's approval.

5.25.4 Pressure Gauges

If required, all pressure gauges shall be fitted with stop-cocks immediately adjacent to each gauge, and all pressure gauge piping shall be fitted with an isolating valve at each point of connection to the main system. Where pressure gauges are mounted on panels, the stop-cocks shall be suitable for the connection of a test gauge.

Where a difference in level exists between the position of the gauge and the point at which pressure is measured, appropriate compensation shall be made in the dial reading (the dial shall be marked with the degree of compensation). However, dials only need marking if the degree of compensation is greater than 2%.

Pressure gauges shall be mounted on panels where practicable. The Employer shall approve the locations of the pressure gauges. All pressure gauges shall be clearly identified by means of separate labels of an approved type and lettering. All high pressure gauge piping shall be stainless steel 316 grade but other pressure gauge piping may be of copper tube or other material approved by the Employer.

5.25.5 Radiators Connected Directly To Tank

Radiators connected directly to the tank shall be detachable and shall be provided with flanged inlet and outlet branches. Plugs shall be fitted at the top of each radiator for air release and at the bottom for draining. A gate valve shall be provided on the radiator at each point of connection to the tank.

5.25.6 Air Forced Cooling

Forced cooling equipment for transformers of similar rating and design shall be completely interchangeable one with the other without modification on Site.

5.25.7 Oil pipes and Flanges

All oil piping shall be of approved material with machined flanged joints. Copper pipe work is to comply with BS.61. Dimensions of steel pipes shall be in accordance with BS.3600 and the drilling of all pipe flanges shall comply with BS.4504.

It shall be possible to drain any section of pipe work independently of the rest and drain valves or plugs shall be provided as necessary to meet this requirement.

5.25.8 TRANSFORMER COOLING FAN

Air blowers for forced air cooling shall be ZIEHL- ABEGG AG and be suitable for continuous operation out-of-doors. They shall also be capable of withstanding the stresses imposed when brought up to speed by the direct application of full line voltage to the motor.

To reduce noise to the practical minimum, motors shall be mounted independently from the coolers or, alternatively, an approved form of anti-vibration mounting shall be provided. It shall be possible to remove the blower complete with motor without disturbing or dismantling the cooler structure framework.

Blades shall be of galvanized steel unless otherwise approved. Blower casings shall be made of galvanized steel of thickness not less than 2.6 mm (14 S.W.G.) and shall be suitably stiffened by angles or tees.

Galvanized wire mesh guards shall be provided to prevent accidental contact with the blades and to prevent access of birds and their nests. Guards shall also be provided over all moving parts. Guards shall be designed such that blades and other moving parts cannot be touched by test fingers to IEC.60529.

The Transformer Cooling fans blowers shall be from ZIEHL- ABEGG AG.

5.25.9 COOLER CONTROL

Where multiple fan cooling using three-phase 240V 50HZ motors is from ZIEHL- ABEGG AG, the motors in each cooling bank shall be grouped so as to form a balance three-phase load. Each motor or group of motors shall be provided with a three-pole electrically operated contactor and with control gear of approved design for starting and stopping manually. The electrical supply for the control of the cooling units shall be provided by means of two independent feeders.

Where forced cooling is used on transformers provision shall be included under this Contract for automatic starting and stopping from the contacts on the oil / winding temperature indicating device as specified. Where small motors are operated in group, the group protection shall be arranged so that it will operate satisfactorily in the event of a fault occurring in a single motor.

The control arrangements are to be designed to prevent the starting of motors totalling more than 1.5 kW simultaneously either manually or automatically. All contacts and other parts, which may require periodic renewal, adjustment or inspection, shall be readily accessible. All wiring for the control gear accommodated in the marshalling kiosk IP55 together with all necessary cable boxes and terminations and all wiring between the marshalling kiosk and the motors shall be included in the Contract.

The first group of fans shall come into operation at lower temperature (i.e. at 50° C hot spot temperature) and the second group at a higher temperature. (i.e. at 65° C hot spot temperature). The winding temperature shall give the starting signal for the fans and the oil temperature shall give the stopping signals.

The cooling equipment shall be controlled by the control contacts on the electronic winding temperature monitor. The cooling fans shall be controlled separately with separate Off/Manual/Auto selector switches. Fan failure alarms shall be provided and wired back to the cooling control cubicle. Each fan shall have independent protection, i.e. failure of one fan shall not trip the remaining fans.

The control scheme shall not inhibit the action of the Buchholz relay at any time. Electrical isolation of the Buchholz relay during fan starts is not acceptable.

Manual reset, inverse time, ambient temperature compensated, overload and single-phase protection shall be provided in each phase of the supply to each motor. Arrangements shall be such that operation of a protective device in any phase automatically disconnects all supply from that motor and closes a cooling failure alarm contact. Disconnectors shall be provided to permit maintenance work to be carried out independently on each motor. All equipment shall be suitably housed for installation outdoors on the transformers.

The fan motors shall be of the 3-phase type and shall comply with IEC 60072. All bearings shall be self-lubricating and sealed for life.

5.26 VOLTAGE CONTROL

5.26.1 General

Transformers shall be provided with voltage control equipment MR Reinhausen Vacuum VacuTAP on-load circuit diverter switch tap changing (OLTC) type for varying the effective transformation ratio. Winding taps as called for in the Employer's Requirements shall be provided on the high voltage winding. All terminals shall be clearly and permanently marked with numbers corresponding to the cables connected thereto.

5.26.2 VACUUM ON-LOAD TAP-CHANGER DIVERTOR SWITCH EQUIPMENT

The on-load tap-changer (OLTC) shall comply with IEC 60214, and selected in accordance with IEC 60214-2 and shall be suitable for bi-directional power flow. The tap-changer shall withstand the type test short-circuit test current detailed in IEC 60214.

On-load tap-changers diverter switch shall be of the **vacuum type** and shall be supplied from **Maschinenfabrik Reinhausen (MR) GmbH of Germany**.

The tap-changer be an in tank type the Contractor shall provide handles and lifting lugs on the top cover.

The tap-changer design shall be such that, should an incomplete tap change operation occur, (because one or more phases of the supply to the driving or control apparatus is interrupted, or because of mechanical failure in the driving mechanism) no damage to the tap-changer or the transformer shall occur.

Tap-changer compartments shall be capable of withstanding full vacuum.

Tie-in resistors and potential control switches shall be installed to provide overvoltage protection for all reversing and coarse/fine type tap-changer mechanisms unless it can be demonstrated by the tap-changer manufacturer that they are not required.

5.26.3 OLTC Compartment

The tap-changer diverter switch shall be readily accessible without draining the main transformer tank oil and so located as to be easily removed without the need to dismantle any appendage. Any access covers to the tap-changer shall be easily removable for maintenance. The tap-changer compartment, or the diverter switch chamber on in-tank tap-changers, shall have oil handling facilities as detailed in this specification.

5.26.4 OLTC Driving Mechanism

The driving mechanism and its electric motor shall be enclosed in a ventilated weatherproof box to IP 55 classification in IEC 60529. The ventilation and drain shall be insect proof.

A mechanical counter shall be fitted to record the number of tap-changer operations. The motor shall be a 3-phase induction type.

5.26.5 OLTC Protection and Alarms

All OLTC protection and alarm auxiliary contacts shall be rated for 125V 2A DC. Mercury switches shall not be used.

The tap-changer mechanism cubicle shall be fitted with:

- i. Electrical interlocks and mechanical stops to prevent the tap-changer mechanism from over-running the contacts at the upper and lower limits.
- ii. One or more of the protective devices against increase in pressure specified in IEC 60214. Each device shall have separate alarm and trip contacts.
- iii. Alarm contacts to indicate tap change in progress to the Employer's AVR REG-DA Controller
- iv. Alarm contacts to indicate incomplete tap change to the Employer's SCADA.
- v. The contacts of all protective and alarm devices shall be wired to the cooling control cubicle.

5.26.6 Tap Position Indicator and Transducer

A mechanical tap-position indicator, clearly visible to a person standing at base level, shall be provided inside the tap-changer mechanism cubicle.

A tap position transducer for SCADA indication shall be installed in the cooling control cubicle. The tap position transducer shall comply with the following requirements:

- i. 2.0 kV isolation rating between input and output and to earth.
- ii. Output range of 0 to 10 mA.
- iii. Rated output burden of 1500 ohm.

To give indication mechanically at the transformer and electrically at the remote control point of the number of the tapping in use.

- iv. To give electrical indication, separate from that specified above, of tap position at the remote supervisory point.
- v. To give indication at the remote control point and at the supervisory control point that a tap change is in progress, this indication to continue until the tap change is completed.
- vi. To indicate at the tap change mechanism the number of operations completed by the equipment.

5.26.7 OLTC Control System

There shall be a Local/Remote selector switch provided in the cooling control cubicle or in the tap changer MB. The Local/Remote selector switch shall be provided with a total of 4 sets of contacts (2 sets for Local and 2 sets for Remote) for status indication of both operating positions to the Employer's AVR and SCADA.

In the Local position, the selector switch shall allow separate tap-change raise and tap-change lower push buttons or switches located in the tap-change drive mechanism cubicle to be enabled. The remote raise and lower functions shall be disabled with the switch in the Local position.

In the Remote position, the selector switch shall allow the Employer's AVR to issue both tap-change raise and tap-change lower commands to the tap-change drive mechanism. The local raise and lower functions shall be disabled with the switch in the Remote position.

The selected OLTC control mode shall not change due to power loss to any relays or other equipment used to implement the OLTC control mode selection.

Any commands issued to the OLTC while a tap change operation is in progress, shall be deferred until the tap change operation has been completed.

It shall be possible to manually change taps at rated voltage and on load using a mechanical crank. The manual, mechanical, control of the tap-changer driving mechanism shall be easily hand operated by a person standing at transformer base level. Insertion of the hand crank, and before the crank is mechanically engaged, shall isolate all the OLTC electrical controls including Local/ Remote.

It shall be possible to isolate all the AC and DC power supplies to the OLTC mechanism housing, to de-energise the OLTC mechanism housing for routine maintenance purposes. The isolation points shall be either at the cooling control cubicle or at the tap changer mechanism cubicle. The status of these isolation switches shall be provided for connection to the Employer's SCADA.

5.27 BUSHING

- i. All bushings shall comply with IEC 60137.
- ii. **All bushing shall be purchased from ABB/Hitachi Sweden Micafil – this is a Mandatory requirement**
- iii. All types of bushings shall satisfactorily withstand the specified climatic and service conditions.
- iv. The strength of bushings, as given by the electromechanical test load, shall be such that the factor of safety when supporting their maximum working loads shall be at least 3.0.
- v. The end fixings for all porcelain bushings shall be designed so the porcelain bushing attains the full strength of the porcelain material. The following requirements for end fixings shall also be met:
 - a. Finger clamps shall not be used on the end fixings of bushings.
 - b. Split flanges shall not be used on the end fixings of bushings.
 - c. There shall be no grinding of glazed porcelain on the bushings.
- vi. Stresses due to expansion and contraction in any part of the bushings and fittings, shall not lead to the development of defects. Damaged bushings shall be replaced and not repaired. All bushings for outdoor switchyards whether pedestal post, cylindrical post or string shall have plain shed profiles.
- vii. All bushings shall be dark chocolate. Bolted porcelain sections shall not be accepted.
- viii. The creepage distance required for bushings shall be 53.7 mm per kV of the highest system voltage.
- ix. All bushings shall have permanent terminal marking plates adjacent to the bushing flange.
- x. The bushing flange shall not be of a type that may trap air.
- xi. Bushings shall be mounted so that:
 - a) The external connections can be taken away clear of all obstacles.
 - b) Removing the bushings does not require lowering the oil level below 300 mm above the top of the windings and/or removal of the tank cover.
 - c) Removing the bushings does not disturb any associated current transformers.
 - d) The base of any bushing shall be at least 1640 mm above the transformer base level.
- xii. Solid core bushings shall be designed so the internal space in the bushing is kept totally separate from oil in the main tank of the transformer.
- xiii. All bushings fitted to the transformer shall be of a proven low partial discharge design.
- xiv. Be fitted with a test tapping with protective cap, to permit the capacitance and dielectric loss angle to be measured. The insulation of this test tapping the associated conducting layer shall be capable of withstanding, throughout the life of the bushing.
- xv. The bushings manufactured by ABB Sweden shall be only supplied
- xvi. The Contractor shall advise if any of the above bushings are not suitable.
- xvii. Oil to air bushings in a cable box, shall be used to bring the HV 33kV and LV 11 kV winding connections out through the transformer wall.
- xviii. The bushings shall be mounted on non-magnetic metal plate prefer 316 Stainless steel and/or means taken to minimise the effects of eddy currents.
- xix. Electrical rated voltage of 36kV in Air.
- xx. Transformers are to be provided with air medium bushing and terminals for phase and neutral terminals as required in the Technical Particulars & Guarantees.
- xxi. All bushings shall comply with IEC.60137 and the minimum creepage distance for outdoor bushings shall be as specified in the Employer's Requirements.
- xxii. Bushings shall be of sealed construction suitable for service under the very humid conditions at Site and, in addition, to the very rapid cooling of equipment exposed to direct sunlight when this is followed by sudden heavy rainstorms.
- xxiii. **Typical sections of bushing insulators showing the internal construction, method of securing the top cap and methods of sealing shall be included in the Tender.**
- xxiv. On all condenser bushings a tapping shall be brought out to a separate terminal for testing purposes on site

High Voltage Bushing – 36kV in Air

The high voltage bushing shall be rated to 52kV and be of condenser type, self-grounding measuring tap and provision for venting.

Rated Voltage:	52kV
AC withstand voltage:	120kV
Lightning Impulse withstand:	250 kV
Creepage distance:	1,642mm per kV

Low Voltage Bushing – 11kV in Air

Rated Voltage:	52kV
AC withstand voltage:	120kV
Lightning Impulse withstand:	250 kV
Creepage distance:	1,642mm per kV

Low Voltage Neutral Bushing

Rated Voltage:	52kV
AC withstand voltage:	120kV
Lightning Impulse withstand:	250 kV
Creepage distance:	1,642mm per kV

Special precautions shall be taken to exclude moisture from paper insulation during manufacture, assembly, transport and erection. The surfaces of all paper insulators shall be finished with approved non-hygroscopic varnish, which cannot easily be damaged.

5.27.1 Marking

Each porcelain insulator shall have marked upon in the manufacturer's ABB Sweden name as identification mark and year of manufacture. These marks shall be clearly legible and visible after assembly of fittings and not impressed but shall be imprinted before firing.

When a batch of insulators bearing a certain identification mark has been rejected, no further insulators bearing this mark shall be submitted and the Contractor shall satisfy the Employer's Representative that adequate steps will be taken to mark or segregate the insulators constituting the rejected batch in such a way that there can be no possibility of the insulators being re-submitted for the test or supplied for the use of the Employer.

Each bushing shall be marked with the manufacturer's name or identification mark, year of manufacture, serial number, electrical and mechanical characteristics in accordance with IEC 60137.

5.27.2 Mounting of Bushings

Bushing insulators shall be mounted on the tank in a manner such that the external connections can be taken away clear of all obstacles. Neutral bushings shall be mounted in a position from which a connection can be taken to a neutral current transformer mounted on a bracket secured to the transformer tank.

The current transformer will be supplied by the contractor manufacturer be made on the tank for mounting to the Employer's Representative's requirements. The clearances from phase to earth and phase to phase must not be less than those stated in the specification.

When bushings with an under-oil end of a re-entrant type are used the associated flexible pull-through lead is to be fitted with a suitably designed gas bubble deflector. The bushing flanges must not be of re-entrant shape, which may trap air.

Clamps and fittings made of steel or malleable iron shall be galvanised in accordance with the specification and all bolt threads are to be greased before erection.

5.27.3 Main Terminals

Main terminals shall be electrically compatible with both copper and aluminium connections and shall be tinned. All current carrying connections shall be drilled flat lugs that follow the specifications set out in the following table:

Current Rating (A)	Dimensions (mm)	Drilling Arrangements
800	100 x 100	Four holes 17.5 mm dia on corners of 50 mm square
1600	100 x 100	Four holes 17.5 mm dia on corners of 50 mm square

Both sides of the terminal shall be machined flat. Both sides of the palm shall be accessible for the insertion of bolts. Corona or voltage grading rings shall be situated so they do not interfere with the connections in either direction.

If the bushing current itself is not one of these standard figures then the terminal dimension shall follow the standard specifications set out for the next highest current.

5.27.4 Terminal Markings

The high voltage terminals shall be marked A, B, C and the low voltage terminals shall be marked a, b, and c, respectively. Likewise, the neutral shall be marked N or n, respectively.

The winding connections to the terminals shall be such that with a phase order of A, B, C on the high voltage terminals, the phase order shall be a, b, c on the low voltage terminals in accordance with the specified vector symbol.

Other terminal and tapping markings shall comply with IEC 60616.

6.0 MECHANICAL STRENGTH AND SEISMIC REQUIREMENTS

The Contractor shall supply a Seismic Design Report for review that proves the requirements specified are met.

6.1 GENERAL

The equipment will be installed in areas subject to earthquakes and shall be designed to withstand, in working order and without normal working stresses being exceeded, the stresses arising from the following earthquake loads in addition to loads present during normal operation:

- a) For main structural components, including attachments, a horizontal load acting in any direction corresponding to its own weight multiplied by a seismic design factor of 3g acting through the centre of gravity of the transformer, excluding the associated cooling plant and attachments.
- b) For all attachments to the main tank, including radiators, conservator tank and pipe work, but excluding gas and oil actuated relays:
 - i. A horizontal load acting in any direction and corresponding to the weight multiplied by a seismic design factor of 1.5.
 - ii. A vertical load added to the weight of the equipment and equal in weight of the equipment multiplied by a seismic design factor of 1.5.

Special consideration shall be given to fastening the core and other components inside the tank and Manufacturer shall confirm that the core will not be able to move within the tank and cause damage to connections, bushings and other components. The consideration of an angle of 60 degrees for travelling and transportation during the design stages must be submitted for approval to the Manufacturer. Special consideration shall be given to fastening the core and other components inside the tank. The core shall not be able to move within the tank and cause damage to connections, bushings or other components.

Any separate radiator banks or other equipment shall be designed so that relative displacement between the bank and the transformer tank is minimised. Pipe-work between the tank and associated separate radiators shall be designed to allow for any relative displacement, and shall not be used as a structural connection.

6.2 SEISMIC REQUIREMENT FOR GAS OPERATED RELAYS

Gas operated relays or any other device arranged to trip the transformer from service automatically, whether mounted on the tank or elsewhere shall not falsely operate when subject to earthquake induced motion.

- a. Buchholz and oil flow relays or any other device arranged to trip a transformer from service automatically whether mounted on the tank or elsewhere shall not falsely operate or suffer damage when subject to earthquake induced motion.
- b. Seismic Stability Test Requirements

The stability tests on the relays offered shall (as a minimum):

- (a) Be carried out on each of the three axes of the gas operated relay, under the following conditions:
 - (a) with the float chamber completely filled with insulating oil; and
 - (b) With 5 % of the oil by volume drawn from the float chamber.
- (c) Be carried out using oil that complies with BS 148.
- (d) Be carried out with the oil at a typical operating temperature for Fiji conditions (in the range 40 °C to 80 °C with a reasonable average being 60 °C).
- (e) Gas operated relays arranged to trip the transformer from service automatically, shall not falsely operate when subject to a 5 cycles per beat sine beat vibration test, producing a maximum acceleration of 2.25 g, at any frequency between 2 and 15 Hz.

6.3 WIND LOADS

- Wind pressures shall be calculated assuming a maximum wind speed of 70 m/s.
- For circular and flat sections, minimum drag factors of 0.7 and 1.0 shall be used, resulting in pressures of 1050 N/m² and 1500 N/m² respectively, unless calculations are performed to demonstrate that lower drag factors are applicable.
- The values used for drag coefficients and solidity ratio shall be supported by reference to common international practice.

6.4 ALLOWABLE STRESS

- Testing to determine porcelain strength shall be performed with the same end fittings as proposed for service. End fixings for all porcelain bushings shall avoid local stress concentrations and be designed so the bushing attains the full strength of the porcelain material.
- Components shall be designed such that brittle components shall be the lowest on the Failure Hierarchy.
- Quoted strength of porcelain insulators shall be supported by testing
- If test certificated are not available, bending test at 70% of the quoted mechanical failing load of the complete porcelain assembly shall be carried out. IEC 60137 or equivalent standards shall be used

6.5 DESIGN LOAD CASES

The table below provides the design load cases to be used for the qualification of power transformers (electrical equipment and support structures). Any additional special loading conditions that may apply to the equipment shall be considered.

Load case	Ultimate limit states
Earthquake and line-pull	G+Eu+P
Wind	1.1*G+Wu

Table 1: Design cases and load factors for power transformers

6.6 Design loads (summary)

The loads used in design calculations and equipment shall be not less than the following:

Design loads	Summary of requirements
Dead load (G)	Includes equipment, accessories and support.
Terminal loads (P)	Longitudinal direction: 2 kN Transversal direction : 1kN
Wind loads (Wu)	Derived from AS/NZS 1170.2 using the annual probability of 1/2500. Alternatively, a value of 4.47 kPa can be used.
Seismic loads (Eu)	Loads from IEEE 693 High performance level. The vertical acceleration shall be 80% of the horizontal accelerations. Horizontal and vertical actions shall be considered simultaneously.

Table 2: Summary of design loads for power transformers

6.7 SEISMIC QUALIFICATION

The qualification consists of a test or analysis (as required below), a seismic qualification report and a permanent seismic qualification identification plate attached to the equipment, compliant with the recommendations of IEEE 693. The compliance with the requirements of IEEE 693 shall to be demonstrated by using, as a minimum, the qualification methods listed in the table below. No item or equipment should be considered as “inherently acceptable” and that seismic qualification should be carried out for all essential equipment and structural components.

The input spectra for both test and analysis shall take into account amplification due to first support performance (mounted equipment) or building structure performance (if not installed at ground level). Equipment mounted on stand shall be tested with their stand. A damping value of 2 % of critical damping shall be assumed when qualifying by analysis. Any damping values for equipment greater than 2 % shall be supported by test records.

Equipment employing composite bushings or housings shall be shake table tested or dynamically analysed to performance level. Load-deflection characteristics for composite bushings or housings shall be provided in order to determine the degree of non-linear behaviour. Acceptance criteria (including maximum allowable stress for brittle materials) shall be as defined in IEEE 693 Section A.2. Holding-down bolts and foundation attachments shall be designed not to yield under maximum earthquake accelerations (performance level). Equipment qualified by shake table test shall undergo and pass functional electrical tests before and after the shake table tests.

Equipment item	Nominal voltage	Seismic qualification method –minimum requirements
Power transformer tanks, cores, coils and anchorages	All	Static analysis
Power transformer radiators, conservators	All	Static analysis (with amplification factor of 3.0)
Power transformer bushings	All	Static pull test (with amplification factor of 2.0)

Table 3: Employers minimum requirements for seismic qualification method

6.8 Seismic qualification plate

The seismic qualification of equipment shall be stated on a seismic identification plate that shall be attached permanently to the equipment – refer to IEEE 693 section A.8.

6.9 General design requirements

A1 Information required

Information required once contract awarded:

- (a) A design report addressing all the applicable load cases. Actions on anchors and foundations shall be calculated.
- (b) A seismic qualification report according to IEEE 693.
- (c) Mechanical strength test reports for porcelain bushings and housings.
- (d) Mechanical strength test reports for composite bushings and housings including load-deflection characteristics.
- (e) Supporting documents if a damping greater than 2 % is assumed for the qualification of the equipment.
- (f) Detailed drawings of structural frames and holding down connections.
- (g) Installation drawings of the complete assembly.
- (h) Drawing of the rating plate attached to the equipment.

7.0 COMPLIANCE REQUIREMENTS

7.1 QUALITY ASSURANCE

Design, manufacture and testing of the equipment supplied shall comply with the ISO 9001 Quality Systems, or an equivalent standard approved by the Employer. The Employer will appoint an independent inspecting authority to verify that the Contractor's design, production, testing and quality assurance facilities and procedures are appropriate to the specified work.

7.2 CORE AND WINDING CALCULATIONS

A Design Review shall be performed at the Contractor's premises and the Contractor shall provide the following core and winding calculations to verify that the design complies with the performance requirements:

1. A core magnetic saturation curve based on design data, showing the core loss and excitation characteristics up to a point at which the air core reactance line becomes tangential to the magnetisation curve.
2. Major insulation details including the positioning of cylinders, barriers, angle rings, caps, angle collars, stress rings etc.
3. The grading of the winding turn insulation and the design limits compared to the permissible limits in these areas.
4. The method of effecting cross-overs, transpositions and lead-outs.
5. Clearances to the tank, end frames and core.
6. All lead insulation and clearances.
7. The method of joining winding lead-outs to other conductors.
8. Areas affected by the leakage flux field will have temperature rises.
9. The calculated hot-spot temperature rise of all windings and leads with temperature gradient calculations verified by reference to like units.
10. Short circuit strength calculations including adequate documentation and experimental test data to verify the free buckling, short circuit currents, transport requirements and seismic earthquake loadings.
11. Impulse calculations demonstrating whether metrosils or other types of voltage limiting devices are required across the tapping windings.

7.3 FIELD PLOTS

A Design Review shall be performed at the Contractor's premises and the Contractor shall provide the following field plots to verify that the design complies with the performance requirements:

1. Electric Field Plots

Field Plots for both Induced Voltage withstand and Separate Source Voltage withstand shall be provided, showing actual positions of windings, leads, crossovers, transpositions, insulation cylinders, angle rings, caps, and angle collars. The information provided shall be sufficient to enable the determination of puncture strength and creep strength of all the solid insulation including the winding strand covering. It shall also enable the determination of the oil strength.

Impulse Voltage verification shall be provided by computer calculated design for both the full wave and chopped wave conditions. These calculations shall allow interrogation of axial, radial and the vectorised resultant stresses within the winding to which the impulse is applied and shall also allow time based interrogation to apply. The criteria shall also apply to the transferred voltage to the other windings and shall allow the maximum voltage stress between windings and within windings to be calculated.

The actual position of the cross-over, transposition and lead-outs shall be fixed in the radial and axial dimensions based on the field plots. The positions and oil duct spacing shall be checked during manufacture.

2. Line End Tap Changers

Line end connected tap changers on HV windings shall be analysed to determine that under full wave and chopped wave impulse conditions, the tap changer insulation withstand ratings (with a suitable safety margin) are not exceeded. If the line end tap changer does not meet these impulse requirements, it shall be placed in the middle of the HV winding.

3. Magnetic Leakage Field Plots

Field Plots of the magnetic leakage field shall be provided to verify the temperature rise limits for all the ratings.

The actual hot spot gradient determined by magnetic leakage field plots shall be used to determine that the maximum allowable temperature limits specified are not exceeded.

7.4 SHIPMENT AND DRYING OUT

7.4.1 Shipment

Each transformer when prepared for shipment shall be fitted with a shock indicator or impact recorder that shall remain in situ until the transformer is delivered to Site. In the event that the transformer is found to have been subjected to excessive shock in transit, such examination as is necessary shall be made in the presence of the Employer's Representative.

Transformers shipped under pressure of gas shall be fitted for the duration of delivery to site and for such time thereafter as is necessary with a gauge and gas cylinder adequate to maintain internal pressure above atmospheric.

7.4.2 Drying Out

All transformers shall be dried out by an approved method at the manufacturer's works and so arranged that they might be put into service without further drying out on site.

Clear instructions shall be included in the Maintenance instructions and any required material shall be provided with the transformers regarding any special precautionary measures (e.g. strutting of tap changer barriers or tank cover) which must be taken before the specified vacuum is applied to the transformers so that they can withstand the treatment.

7.4.3 Oil Storage

The Contractor shall supply the first filling of transformer oil, which in accordance with the Employer's current practice shall be to IEC 60296. It is envisaged that the oil will be supplied to site in 200L drums or 1000L tanks and filtered prior to transfer into the transformer.

7.4.4 UNLOADING EQUIPMENT

Special attention has to be given for unloading the transformers as the harbour in Fiji has limited facilities to handle such heavy equipment. Also the transport to site by trailers etc. has to be thoroughly planned by the Contractor, with regard to maximum permissible loads for roads and bridges or other obstacles and detailed information has to be included in the Bid. **Industrial cranes are available in Fiji up to a maximum load rating of 100 Tonne for loading and unloading of the transformer.**

For movement, alignment and positioning of the main transformers on site the Contractor shall provide hydraulic jacks, heavy duty tank type steel rollers and other equipment required.

The installation site has limited space and movement limitations. The contractor shall carefully assess the site requirements during tender site visit and utilize the available means (Jack and Skid or Crawler Crane) at the time of installation to offload the transformers from the trailer and to install on the pad.

During the site visit if the contractor deems that the proposed site will not be able to accommodate two 20/25MVA Transformer, then EFL will construct only one pad at the proposed location and commission one of the transformers.

The second unit will be stored at Rokobili Substation or Cunningham Substation (to be determined during tender site visit). After the commissioning of the first unit EFL will decommission the existing two units,

demolish the pads and prepare new pads. Hence, the second unit will be transported later from the storage site, installed and commissioned. Hence, the contractor will need to assess this during tender site visit and advise EFL accordingly in their bid document.

Also note the contractor will then have to account for the cost of transportation to the storage site and back to Hibiscus Park Substation. Split installation charge will need to be accounted as well.

8.0 TEST AT MANUFACTURE'S WORK

8.1 GENERAL

- a. The Manufacturer shall carry out the tests listed below, together with such additional tests that the Employer considers that are reasonable to determine that the equipment complies with the specification. The cost of all tests and of such additional tests shall, unless otherwise agreed, be borne by Manufacturer.
- b. All material used in the manufacture of the equipment to be supplied shall be subjected to, and shall pass, such routine tests as are customary for these materials.
- c. Adequate notice of all tests shall be given to the Employer in order that these tests may be witnessed if required. As many tests as possible should be arranged together.
- d. Three copies of the Contactor's test certificates recording the results of all tests and inspections required by this specification should be supplied to the Employer. The test results shall include all raw data as well as adjusted figures.
- e. The Employer may agree to the omission of the whole or part of any type test upon submission of details of type test that have been carried out previously on identical or substantially similar equipment. The Contactor is to separately detail the cost of each of the type tests and the cost of any tests not performed shall be credited. These costs are to be submitted at time of tender.

8.2 Additional Tests to be carried out during Manufacture

The following additional tests shall be carried out during manufacture, before final assembly of the transformer. The Employer may require these tests to be carried out in the presence of the Employer's inspector.

8.2.1 Conductor Tests

A sample of conductor from each reel used shall be made available for testing. The profile edges of the conductor shall be checked for quality of finish.

8.2.2 Inter Strand Check

Once the windings have been dried out and compressed to their final dimensions a 500V insulation test between strands for paper covered conductor and 250V insulation test between strands for continuously transposed cable shall be carried out.

8.2.3 Harmonic Test as per IEC standard

8.2.4 Dimensional Checks of Windings and Ducts

The following measurements shall be made on each winding to confirm their compliance with the design drawings:

- a. Internal diameter;
- b. Outside diameter;
- c. Radial dimension of duct next to inside of winding;
- d. Radial dimension of duct next to outside of winding.

8.2.5 Polymerisation Tests of Insulation Samples before and after Dry-out

- a. Before and after the dry-out Degree of Polymerisation tests shall be performed on a sample of paper insulation taken from the sample roll. The Manufacturer shall remove the sample from the roll before dry-out, one half of which shall be kept by the Manufacturer and one half shall be provided to the Employer. On the completion of the dry-out, test shall be performed on a second sample of paper insulation taken from the sample roll, the Manufacturer shall keep one half and one half shall be provided to the Employer.
- b. Tests determining the extent of degradation of the life of the paper shall be carried out.
- c. The test method for Degree of Polymerisation shall be in accordance with ASTM D4243. The weight of each sample shall be 3 grams.
- d. The measured Degree of Polymerisation after dry-out shall not be less than 1100.

8.3 Main Transformers

Each of the transformers shall be subject to acceptance tests to be performed at the Contractor's premises (and at site) in order to verify their conformity with the guaranteed and other design data. The methods of testing shall be submitted for approval at least three months before testing. The transformers shall be completely assembled in every respect. All of the tests shall be performed with all original bushings installed. The tests shall be performed in accordance with the latest issues of the recommendations of the (International Electrotechnical Commission) IEC, in particular IEC 60076 and IEC 60060. The Contractor is obliged to submit a detailed test program (including detailed test connections for all dielectric tests) for approval in due time, prior to the tests (at least three months before testing). Detailed test schedules separately for each unit showing exactly when each of the tests will be carried out shall be submitted for approval at least six weeks prior to the tests. The following test shall be performed in the presence of the Employer/Employer's Representative:

8.4 Routine Tests

Routine test shall be according to the IEC 60076, part 1, clause 10.1.1.

- | | | |
|-------------------|---|---|
| Clause 10.2 | - | measurement of winding resistance at each tapping |
| Clause 10.3 | - | measurement of voltage ratio and check of phase displacement and vector group |
| Clause 10.4 | - | measurement of short-circuit impedance and load loss. This test shall be done on highest, nominal and lowest taps. |
| Clause 10.5 | - | measurement of no-load loss and current. |
| IEC 60076, part 3 | - | Dielectric routine tests |
| IEC 60076, part 3 | - | Insulation of Auxiliary wiring |
| IEC 60076, part 3 | - | Separate source AC withstand voltage |
| IEC 60076, part 3 | - | Induced AC voltage test |
| IEC 60076, part 3 | - | Partial discharge measurement before and after induced over voltage test |

The transformer shall be subjected to all the routine tests specified in IEC 60076-1 above and shall include the following:

8.5 Type Tests

Type test shall be conducted on the transformer according to the IEC 60076, part 1, clause 10.1.2.

8.5.1 Temperature rise test (IEC 60076-2)

- The transformer shall be subjected to a temperature-rise test. This shall be at the continuous rating associated with each mode of cooling, at the tap position giving maximum losses in accordance with IEC 60076-2.
- The transformer shall be temperature-rise tested for compliance with the requirements of Clause 2.1.1.
- The hot winding resistance measurements of the transformer shall commence no later than 30 seconds from supply shutdown at the end of the temperature-rise period.
- A check shall be made to ensure there is no overheating of the tank including flange bolts.

8.5.2 Dielectric type test (IEC 60076-3)

8.6 FACTORY ACCEPTANCE TEST

Special test shall be conducted on the transformers according to the IEC 60076, part 1, clause 10.1.3 –

- Dielectric special tests (IEC 60076 , part 3)
- Determination of capacitances windings-to-earth, and between windings.
- Determination of transient voltage transfer characteristics.
- Measurement of zero-sequence impedance(s) on three-phase transformers. This test shall be done on highest, nominal and lowest taps as specified in IEC 66007-1.
- Determination of sound levels (IEC 60551).

- f. Measurement of the harmonics of the no-load current IEC 60076-1 to determine the combined harmonic content of the magnetizing current. The tests shall be conducted at 90%, 100% and 110% of rated voltage. .
- g. Measurement of the power taken by the fan.
- h. Measurement of insulation resistance and polarisation index of the windings Insulation resistance of the transformer shall be measured between windings, and between windings and earth, at a minimum DC voltage of 5 kV using a test instrument capable of measuring a minimum of 500,000 megohms. The transformer's temperature shall be constant over the test period.
- i. Measurement of dissipation factor ($\tan \delta$) of the insulation system capacitances
- j. Efficiency and voltage regulation on load factors of 25%, 50%, 75% and 100%.
- k. Lightning Impulse Voltage test including lightning impulse chopped on tail test (LIC) (IEC 60076, part 3)
Each winding of the transformer shall be subjected to full wave and chopped wave lightning impulse tests in accordance with IEC 60076-3.
 - i. The order of the different impulse applications during testing shall be as follows:
 - a. One reduced full impulse
 - b. One 100% full impulse
 - c. One reduced tail chopped impulse
 - d. Two 100% tail chopped impulses
 - e. Two 100% full impulses
 - f. One reduced chopped impulse
 - g. One reduced full impulse.
 - ii. Impulse tests shall meet the following requirements:
 - a. The instant of chop on the full voltage test shall be within 0.1 microseconds of that on the reduced voltage test.
 - b. The applied voltage oscillograms shall show a virtual time of voltage collapse during chopping of not greater than 0.2 microseconds.
 - c. The oscillograph sweep times for the applied terminal voltage tests shall be:
 - A. Full wave: Not less than 50 μ s; not greater than 100 μ s
 - B. Chopped wave: Not less than 5 μ s; not greater than 1 μ s
 - C. The oscillograph sweep times for the fault detection current oscillograms of the winding under test shall be:
 - a. Full wave: Not less than 100 μ s; not greater than 300 μ s
 - b. Chopped wave: Not less than 10 μ s; not greater than 30 μ s.
 - D. The oscillograph sweep times for the fault detection ground current of the other winding shall be:
 - a. Full and chopped wave: Not less than 10 μ s; not greater than 30 μ s.
 - iii. The tap switch on the winding under test shall be set at the minimum turn position. When the other winding is being tested it shall be set in the maximum turn position. If this position is in conflict with the RSG determination then the scenario that produces the most extreme condition shall apply.
 - iv. The transferred voltages appearing at the line terminals of the other winding shall be recorded. The transferred voltage shall not be greater than the BIL of the winding that the impulse is transferred to. The method of measuring transferred voltage shall be by setting up the impulse generator with the voltage applied not greater than 50 % of the respective proof stress voltage. In all cases the applied voltages shall have a wave front of not more than 1.5 microseconds and a wave tail of not less than 40 microseconds.
- l. Insulation test of oil and measurement of dielectric strength of oil
- m. Dissolved gases analysis
- n. Sweep Frequency Response Analysis
- o. Pressure test of complete assembled transformer (tank, radiators, pipe work and all gas relays, pressure relief device, etc) over a period of 24 hours. During this period there shall be no leakage and after release of pressure no permanent deflection should be observed.

- p. Losses and Impedance shall be checked to prove compliance with the guarantees of no-load loss, no-load current and impedance voltage. The no-load loss, no-load current shall be measured at 90%, 100% and 110% of rated voltage at normal voltage. The load losses and impedance voltages at the maximum, principal and minimum tap positions shall be measured at not less than 50% of the ONAN current. The waveform of the excitation voltage and the excitation current shall be recorded and the excitation voltage and current shall be measured and recorded with r.m.s., average and peak instruments.
- q. Tap change operation tests as specified in IEC 60214. Core Frequency Voltage Withstand: The insulation between the core and the clamping framework shall be tested at 2.5 kV rms. for one minute.
- r. Insulation power factor shall be measured by Method II of ANSI/IEEE C57.12.90 and recorded in the test report. The measured values shall be 0.5% or less at 20°C ambient reference temperature.
- s. Partial discharge measurements carried out in accordance with IEC 60076-2.
- t. Noise Level
The transformer shall be subjected to a sound power level test in accordance with IEC 60551. The sound power level shall not exceed the value given in Tender.
- u. Pressure and Vacuum Withstand Tests
The transformer complete with conservator tank, cooling system and all other fittings including valves shall be pressure and vacuum tested as follows:

a) Pressure Tests

A hydraulic pressure test of 50kPa shall be applied to the transformer filled with oil. This test shall be applied for 24 hours without any oil leakage occurring. The conservator tank shall be tested for leaks in the same manner. The Manufacturer shall demonstrate that the equipment will satisfactorily withstand a pressure equal to the vent diaphragm release pressure.

b) Vacuum Tests

With the tank empty of oil, a full vacuum no greater than 1.0 mm Hg shall be applied for 2 hours. A string line shall be placed around the transformer and measurements taken before and after full vacuum to verify that no permanent distortion has taken place.

Sweep Frequency response Test on all tap positions

With the tank empty of oil, a full vacuum no greater than 1.0 mm Hg shall be applied for 2 hours and then the vacuum pump shall be disconnected at the tank. After another 2 hours, the vacuum shall not have risen to a value greater than 1.5 mm Hg.

The above tests shall not cause any measurable permanent distortion of the conservator or main tanks. Any distortion shall be rectified and the tests repeated. The test is deemed successful if no further permanent distortion occurs.

c) Distortion

The transformer, when completely assembled and filled with oil, shall be jacked up at each jacking point in turn such that the tank is lifted by 10 mm (measured at the pad being jacked).

There shall be no weld fractures.

There shall be no measurable permanent distortion of the tank or jacking pad.

8.7 Main Transformer Bushings

Each of the transformer bushings shall be subject to routine tests to be performed at the place of manufacture. All of the tests shall be performed on each bushing on an individual basis.

The tests shall be performed in accordance with the latest issues of the recommendations of the (International Electrotechnical Commission) IEC, in particular IEC 60137 and IEC 60060.

8.8 Routine Test

- a. Measurement of power factor
- b. Measurement of capacitance
- c. AC voltage withstand
- d. Partial discharge measurement

8.9 Type test

Type test reports shall be provided for bushings of the same type and rating as the bushings installed on the transformer covering the following:

- a. power factor and capacitance measurement
- b. Low frequency dry withstand voltage
- c. Power factor and capacitance check
- d. Wet withstand voltage
- e. Repeat power factor and capacitance measurement
- f. Impulse voltage withstand
- g. Repeat power factor and capacitance

8.10 MR Reinhausen VACUUM VACUTAP ON-LOAD DIVERTOR SWITCH Tap Changer

8.10.1 Routine test

Routine operations tests shall be done with the tap changer completely installed in the transformer. The following test shall be performed in the presence of the Employer/Employer's Representative:

- a. Ten complete cycles of operation of the ON-LOAD Divertor Switch tap changer with the transformer un-energised.

8.11 Type Test

Type test results shall be submitted for a same type of on-load tap changer with the same number of taps covering the following tests

- a. Temperature rise of contacts
- b. Short circuit current test
- c. Switching tests
- d. Mechanical endurance test
- e. Dielectric test

8.12 Site Tests

8.12.1 Transformers and Auxiliary Equipment

The following site tests shall be performed:-

1. Measurement of the excitation current at any star-connected winding with low voltage (AC, 3 phase) when the transformer is completely de-magnetised.
2. Measurements of voltage ratio at all tap positions.
3. Check of vector group.
4. Measurement of winding resistance at all taps.
5. Measurement of insulation resistance between the core and core tank at 2500 V DC.
6. Measurement of insulation resistance and polarization index at 5kV or 10kV DC.
7. Determination of capacitances windings-to-earth, and between windings.
8. Measurement of dissipation factor ($\tan \delta$) of the insulation system capacitances
9. Dissolved gases analysis
10. Sweep frequency response analysis (to be compared with the initial test carried out at the factory prior to dispatch) for minimum, maximum and normal operating tap.
11. Measurement of the dielectric strength of the insulation oil.
12. Applied over-voltage test at 2000V on AC wiring, control and supervision equipment
13. Functional test on control & supervision test.

14. Functional test of tap changer
15. Functional test of alarm and trip signals from all auxiliary protection (bucholz gas relays, winding temperature, oil temperature, pressure relief device, oil level indicators)
16. Visual checks.

Prior to commencing installation at site, the data from the impact recorders is to be extracted and analysed to assess any major shock/vibration incurred by the transformer. If there is evidence of a substantial impact on the transformer, a sweep frequency analysis will be carried out immediately to determine the extent of damage, followed by transformer examination. If the impact recorders do not show any substantial shock experienced by the transformers during transport, then the SFRA will be carried out after installation of the transformer.

8.12.2 Paint and Galvanising Thickness Tests.

The Manufacturer shall test and record the paint and galvanising thickness and may be required to demonstrate to the Employer's inspector that the thicknesses comply with the requirements of the specification.

8.12.3 Performance Tests

The following tests shall be performed on the transformer after final assembly. For the tests the transformer shall be as near as in-service as possible. If a transformer, or any part thereof, fails to meet the test criteria then the transformer shall be rejected at no cost to the Employer.

8.12.4 Test Order

The following type and special tests shall be carried out sequentially and in the following order with the transformer still hot:

- a) The temperature rise test.
- b) Impulse test.
- c) Separate source test.
- d) Induced withstand tests, including partial discharge.

Samples of the oil for the dissolved gas analysis (DGA) testing shall be taken before and after each of the above tests. The results of the DGA shall be supplied to the Employer.

9.0 PACKING

The transformer shall be carefully packed for transport and shipment in such a manner that it is protected from all dust and climatic conditions during loading, transport, unloading and subsequent storage in the open. Equipment shall be suitably packed and protected against vibration, movement and shock which may occur during loading and transport. Particular care in packing shall be taken when the apparatus is transported by road.

Upon delivery to site, the impact force readings from both impact recorders fitted in accordance with Clause 7.4 shall be supplied to the Employers Engineer for review. For all impact recorder readings in the range 1.0g, 2.0 g to 3.0 g, the main tank exterior shall be visually inspected by the Transformer Manufacturer upon arrival in Fiji Islands for signs of transport damage. A written report with photographs of the inspection shall be provided to the Employers Engineer.

For all impact recorder readings above 3.0 g, the main tank external and main tank interior shall be visually inspected upon arrival in Fiji Islands by the Transformer Manufacturer for signs of transport damage. The main tank interior inspection shall be performed via bushing and manhole access covers. A representative of the Employers Engineer shall also participate in the external and internal inspections. A written report with photographs of the inspection shall be provided to the Employers Engineer.

For all impact recorder readings above 3.0 g, the Transformer Manufacturer shall also request the Impact Recorder Manufacturer to review the readings to determine if the Impact Recorders were functioning correctly at the time of the readings. A written report of the Impact Recorder Manufacturer's review shall be provided to the Employers Engineer.

9.1 MAIN TANK

The transformer shall be delivered in its tank. The tank shall be made moisture proof by charging the tank with dry air under pressure, and an approved means of maintaining pressure in the event of slow leakage shall be provided. Dry air shall be to the appropriate industrial standard.

Details of charging pressure, and temperature and dew point (measured 48 hours after filling the transformer) shall be forwarded to the Employer with the shipping documents. Strong mechanical protection shall be placed over the pipe between the air container and the tank, to prevent it being damaged in transit.

9.2 ELECTRONIC IMPACT RECORDERS

Before dispatch from the site, the transformer shall be equipped with electronic impact recorders to monitor the impacts the transformer is subjected to during transportation. The impact recorders shall not be dismantled until the transformer has been delivered to site and final reading has been taken. The electronic impact recorders should have capability of recording shock and vibration history with date and time stamping, together with GPS coordinates and have provision for extraction of the logs so that the data can be analysed on either vendor's software, or on a spreadsheet format. The impact recorder's battery should have enough capacity to power up the device for a minimum of 3 months. Upon completion of the project the impact recorders will be handed over to EFL.

9.3 COMPONENTS AND SPARES

All transformer components and spares shall be packed securely within totally enclosed wooden crates and protected against corrosion. The wooden crates shall be strong enough to resist major impacts that can occur during shipping. The final packing arrangements shall be subject to the Employer's approval.

All spares shall be interchangeable with the original parts. Spare parts shall be packed separately in a case marked "Spares". Individual items shall be clearly labelled. The label shall include the transformer manufacturer's name, part number, and the contract number. Small, similar items shall be packed together in moisture-proof, suitably labelled bags. Each radiator shall be sealed with dry air.

Section 6 Form of Proposals and Appendices

Form of Tender

To: Mr. Sumeet Chetty
Acting Manager Procurement, Inventory & Supply Chain ,
Energy Fiji Limited
2 Marlow St, Suva, Fiji.

Contract No: _____

Gentlemen:

We have examined the Conditions of Contract, Employer's Requirements, Schedules, Addenda Nos _____ and the matters set out in the Appendix hereto. We have understood and checked these documents and have not found any errors in them. We accordingly offer to design, execute and complete the said Works and remedy any defects, fit for purpose in conformity with these documents and the enclosed Proposal, for the fixed lump sum of (in currencies, of payment) _____ or other such sums as may be determined in accordance with the terms and conditions of the Contract. The above amounts are in accordance with the Price Schedules herewith and are made part of this bid.

We confirm our agreement with the appointment of *(name proposed in Bid Data Sheet or during the clarification meeting of the First Stage bid)* as the Adjudicator.

We agree to abide by this Bid until _____ and it shall remain binding upon us and maybe accepted at any time before that date. We acknowledge that the Appendix forms part of our Bid.

If our bid is accepted, we will provide the specified performance security, commence the Works as soon as reasonably possible after receiving the Employer's Representative's notice to commence, and complete the Works in accordance with the above-named documents within the time stated in the Appendix to Technical Proposal.

Unless and until a formal Agreement is prepared and executed this Bid, together with your written acceptance thereof, shall constitute a binding contract between us.

We understand that you are not bound to accept the lowest or any bid you may receive.

Commissions or gratuities, if any, paid or to be paid by us to agents relating to this Bid, and to contract execution if we are awarded the contract, are listed below:

Name and Address of Agent	Amount and Currency	Purpose of Commission or Gratuity
_____	_____	_____
_____	_____	_____
_____	_____	_____

(if none, state "none").

We are, Gentlemen
Yours faithfully

Signature _____ in the capacity of _____ duly authorized to sign bids for and on behalf of _____

Address

Date _____

Appendix to Tender

[Note: with the exception of the items for which the Employer's requirements have been inserted, the following information must be completed before the Bid is submitted]

Sub-Clause		
Employer's name and address	1.1.2.1 & 1.8*	Energy Fiji Limited, Private Mail Bag, Suva, Fiji
Contractor's name and address	1.1.2.2 & 1.8	_____ _____
Name and address of the Employer's Representative	1.1.2.2 & 1.8	General Manager Network, EFL, Private Mail Bag, Suva, Fiji
Time for notice to commence	8.1	28 days
Time for Completion of the Works	1.1.3.4	18 months
Electronic transmission systems	1.8	Email & Facsimile
Confidential details	1.12	Nil
Time for access to the Site	2.2	5 days after the Commencement Date
Amount of performance security	4.2*	Ten (10%) of the Contract Price and in the proportions of currencies which the Contract Price is payable
Time for submission of programme	4.14	14 days after the issue of Letter of Acceptance
Normal working hours	6.5	8.00 am to 4.30pm, Monday to Friday
Liquidated damages for delay	8.6*	0.25 % of the Contract Price per day, in the proportions of currencies in which the Contract Price is payable
Limit of liquidated damages for delay	8.6*	Ten (10) % of the Contract Price
Total amount of advance payments	13.2*	Refer to Payment Schedule
Number of instalments	13.2	Two (2) upon submission of Advance Payment Guarantee
Start repayment of advance payment	13.2(a)	After receiving bank guarantee
Repayment amortization of advance Payment.	13.2(b)	30% (With bank guarantee)
Percentage of retention	13.3(c)*	TEN (5) % cash retention

Limit of Retention Money	13.3(c)*	TEN (5)% of the Contract Price
Minimum amount of Interim Payment Certificates	13.6*	Five (5)% of the Contract Price

If Sub-Clause 13.15 applies:

Payments in Local and Foreign Currencies	1.1.5.3 & 13.15
--	--------------------

Currency Unit	Amount Payable in such Currency
Local: _____ [name]	_____
Foreign: _____ [name]	_____
_____ [name]	_____

Amount of insurance for design	18.1	Full value of the Contract Price
Amount of third party insurance	18.3	FJD 3,000,000 or contractor to propose
Periods for submission of insurance:	18.5	
(a) evidence of insurance	*	Not later than Commencement Date.
(b) relevant policies	*	Fourteen (14) days after Commencement Date.
Number of members of Dispute Adjudication Board	20.3*	Three (3)
Arbitration rules	20.6*	International Chamber of Commerce, Rules of Arbitration
Number of Arbitrators	20.6*	Three (3)
Language of arbitration	20.6*	English
Place of arbitration	20.6	Fiji

Initials of signatory of Bid _____

Section 7 Sample Forms

Form of Contract Agreement

This Agreement made this ____ day of _____ 20 ____ between _____ of Energy Fiji Limited (hereinafter called "the Employer") of the one part and _____ of _____ (hereinafter called "the Contractor") of the other part

Whereas the Employer desires that the Works known as Supply and Installation of Transformers should be designed and executed by the Contractor, and has accepted a Bid by the Contractor for the design, execution and completion of such Works and the remedying of any defects therein.

The Employer and the Contractor agree as follows:

1. In this Agreement words and expressions shall have the same meanings as are respectively assigned to them in the Conditions of Contract hereinafter referred to.
2. The following documents shall be deemed to form and be read and construed as part of this Agreement:
 - (a) The Letter of Acceptance dated _____
 - (b) The Employer's Requirements
 - (c) The Addenda nos. _____
 - (d) The Bid dated _____
 - (e) The Conditions of Contract (Parts I and II)
 - (f) The completed Schedules, and
 - (g) The Contractor's Proposal.
3. In consideration of the payments to be made by the Employer to the Contractor as hereinafter mentioned, the Contractor hereby covenants with the Employer to design, execute and complete the Works and remedy any defects therein in conformity in all respects with the provisions of the Contract.
4. The Employer hereby covenants to pay the Contractor, in consideration of the design, execution and completion of the Works and the remedying of defects therein, the Contract Price or such other sum as may become payable under the provisions of the Contract at the times and in the manner prescribed by the Contract.
5. This Agreement shall come into effect on signing by both parties.

In Witness whereof the parties hereto have caused this Agreement to be executed the day and year first before written in accordance with their respective laws.

Authorized signature of Contractor
SEAL
(if any)

Authorized signature of Contractor
SEAL
(if any)

in the presence of:

in the presence of:

Name _____
Signature _____
Address _____

Name _____
Signature _____
Address _____

Form of Performance Security (Bank Guarantee)

To: Energy Fiji Limited
2 Marlow st, Suva
Fiji.

Tender Name: Design, manufacture transport, Supply and Installation of Two X 33kV/11kV, Dyn1, 50Hz, 20/25MVA Transformers for Hibiscus Park Substation.

Tender No: _____

WHEREAS _____ [name and address of Contractor] (hereinafter called "the Contractor") has undertaken, in pursuance of Contract No. _____ dated _____ to execute _____ [name of Contract and brief description of Works] (hereinafter called "the Contract");

AND WHEREAS it has been stipulated by you in the said Contract that the Contractor shall furnish you with a Bank Guarantee by a recognized bank for the sum specified therein as security for compliance with its obligations in accordance with the Contract;

AND WHEREAS we have agreed to give the Contractor such a Bank Guarantee;

NOW THEREFORE we hereby affirm that we are the Guarantor and responsible to you, on behalf of the Contractor, up to a total of _____ [amount of Guarantee] _____ [in words], such sum being payable in the types and proportions of currencies in which the Contract Price is payable, and we undertake to pay you, upon your first written demand and without cavil or argument, any sum or sums within the limits of _____ [amount of Guarantee] as aforesaid without your needing to prove or to show grounds or reasons for your demand for the sum specified therein.

We hereby waive the necessity of your demanding the said debt from the Contractor before presenting us with the demand.

We further agree that no change or addition to or other modification of the terms of the Contract or of the Works to be performed thereunder or of any of the Contract documents which may be made between you and the Contractor shall in any way release us from any liability under this guarantee, and we hereby waive notice of any such change, addition or modification.

This guarantee shall be valid until the date of issue of the Performance Certificate.

Signature and Seal of the Guarantor	_____
Name of Bank	_____
Address	_____
Date	_____

Form of Advance Payment Security (Bank Guarantee)

To: _____ [name of Employer]
_____ [address of Employer]
_____ [name of Contract]

Tender Name: Design, manufacture transport, Supply and Installation of Two X 33kV/11kV, Dyn1, 50Hz, 20/25MVA Transformers for Hibiscus Park Substation.

Tender No: _____

Gentlemen:

In accordance with the provisions of the Conditions of Contract, Sub-Clause 13.2 ("Advance Payment") of the above-mentioned Contract, _____ [name and Address of Contractor] (hereinafter called "the Contractor") shall deposit with _____ [name of Employer] a bank guarantee to guarantee its proper and faithful performance under the said Clause of the Contract in an amount of _____ [amount of Guarantee]
_____ [in words].

We, the _____ [bank or financial institution], as instructed by the Contractor, agree unconditionally and irrevocably to guarantee as primary obligator and not as Surety merely, the payment to _____ [name of Employer] on its first demand without whatsoever right of objection on our part and without its first claim to the Contractor, in the amount not exceeding _____ [amount of Guarantee]
_____ [in words].

We further agree that no change or addition to or other modification of the terms of the Contract or of Works to be performed thereunder or of any of the Contract documents which may be made between _____ [name of Employer] and the Contractor, shall in any way release us from any liability under this guarantee, and we hereby waive notice of any such change, addition or modification.

This guarantee shall remain valid and in full effect from the date of the advance payment under the Contract until _____ [name of Employer] receives full repayment of the same amount from the Contractor.

Yours truly, _____
Signature and Seal: _____
Name of Bank/Financial Institution: _____
Address: _____
Date: _____

Section 8 Schedules - Part I Schedule of Prices

10.0 NOTES ON SCHEDULES

The Schedules are intended to provide the Employer with essential supplementary information in an organized format. Examples of more commonly used Schedules are given herein. Others may be devised and added in accordance with the requirements of the Instructions to Bidders. All the Schedules are essential for bid evaluation and some in contract execution; they should all be incorporated in the Contract, and appropriate changes introduced with the approval of the Employer or its representative.

The schedules are to be completed and submitted as part of the Tender submission in accordance with the Instructions to Bidders Clause 13, Documents Comprising the Bid.

10.1 SCHEDULE OF PRICES & CONDITIONS OF PAYMENT

10.1.1 CONTRACT PRICE

The Contract Price is comprehensive in that, in consideration of the Contractor meeting all obligations, conditions and liabilities under the Contract, including the Contractor's allowance for the cost of supply of all labour, materials, plant, supervision required to complete the Contract Works, overheads and profit, subject only such adjustment as is provided for the Contract. The contract price shall be Supply and Install New Transformers.

10.1.2 BASIS OF SCHEDULES

Descriptions of various items contained in the Schedule of Prices are intended to be a complete definition of the scope of the Contract Works, for which reference shall be made to the Specification, Drawings, Basis of Payments and other Contract Documents. The items descriptions on the Schedule of Prices shall be used only for the purpose of calculating progress payments and for valuing variations.

10.1.3 BASIS OF PAYMENTS

The rate or cost of the items shall represent the total cost of designing (where appropriate), checking, approving, purchasing, constructing, installing, commissioning, training the Employer's staff, testing and providing as-built drawings and O&M manuals for the works unless separate items have been included for some of these activities.

10.1.4 PAYMENTS TERMS

All payments shall be due and payable by the Employer in accordance with the payments terms detailed below. The payments shall be made on completion of milestones as identified and agreed by both the Employer's Representative and the Contractor.

	Particulars	Milestone	Payment (%)
SUPPLY AND INSTALL NEW TRANSFORMERS			
1	Advance payment	As per clause 13.2 of Section 3 - Conditions of Particular Application (Bank Guarantee Required)	30%
2	Delivery of Plant	Upon completion of FAT and shipment to Fiji (Suva Port) with Bill of Lading Documents	60%
3	Installation and commissioning of new transformers including WHT	Upon completion of transportation, installation of transformers on pad, commissioning, rectification of defects and issuing of performance certificate	10%
4	Retention	12 months after issuing of performance certificate	Nil (B/G required)
TOTAL			100%

Offshore payment for **all services provided on-shore** (such as installation and commissioning) by the contractor is liable for taxation under the laws of Fiji. If the contractor is not a registered entity in Fiji, then a **withholding tax of 15%** will be levied by the Government of Fiji on all work carried out by the contractor related to installation and commissioning in Fiji. This amount will be deducted from the outward payments being made to the contractor. **The contractor shall therefore specify in the price schedules whether the bid price is inclusive of the 15% withholding tax.** Note that this will not be levied on the design, manufacture or supply of any plant or equipment.

The contract price will be subject to the applicable Non- Resident Withholding Tax ("NRWHT") which will be deducted by EFL upon payment to the supplier. This applies to the services carried on-shore. The NRWHT is claimable by the Supplier in Australia and EFL will provide the necessary tax deduction certificate to the supplier.

10.2 SCHEDULES OF RATES & PRICES

10.2.1 NOTES ON SCHEDULES OF RATES AND PRICES

1. The Schedules are divided into seven separate sections as follows:
 - 3.2 Plant and Equipment Including Mandatory Spare Parts
 - 3.3 Installation and Other Services
 - 3.4 Grand Summary
 - 3.5 Alternative Offer
 - 3.6 Bidders Tools & Equipment
 - 3.7 Recommended Tools and Spare Parts
 - 3.8 Rates for Variation
2. The Schedules do not generally give a full description of the plant and equipment to be supplied and the services to be performed under each item. Bidders shall be deemed to have read the Employer's Requirements and other section of the bidding documents and reviewed the Drawings to ascertain the full scope of the requirements included in each item prior to filling in the rates and prices. The entered rate and prices shall be deemed to include for the full scope as aforesaid including overheads and profit.
3. Bid prices shall be quoted in the manner indicated and in the currencies specified in the Instructions to Bidders in the bidding documents. For each item, bidder shall complete each appropriate column in the respective Schedules, giving the price breakdown as indicated in the Schedules. Prices given in the Schedules against each item shall be for the scope covered by that item as detailed in the Employer's Requirements, Drawings or elsewhere in the bidding documents.
4. Items left blank with be deemed to have been included in other items. The TOTAL for each Schedule and TOTAL of the Grand Summary shall be deemed to be the total price for executing the facilities and sections thereof in complete accordance with the Contract.
5. These schedules are intended primarily to provide information for bid evaluation but not intended to be used for the evaluation of work done for the purpose of interim payment. They may however, be used as a reference for the adjustment of the Schedule of Payment should the need arise.
6. These schedules can also be used as a basis to value variations of work done under the Proposal Sum.

10.3 PART A - PLANT AND EQUIPMENT INCLUDING MANDATORY SPARE PARTS

ITEM NO.	DESCRIPTION	Quantity	DDU FIJI Currency - ____		DDU FIJI Currency - FJD	
			Unit Rate	Total Amount	Unit Rate	Total Amount
A	NEW 33/11kV TRANSFORMERS – Design, Test, Supply & Freight					
A.1	33kV/11kV Transformers, 20/25 MVA ONAN Dyn1 (Inclusive of freight, insurance and transportation to site.)	2 Nos.				
A.2	2 x REG-DA Relays-Mounted and Wired in a RITTAL Panel					
A.3	Design Review – 2 EFL staff at the Factory					
A.4	Witness testing by EFL staff (2) at the Factory for Factory Acceptance Witness testing					
A.5	Mandatory Spares and other accessories	1 Nos.				
A.6	Impact Recorders for transportation	2 Nos.				
A.7	Tools & Equipment	1 Nos.				
TOTAL AMOUNT FOR PART A (Excluding Taxes & Duties)						

Note: Bidder may provide price in either foreign currency or FJD Currency.

10.4 PART B - INSTALLATION AND OTHER SERVICES – Local Component

ITEM NO.	DESCRIPTION	Quantity	Currency - ____		Currency - FJD	
			Unit Rate	Total Amount	Unit Rate	Total Amount
B	NEW 33/11kV TRANSFORMERS – Local Transportation, Installation & Testing					
B.1	Local Transportation & Erection on Site (Excluding Withholding Tax)	2 Nos.				
B.2	Installation of new 33kV/11kV Transformers, 20/25 MVA ONAN/ONAF Dyn 1, together with tap changer, SEL2414 equipment and other accessories on the constructed transformer pad.	2 Nos.				
B.3	Site Testing of the new transformers					
B.4	Training (Clause1.4)					
B.5	WHT(FIJI) 15%					
TOTAL AMOUNT FOR PART B (Including Withholding Tax)						

Note:

1. Bidder to take into account instructions stated in **Clause 7.4.4 - UNLOADING EQUIPMENT** as part of their Part B costing.
2. For Site Testing, the installation Engineer will be provided access to test equipment for majority of the site testing. Bidder to account for equipment cartage for test equipment not available with EFL.

10.5 GRAND SUMMARY

Part	DESCRIPTION	Total Price	Total Price
		Currency - _____	Currency - FJD
A	Plant and Equipment Including Mandatory Spare Parts & equipment and REG-DA Panel (Clause 10.3)		
B	Local Transportation, Installation and Other Service including WHT 15% (Clause 10.4)		
GRAND TOTAL (Part A + Part B)			

10.6 BIDDERS TOOLS & TEST EQUIPMENT

During the pre-commissioning and commissioning tests, specialised tools and equipment will be required to carry out the testing mentioned in Section 5 Technical Requirements clause 8.12 of this tender. The bidders shall provide a list of such tools and equipment that they will use and the associated cost including cost of freight. These are the tools and equipment which will be used for commissioning the transformers.

Item No.	Description	Model No.	Manufacturer	Cost

10.7 RECOMMENDED TOOLS & SPARE PARTS

As per clause 2.10 of the technical specifications, the bidder is required to provide a list of spare parts as recommended by the Manufacturer. These shall be divided into two categories i.e. Mandatory and Optional. Thus the bidders are required to provide two separate tables for the two categories.

Item	Description	Qty	Unit Price		Total Price	
			F/C	FJD	F/C	FJD
1	33kV Bushing	1				
2	11kV Bushing	1				
3	PRD Device	1				
4	SK1 Relay for REG-DA Relay	2				
5	PT100 Temperature Probe with tail	2				
6	Silica Gel Breathers for Cable Box	4				
7	MESSKO® MTRAB® . Dehydrating breather DB200 with Din flange	4				

10.8 RATES FOR VARIATION

The Contractor shall aim to carry out the project without any variations. However, if unforeseen circumstances and event warrant any variation, the Contractor shall only proceed with a written approval from the Employer's Representative. The agreed price variation shall be documented.

The rates stated in this schedule shall be applicable to variations ordered by the Employer's Representative and not covered by the Schedule of Prices. These rates shall be deemed to include the cost of construction facilities, professional and technical services, royalties, taxes, transport of equipment, labour and other changes necessary to perform the work. The Contractor shall not be entitled to any allowance above unit rates stated in the schedule by reason of any amount of work being required under such items during the currency of the Contract.

10.8.1 Materials

Materials required for variations or day work shall be paid for on the basis of the net quantities actually used in accordance with the Employer's Representatives. Payment will be at the cost on site based on evidence of purchased prices after deductions of all trade and bulk discounts, transport, and any other charges applicable to the materials plus the percentage stated below to cover contractor's profit and overheads. Materials supplied by the Contractor will be at prices to be agreed, due regard being paid to the prices for similar materials if supplied from outside sources.

10.8.2 Labour

Payment of labour shall be in accordance with the table of hourly rates below which shall include Contractor's profit, overheads, superintendence, insurance, time keeping and all clerical and office work and use of hand operated tools and all incidental charges whatsoever. The time of technicians or leading hands working with the crews will be paid for at rates stated but the time of the supervisors and foremen shall be covered by the overhead component of the hourly rates.

Item No.	Grade of Officer/Workman	Rate/hour F/C	Rate/hour FJD

% for Cost of Materials

Section 9 Schedules - Part II Schedule of Supplementary Information

11.0 Technical Parameters

11.1 MANUFACTURERS, PLACES OF MANUFACTURE & TESTING

ITEM	RECOMMENDED MANUFACTURER	BIDDER'S PROPOSAL	
		PLACE OF MANUFACTURE	PLACE OF TESTING & INSPECTION
33/11kV TRANSFORMER			
Transformer Complete			
Windings			
33 kV terminal	ABB Sweden		
Neutral terminal	ABB Sweden		
11 kV terminal	ABB Sweden		
33kV & 11kV cable end box			
33kV and 11kV Insulators	ABB Sweden Micafil		
ON LOAD Vacuum Divertor Switch	MR Reinhausen		
Copper	SAM DONG KOREA		
Core parts	JFE Japan/ Nippon		
Tanks			
Radiators	Menk USA		
Oil level indicators	MR Reinhausen		
Oil Valves			
Pressure relief device	MR Reinhausen / Qualitrol		
Dehydrating breather	Cedaspe VE Model		
Alarm devices			
Gas and Oil actuated relays	MR Reinhausen		
Temperature Monitoring	SEL2414		
Transformer Fan & Controller	ZHEIL ABEGG		

11.2 TECHNICAL PARTICULARS AND GURANTEES – ELECTRICAL WORKS

11.2.1 20/25MVA 33/11kV TRANSFORMER

	<i>Item</i>	<i>Units</i>	<i>Required</i>	<i>Tendered</i>
(a)	RATING & PERFORMANCE			
1.	Manufacturer's Name			
2.	Manufacturer's Address			
3.	County of Manufacture			
4.	Type number			
	Delivery and off-loading			
5.	a. Transformer delivered to		Hibiscus Park Substation	
	b. Spares delivered to		Hibiscus Park Substation	
	c. Delivery effected on	Date		
	Type of Construction			
6.	a. Type (core or shell)			
	b. Number of limbs			
	c. Type of Cooling			
7.	Anti- corrosion design classification		Severe marine	
	Rated Power and continuous rating			
8.	ONAN	MVA	20	
	ONAF	MVA	25	
	Nominal rated voltage on principal tapping:			
9.	a. HV	kV r.m.s.		
	b. LV	kV r.m.s.		
10.	Vector Group		Dyn1	
11.	Number of phases		3	
12.	Number of Windings		2	
13.	Applicable Standard – IEC		60076	

14.	System maximum voltage for both windings Um	HV	36 kV	
		LV	12 kV	
15.	Termination Type			
	a. HV			
	b. LV			
	c. Neutral			
16.	Insulation type	HV	Graded	
		LV	Uniform	
17.	Highest Voltage for equipment	HV	36 kV	
		MV	12 kV	
18.	Winding Insulation Level	HV	170 – 95	
		N	95 – 38	
		LV	95 – 28	
19.	Transformer Nominal ratio		33/11 kV	
20.	Short circuit withstand fault level at terminals of			
	36kV busbars	kA	31.5	
	12kV busbars	kA	31.5	
21.	Type of Cooling		ONAN	
22.	External cooling medium		Air forced (FAN)	
23.	Service conditions :			
	Altitude not exceeding	m	300	
	Air temperature not exceeding	°C	50	
	Average air temperature in any one year not exceeding	°C		
	In any one day	°C	38	
	Average in one year	°C	30	
24.	Divertor Switch ON-LOAD Tap Changer		MR Reinhausen – Vacuum	
	(A) Type			
	(B) Category of voltage control		CFVV	
	(C) HV or LV winding		HV	
	(D) Range (+ & -)	%	+ 5% to -12.5%	
	(E) Step size	%	1.25	

	(F) Power frequency withstand test voltage between first and last contacts of the selector switch between any two adjacent contacts of the selector between diverter and switch contacts	(kV)		
	(G) Type test certificate reference			
25.	Size of tapping step with position nos.			
26.	Approximate ONAN rating	MVA		
27.	Hot spot temperature rise at CMR under service and at 30°C ambient temperature	°C		
28.	Top oil temperature rise (average daily ambient air temperature 32°C)			
	(A) CMR	°C		
	(B) ONAN rating	°C		
29.	Maximum hot spot temperature when loaded according to IEC 60354	°C		
30.	Winding hot spot temperature on emergency overload not exceeding	°C		
31.	Flux density in iron at normal voltage and frequency and at normal ratio - (no load).		1.5T	
	(A) Core	Tesla		
	(B) Yokes	Tesla		
32.	Magnetising current (approx) at nominal ratio and			
	at 0.9 x nominal voltage	%		
	at 1.0 x nominal voltage	%	0.25	
	at 1.1 x nominal voltage	%		
	at 1.2 x nominal voltage	%		
33.	Guaranteed Losses at nominal ratio			
	(A) No Load losses	kW		
	(B) Copper losses at CMR	kW		
	(C) Auxiliary losses at CMR	kW		
34.	Regulation at 75°C and normal ratio -			
	(A) At unity power factor	%		

	(B) At 0.8 lagging power factor	%		
35.	Impedance voltage at 75°C and CMR. Between HV and LV Windings at Tap			
	Maximum	%		
	Nominal	%	~12.00	
	Minimum	%		
36.	Equivalent circuit zero sequence impedance between HV and LV windings			
	Maximum Tap (1)	Ω/phase		
	Nominal Tap (6)	Ω/phase		
	Minimum Tap (16)	Ω/phase		
37.	Zero sequence impedance as a Percentage of U_n^2/IM			
	Maximum Tap (1)	%		
	Nominal Tap (6)	%		
	Minimum Tap (16)	%		
38.	Maximum current density in windings at C.M.R.			
	(A) HV Winding	A/mm ²		
	(B) LV Winding	A/mm ²		
39.	Short circuit current that the transformer is designed to withstand, per unit (p.u.) of r.m.s. rated current			
	a. HV	p.u.		
	b. LV	p.u.		
40.	No load loss of Principal tapping			
	a. At $1.00U_n$	kW		
	b. At $1.10U_n$	kW		
41.	Efficiency	%	99	
42.	Continuous On-line Bushing Monitoring Equipment:			
	Manufacturer's Name			
	Manufacturer's Address			
	Equipment Model			
	List type of parameters which can be measured			
	Communication options			
	Number of monitoring channels			
	Rated voltage	V		

	Rated Current	A		
	Frequency	Hz	50	
	Power	W		
43.	Digital Temperature Monitoring Equipment:			
	Manufacturer's Name		SEL2414 or equivalent	
	Manufacturer's Address			
	Equipment Model			
	Number of inputs			
	Number of outputs			
	Number of fiber optic sensor probes			
	Tank wall plate assembly		Welded on tank	
	Number of optical feedthroughs			
	Communications options			
	Rated voltage	V		
	Frequency	Hz	50	
	Power	W		

	<i>Item</i>	<i>Units</i>	<i>Required</i>	<i>Tendered</i>
(b)	CONTROL CIRCUITS			
1.	Type of controls for cooler			
2.	Whether automatic control required and the reference voltage (VT output line to line)	V	Yes 110 V AC 50 Hz	
3.	Whether load compensation required on the AVR.		N/A	
4.	Whether separate remote control panel required		No (use existing)	
6.	DC supply (control voltage) :			
	Nominal	V	110	
	Maximum float voltage	V	125	
7.	AC supply voltage for tap changer operating motor 3 phase.		415V	
8.	Whether provision for supervisory control required, including AVR setting		YES	
9.	Whether marshalling kiosk required		YES	
10.	Number of transformers for which automatic control is to be provided		All	
11.	Transformer terminals for line and neutral			
	(i) HV line		Cable box	
	(ii) Neutral		Cable box	
	(iii) LV line		Cable box	
12.	Accommodation of tank for outdoor weatherproof HV neutral current transformers		YES	
13.	Pollution category of bushings High-53.7mm/kV based on system highest voltage	mm/kV		

	<i>Item</i>	<i>Units</i>	<i>Required</i>	<i>Tendered</i>
(c)	COOLING			
1.	Minimum number of radiators per transformer			
2.	Maximum rating of each radiator as percentage of total loss at CMR			
(d)	GENERAL			
1.	Type of oil preservation system		Dehydration	
2.	Whether wheels, skid or flat bottom base required		Flat bottom	
3.	Whether anti-vibration pads required		Yes	
4.	Transformer sound pressure acceptance level	dB		
(e)	DETAILS OF CONSTRUCTION			
1.	Types of winding -			
	(A) HV			
	(B) MV			
2.	Material of Insulation			
	(A) HV Windings			
	(B) MV Windings			
3.	Insulation of tapping connections			
4.	Insulation of -			
	(A) Yoke bolts.			
	(B) Side plates.			
5.	Winding connections brazed or crimped Specify material (winding material and the joint material)			
6.	Is facility provided for adjustment of axial pressure on windings?	Yes/No		
7.	Thickness of transformer tank			
	(A) Sides	mm		
	(B) Bottom	mm		

8.	Material used for gaskets for oil tight joints.			
9.	Top Cover flange:-			
	Level: Low/High			
	Joint: WELDED/GASKETTED			
10.	Core design			
	a) manufacturer of core steel:			
	a. grade and thickness of core steel	Grade/mm		
	b. number and length of limbs	No./mm		
	c. core diameter	mm		
	b) cross sectional area of:			
	1) wound limbs	mm ²		
	2) yoke	mm ²		
	3) unwound limbs	mm ²		
	c) distance between core limb centres	Mm		
	d) total core mass	Kg		
	e) design flux density at U_n for:			
	a. yoke	T		
	b. limb with winding	T		
	c. volts per turn at the above flux densities	V		
	f) magnetizing current, at rated frequency, on principal tapping, as a percentage of rated current at maximum HV rating:			
	a. at 0.90 U_n	%		
	b. at 1.00 U_n	%		
	c. at 1.10 U_n	%		
	g) load loss (I^2R + stray) at 75°C and at maximum HV rating with LV fully loaded:			
	a. on principal tapping	kW		
	b. on extreme plus tapping	kW		
	c. on extreme minus tapping	kW		
11.	Transformer Cooling Fans			
	a. Voltage	V		
	b. Power per fan	kW		
	c. Current per fan	A		

	d. No. of fans	No.	2	
12.	Ohmic impedance at 75°C and rated frequency based on maximum rated power of HV winding: HV/LV:			
	a. on principal tapping	%		
	b. on extreme plus tapping	%		
	c. on extreme minus tapping	%		
13.	Tolerances applicable to guaranteed impedances. HV/LV:			
	a. on principal tapping	%		
	b. on extreme plus tapping	%		
	c. on extreme minus tapping	%		
14.	Temperature rises at altitude of 1000m:			
	a. top oil			
	b. windings (by resistance)			
	c. hot spot			
15.	Maximum acoustic sound level			
16.	Winding design: Cross-sectional diagram of the windings showing relative position to the core, dimensioned to indicate inner and outer diameters and axial length of each coil. (Supply on separate sheets.)			
17.	Indicate, per coil, the following: a) type (i.e. multilayer helix) b) number of turns c) conductor size, number and configuration d) number and width of support spacers per turn e) total conductor mass f) dry insulation mass			
18.	Give details of processing of the active part (core and windings) making reference to temperatures, time, vacuum levels and clamping pressures. Include sizing of windings as part of the processing. (Supply on separate sheets.)			
19.	Impulse withstand test voltage for:			

	a) HV b) LV			
20.	Sixty-second, separate source: a) HV b) LV			
21.	Induced over voltage withstand test voltages: a) HV to earth b) LV to earth c) between terminals HV to HV d) between terminals LV to LV e) test frequency f) test duration			
22.	Impulse withstand test voltage of main terminal bushings at sea level (1.2/50µs): a) HV b) LV c) LV Neutral			
23.	Sixty-second, power-frequency withstand test voltage to earth: a) HV b) LV c) LV Neutral			
24.	Total creepage distance: a) HV b) LV c) LV Neutral			
25.	Protected creepage distance: a) HV b) LV c) LV Neutral			
26.	Oil quantities: a) transformer tank b) conservator c) radiators d) tap-changer			

	e) total			
27.	Masses: a) mass of core and windings b) mass of core steel c) mass of winding copper (insulation excluded) d) mass of tank and fittings e) mass of coolers f) mass of oil g) total mass h) greatest transport mass			
28.	Filling medium for transport			
29.	Overall dimensions of complete unit: a) height b) length c) width			
30.	Overall dimensions of tank only: a) height b) length c) width			
31.	Overall dimensions of coolers only: a) height b) length c) width			
32.	Tank and cooler material thickness: a) sides b) bottom c) top d) conservator e) cooler tubes f) pressed-sheet radiators			
33.	Safe withstand vacuum at sea level			
34.	Bushings type, ratings and dimensions (attach data sheets): a) HV b) LV			

	c) HV/LV/Neutral			
35.	Fan Motors: a) make b) type			
36.	Nominal 50 Hz ratings of tap-changer: a) voltage b) current			
37.	Lightning impulse insulation level (1.2/50 μs full wave) of tap-changer: a) phase-to-ground b) phase-to-ground			
38.	Tap-changer 50 Hz insulation level withstand: a) phase-to-ground b) phase-to-phase			
39.	Nominal voltage and current rating of tap-changer contacts: a) selector b) selector switch c) diverter switch			
	Nominal voltage and current rating of tap-changer transition resistor			
40.	Tap-changer driving motor: a) type of driving motor b) power c) voltage d) current			
41.	Resulting no-load voltage appearing: a) on principal tapping b) on extreme plus tapping c) on extreme minus tapping			
42.	Have type test certificates been submitted with the tender for approval? If no, it will be assumed that no type tests for identical units are available.			

43.	Actual maximum overall dimensions of the transformer (including surge arresters and their mounting brackets): a) height b) length c) width			
44.	Guaranteed loss values: a) no load current with rated voltage on secondary winding b) no-load loss at rated voltage c) load loss at ONAN rating d) load loss at ONAF rating			
45.	Are there any limitations in the performance of the required tests? If yes, state limitations			

	<i>Item</i>	<i>Units</i>	<i>Required</i>	<i>Tendered</i>
(f)	RADIATORS VALVES & FANS			
1.	Thickness of radiator plates and/or cooling tubes.	mm		
2.	Valve type/material:			
	75mm and below			
	above 75mm			
3.	Equipment for ONAN cooling state (A) or (B) -		A	
	(A) Radiator on main tank			
	(B) Separate cooler bank			
4.	Number of cooling air blowers per transformer		2	
5.	Speed of air blowers and air flow	rpm/m ³ per min		
6.	Rating of each air blower motor	kW		
7.	Starting current of each blower motor,	A		
(g)	OIL VOLUMES & WEIGHTS			
1.	Total oil required including cooler system	Litres		
2.	Volume of oil to fill transformer to above the top yoke.	Litres		
3.	Total volume of conservator	Litres		
4.	Volume of oil in conservator between highest and lowest visible	Litres		
5.	Weight of core and winding assembly	Tons		
6.	Weight of each oil cooler bank complete with oil if mounted separately from transformer	Tons		
7.	Total weights of complete transformers, including attached coolers, voltage regulating equipment, all fittings and oil	Tons		
8.	Weight of transformer arranged for transport	Tons		

	<i>Item</i>	<i>Units</i>	<i>Required</i>	<i>Tendered</i>
(h)	TRANSFORMER OIL			
1.	Manufacture, type and class of oil to BS 148-1972	mm		
(i)	TRANSFORMER PARTS SUBJECT TO SHORT-CIRCUIT TEST			
1.	Brief description of Transformer or parts thereof subjected to short circuit test for which short-circuit calculations are available.	Yes/No		
(j)	TRANSFORMER BUSHING			
1.	Manufacturer			
2.	Insulator material (solid/oil-paper):			
	a. HV bushing			
	b. Neutral bushing			
	c. MV bushing			
3.	Manufacturer's type reference and rated voltage			
4.	Rated current			
	a. HV bushing			
	b. Neutral bushing			
	c. MV bushing			
5.	Manufacturer of porcelain			
6.	Length of insulator (overall).			
	a. HV bushing	mm		
	b. Neutral bushing	mm		
	c. MV bushing	mm		
7.	Weight of insulator.			
	a. HV bushing	kg		
	b. Neutral bushing	kg		
	c. MV bushing	kg		
8.	Electrostatic capacity of complete bushings.			
	a. HV bushing	pF		
	b. Neutral bushing	pF		
	c. MV bushing	pF		

9.	Dry lightning impulse voltage withstand. (1.2/50 wave)			
	a. HV bushing	kV		
	b. Neutral bushing	kV		
	c. MV bushing	kV		
10.	50Hz dry voltage withstand			
	a. HV bushing	kV		
	b. Neutral bushing	kV		
	c. MV bushing	kV		
11.	50Hz wet withstand voltage without arcing horns			
	a. HV bushing	kV		
	b. Neutral bushing	kV		
	c. MV bushing	kV		
12.	Total creepage distance of shed (specified minimum 25mm/kV based on maximum system voltage)			
	a. HV bushing	mm		
	b. Neutral bushing	mm		
	c. MV bushing	mm		

11.3 TIMES FOR DELIVERY & COMPLETION AND CONTRACT COMPLETION TIMES

11.3.1 TIMES FOR DELIVERY & COMPLETION

The individual dates are all contractually binding.

The times given include all necessary equipment to enable the respective circuit or item of plant to be completely commissioned and put into commercial operation, together with such other associated equipment, e.g. bushing monitoring equipment, etc. as well ensure that subsequent shut-downs are unnecessary or at least only of a temporary or short time nature.

The dates assume an order is placed by Week No. 1.

Key to dates be provided as follows.

- D - Target completion dates planned by EFL
- C - Construction (installation and commissioning) date guaranteed by contractor.
- B - Shipping completion dates guaranteed by contractor.
- A - Earliest date by which access is required by the contractor.

Site	A	B	C	D
	Earliest access permitted Week No.	Week No.	Week No.	Week No.
Two x 33/11 kV Transformers				

11.4 DEPARTURES FROM SPECIFICATIONS

(To be completed by the Contractor)

All deviations shall be forwarded in the format given below. Any details that will lead to deductions of final Bid price shall not be inserted.

Section	Clause No.	Proposed Deviations

11.5 MANUFACTURERS' STATEMENT OF EXPERIENCE

Bidders are to complete this schedule giving details of substation contract of the same type of construction as this contract and which they have completed or which are in the course of completion by them.

Country		
System Voltage kV		
Type of Construction		
Employer		
Consultant		
Capacity of Power Transformer (MVA)		
Contract Award Date		
Contractual Completion Date		
Actual Completion Date		
Contract Value		

11.6 CONTRACTOR HEALTH & SAFETY PLAN

The bidder shall complete the following sub-sections to provide details in relation to the Health and Safety plans for the project.

11.6.1 CONTRACT DETAILS

Contractor Name: _____
 Contractor Address: _____
 Contractor Representative: _____
 Contract Description: _____
 Location of Works: _____
 Timing of Works (approximate): Start Date: _____ End Date: _____

11.6.2 RESPONSIBILITIES

Name	Position Held	Safety Responsibilities	Contact Number (Direct)

11.6.3 EMERGENCY CONTACT DETAILS

Contact	Name	Position	Contact Number (Direct)
First Contact			
Second Contact			
Third Contact			
Fourth Contact			

11.6.4 SCOPE & TASK DETAILS

List Major Tasks

11.6.5 RISK ASSESSMENT

Risk assessment is a fundamental tool in management of risk. It involves the identification of hazards and control measures. Describe how you plan to carry out this process for this particular application contract.

--

11.6.6 SAFE WORK PROCEDURES

After completing the risk assessment, you must compile a safe system of work describing how you plan to control the hazards you have identified. Complete the following section outlining how you will ensure that all employees and subcontractors understand the Safe Work Procedures (SWP). Also attach copies of the relevant SWP.

11.6.7 PERSONAL PROTECTIVE EQUIPMENT

Where risk assessment identifies the need for personal protective equipment (PPE), then PPE must be made available. List down below the PPE you will require for this project.

11.6.8 ACCESSING SITE/TIMES OF WORK

If work is going to be carried out at EFL premises, then it is important to determine when you will be accessing the Site. You may need to sign a PASS and sign in and out. This will avoid conflicts with other activities which may be continuing on site during contract works. Describe below your site access requirements.

11.6.9 FENCING & SEPARATION OF WORK

In order to protect our employees as well as general members of the public, the work areas should, so far as is possible, be physically isolated with barriers like bollards, cones, tapes, netting, etc. Describe below how you will fence or separate your work.

11.6.10 SIGNS AND WARNINGS

Sufficient signs should be erected or placed so that adequate warning is afforded around the worksite. Describe the kinds of notices you will be putting up and places where you will be putting this.

11.6.11 GENERAL STORAGE & DISPOSAL OF WASTE

Describe below what waste you anticipate producing and how you plan to store and/or dispose off waste. You must take into account the nature of the waste e.g. hazardous/flammable.

11.6.12 FIRST AID & INJURY MANAGEMENT

A first aid program for contractors is outlined in EFL Safety Manual. Please describe below any additional first aid needs and specific Injury management process for this contract.

11.6.13 EMERGENCY PROCEDURES

Identify specific emergency procedures or equipment required for the contract.

11.6.14 INCIDENT REPORTING & INVESTIGATION

Describe how incidents will be reported and investigated during the contract.

11.6.15 SPECIALISED WORK OR LICENSING

List any special licences required for the contract.

11.6.16 TRAINING & INDUCTION REQUIREMENTS

Training and inductions for contractors are to be completed in accordance with the EFL Training requirements. List any training required for the contract works in relation to safety, for example safe procedure training and attach training certificates:

11.6.17 SAFETY MONITORING

List any ongoing inspections, hazards management or incident reporting or investigation processes to be used during the works, if relevant.

Describe below your site access requirements.

11.6.18 SUBCONTRACTOR MANAGEMENT

Complete the attached Subcontractor List detailing the subcontractors to be used and the details of the subcontractor management:

Sub-Contractor Name	Sub-Contractor Representative Name	Description of Work	Date of Local Induction

11.7 PLANT & EQUIPMENT REGISTER

Complete the following table:

Type	Registration Include: Design, Design No. Item, Item No.	Purpose (Use on Site)	Inspection Date and Frequency	Inspected by

Contractor Signature: _____
Date: _____

11.8 CONTRACTOR CHEMICAL REGISTER

Complete the following table:

Product Name	Hazard	Controls Required	Location	Quantity

Contractor Signature: _____

Date: _____

11.9 OTHER DOCUMENTS & DRAWINGS TO BE SUBMITTED WITH BID

As a minimum requirement to be considered for technical evaluation, the following documents & drawings shall be submitted with the Bid:

- 1.1 Typical plan and section drawings of transformer.**
- 1.2 Foundation drawings of transformer.**
- 1.3 Manufactures Technical Broachers type number, reference number and Drawings showing details of construction and dimensions of :-**
 - a) Power Transformers.
 - b) Bushings (33kV and 11kV)
- 1.4 Typical arrangement drawing of transformer marshalling kiosk.**
- 1.5 Control and wiring drawings of auxiliary relays (transformer temperature monitor, bushing monitor, oil and gas relays, etc.).**
- 1.6 Cross section drawings of transformer terminal boxes and terminal sealing ends.**
- 1.7 Independent type test certificates for,**
 - a) Power Transformers.
- 1.8 General bar chart of the design, manufacturing, shipping, erection and commissioning schedule clearly showing the dated.**
- 1.9 Evidence of Bidder's experience in works similar to this.**
- 1.10 Evidence of Bidder's subcontractor's experience in works similar to those subcontracted.**
- 1.11 Certificates issued by an independent International Organization to ensure compliance with the ISO 9001:2000 standards by Bidder and manufacturers.**
- 1.12 List of standards the Bidder intends to follow for the electrical works.**
- 1.13 Evidence of Manufacturer's experience in manufacturing comparable type of equipment or equivalent as offered under this contract.**
- 1.14 Descriptive information for equipment being offered including:**
 - a) List of recommended spare parts with prices.
 - b) List of special tools or fixtures required for installation, testing, maintaining and operating the equipment
 - c) List and cost of special tools, lifting devices required for installation, operation and maintenance.
 - d) List of exceptions to and deviations from this specification. All exceptions shall be clarified and separately itemized. It shall not be necessary for the employer to examine the standard literature and documents of the manufacturer to determine the existence and extent of any exceptions or deviations from this specification.
 - e) Evidence of field service experience of main equipment.

11.10 TENDER SUBMISSION CHECK LIST

The Bidders must ensure that the details and documentation mention below must be submitted as part of their tender Bid

Tender Number _____

Tender Name _____

1. Full Company / Business Name: _____

(Attach copy of Registration Certificate)

2. Director/Owner(s): _____

3. Postal Address: _____

4. Phone Contact: _____

5. Fax Number: _____

6. Email address: _____

7. Office Location: _____

8. TIN Number: _____

(Attach copy of the VAT/TIN Registration Certificate - Local Bidders Only (Mandatory)

9. FNPF Employer Registration Number: _____ **(For Local Bidders only) (Mandatory)**

10. **Provide a copy of Valid FNPF Compliance Certificate (Mandatory- Local Bidders only)**

11. **Provide a copy of Valid FRCS (Tax) Compliance Certificate (Mandatory Local Bidders only)**

12. **Provide a copy of Valid FNU Compliance Certificate (Mandatory Local Bidders only)**

13. Contact Person: _____

I declare that all the above information is correct.

Name: _____

Position: _____

Sign: _____

Date: _____

Tender Submission - Instruction to bidders

Bidders are requested to upload electronic copies via Tender Link by registering their interest at: <https://www.tenderlink.com/efl>

EFL will not accept any hard copy submission to be dropped in the tender box at EFL Head Office in Suva.

This tender closes at 4.00pm (1600hrs) on Wednesday 23rd April, 2025.

For further information or clarification please contact our Supply Chain Office on phone **(+679) 3224360** or **(+679) 9992400** or email us on tenders@efl.com.fj

The bidders must ensure that their bid is inclusive of all Taxes payable under Fiji Income Tax Act. Bidders are to clearly state the percentage of VAT that is applicable to the bid prices.

The lowest bid will not necessarily be accepted as the successful bid.

The Tender Bids particularly the “Price” must be typed and not hand written.

Any request for the extension of the closing date must be addressed to EFL in writing three (3) working days prior to the tender closing date.

Tender Submission via email or fax will not be accepted.