



# Nauru Utilities Corporation

## Load Flow and Fault Study

Nauru Utilities Corporation

3 September 2024

→ The Power of Commitment



**GHD Pty Ltd ABN 39 008 488 373**

180 Lonsdale Street, Level 9

Melbourne, Victoria 3000, Australia

**T** +61 3 8687 8000 | **F** +61 3 8732 7046 | **E** melmail@ghd.com | **ghd.com**

|                         |                                                                                                                                                           |
|-------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Printed date</b>     | 10/09/2024 8:20:00 AM                                                                                                                                     |
| <b>Last saved date</b>  | 4 September 2024 1:42 PM                                                                                                                                  |
| <b>File name</b>        | https://projectsportal.ghd.com/sites/pp02_02/naurusolarpic/ProjectDocs/12556753-GHD-01-00-RPT-EL-0001 - Load Flow and Fault Study DRAFT - Revised_v3.docx |
| <b>Author</b>           | Amit Datta                                                                                                                                                |
| <b>Project manager</b>  | Ian Dinh                                                                                                                                                  |
| <b>Client name</b>      | Nauru Utilities Corporation                                                                                                                               |
| <b>Project name</b>     | NUC Solar PIC                                                                                                                                             |
| <b>Document title</b>   | Nauru Utilities Corporation   Load Flow and Fault Study                                                                                                   |
| <b>Revision version</b> | Rev B                                                                                                                                                     |
| <b>Project number</b>   | 12543852                                                                                                                                                  |

#### Document status

| Status Code | Revision | Author        | Reviewer |           | Approved for issue |           |      |
|-------------|----------|---------------|----------|-----------|--------------------|-----------|------|
|             |          |               | Name     | Signature | Name               | Signature | Date |
| S3          | A        | A Datta       | C Morris |           | M. Jones           |           |      |
| S4          | B        | E Del Rosario | I Ziari  |           | A. Spencer         |           |      |

© GHD 2024

This document is and shall remain the property of GHD. The document may only be used for the purpose for which it was commissioned and in accordance with the Terms of Engagement for the commission. Unauthorised use of this document in any form whatsoever is prohibited.

# Executive summary

Nauru, a Pacific Island country, has approximately 13,300 residents. It predominantly sources its energy through diesel power generators. About 5% of its current energy demand is sourced from renewable energy of which all are solar Photovoltaic (PV) installations. The Government of Nauru has a target to increase the annual energy renewable penetration within Nauru to 50%. At the request of the Government of Nauru, the Asian Development Bank (ADB) provided support for the development of a Solar Power Expansion Plan, and using the recommendations undertake a feasibility study for a solar facility for Nauru.

This revised study was initiated for the following reasons:

- (1) Nauru Utilities Corporation (NUC) has decided not to relocate the existing gensets.
- (2) Recently, NUC has provided an updated SLD.
- (3) Furthermore, the contractor (CHEC) has advised that their BESS and solar have different fault current capabilities.

This report is subject to, and must be read in conjunction with, the limitations set out in Section 1.3 and the assumptions and qualifications contained throughout the Report. This report summarises the results and findings of a steady state study that GHD has carried out on the NUC Network. The study period considers the load forecast maximum of 7.5 MW, shoulder load of 5.5 MW and minimum of 2 MW. In this study, simulations were carried out using DigSILENT PowerFactory to analyse the steady state network response. The key outcomes of the study are summarised below.

## **Steady-state load flow study findings:**

### Normal Conditions

There were no overvoltages observed for the operation scenarios considered.

At diesel only operation at maximum load, undervoltage was observed at RPC3RPC2Ronphos 11kV bus, which was at 9.89 kV (0.899 p.u.). In the same scenario, three main transformers T1, T2 and T3 were all overloaded at ~114%. These issues however were due to the load growth modelled and not associated with the connection of the solar or BESS.

### Contingency Events

During the Express Feeder network configuration (i.e. Field Feeder open or faulted) and maximum load when running in diesel off mode (Scenario 1), the Express Feeder conductor is overloaded (108.5%) based on the Krypton conductor rating of 410 A.

Conversely, during the Field Feeder network configuration (i.e., Express feeder open or faulted) and maximum load when running in diesel off mode (scenario 1), the Field Feeder conductor is marginally overloaded (101.4%).

It is therefore recommended that a protection or control system is installed to prevent this overload at diesel-off maximum load operation, and dispatch additional gensets if required.

## **Short-circuit fault study findings:**

Fault studies were conducted to determine the minimum and maximum fault currents from the six operational scenarios. Among the six scenarios, maximum fault currents were observed for the mixed operation of renewables and diesel (Scenario 5), while minimum fault currents were observed for the BESS only operation (Scenario 6).

## **Study recommendations and future works:**

The primary objective of this steady state modelling is to ensure the equipment will not have thermal overloading, voltage regulation issues or exceed equipment fault ratings at different load and generation dispatch scenarios. GHD has developed the DigSILENT model based on information made available by NUC however the effective As Built information had a number of limitations and assumptions had to be

made. To further improve the model, a process of validation of the models could be undertaken by NUC including:

- Generator governor and real power capability curves.
- Transformer tap settings.
- Network configuration verification
- Detailed load measurements per transformation (rather than scaling based on nameplate rating)

Future works include:

- Verification by CHEC to confirm fault current contribution of solar and BESS inverters acts as a fixed current source (i.e. irrespective of impedance of fault)
- Analysis of unbalanced/earth faults and ability to detect and clear (including earth return path analysis).
- Development of detailed protection and control design by CHEC

# Contents

|           |                                                                 |           |
|-----------|-----------------------------------------------------------------|-----------|
| <b>1.</b> | <b>Introduction</b>                                             | <b>1</b>  |
| 1.1       | Purpose of this report                                          | 1         |
| 1.2       | Scope                                                           | 1         |
| 1.3       | Limitations                                                     | 1         |
| 1.4       | Inputs, Assumptions and Reliance                                | 2         |
| 1.5       | Acronyms and Standards                                          | 2         |
| <b>2.</b> | <b>Methodology</b>                                              | <b>5</b>  |
| <b>3.</b> | <b>Model Development &amp; Scenarios</b>                        | <b>6</b>  |
| 3.1       | Model Updates from the Previous Study                           | 6         |
| 3.2       | Steady State Modelling Approach                                 | 6         |
| 3.3       | List of Scenarios                                               | 6         |
| 3.3.1     | Load Flow Study Scenarios                                       | 6         |
| 3.3.2     | Fault Study Scenarios                                           | 9         |
| 3.4       | Summary of System Loads                                         | 9         |
| 3.5       | Model Inputs                                                    | 11        |
| 3.5.1     | Network Configuration                                           | 11        |
| 3.5.2     | Transformer and conductor                                       | 11        |
| 3.5.3     | Fault contributions                                             | 12        |
| <b>4.</b> | <b>Study Results</b>                                            | <b>12</b> |
| 4.1.1     | Scenario 1                                                      | 13        |
| 4.1.1.1   | Contingency at Field Feeder/Solar Interconnector                | 14        |
| 4.1.1.2   | Contingency at Express Feeder                                   | 15        |
| 4.1.2     | Scenario 2                                                      | 16        |
| 4.1.3     | Scenario 3                                                      | 18        |
| 4.1.4     | Scenario 4                                                      | 19        |
| 4.1.5     | Scenario 5                                                      | 20        |
| 4.1.6     | Scenario 6                                                      | 21        |
| 4.2       | Fault Study Results                                             | 22        |
| 4.2.1     | Summary of Fault Study                                          | 23        |
| 4.2.2     | Fault study with solar interconnector failure contingency event | 25        |
| <b>5.</b> | <b>Conclusion and Next Steps</b>                                | <b>26</b> |
| 5.1       | Thermal Constraints and Voltage Regulation                      | 26        |
| 5.2       | Fault Study                                                     | 26        |

## Table index

|          |                                                                                                                                                    |    |
|----------|----------------------------------------------------------------------------------------------------------------------------------------------------|----|
| Table 1  | Acronyms                                                                                                                                           | 2  |
| Table 2  | Standards                                                                                                                                          | 4  |
| Table 3  | Symbols                                                                                                                                            | 4  |
| Table 4  | Scenario 1 (maximum load) Diesel off                                                                                                               | 7  |
| Table 5  | Scenario 2 (minimum load) Generator loading                                                                                                        | 7  |
| Table 6  | Scenario 3 (maximum load) Generator loading                                                                                                        | 8  |
| Table 7  | Scenario 4 (minimum load) Generator loading                                                                                                        | 8  |
| Table 8  | Scenario 5 (moderate load) Generator loading                                                                                                       | 8  |
| Table 9  | Scenario 6 (minimum load) Generator loading                                                                                                        | 9  |
| Table 10 | Summary of system loads                                                                                                                            | 9  |
| Table 11 | Network Transformer Particulars                                                                                                                    | 11 |
| Table 12 | Generator Transformer Particulars                                                                                                                  | 11 |
| Table 13 | Conductor Particulars                                                                                                                              | 11 |
| Table 14 | Scenario 1 load flow results                                                                                                                       | 13 |
| Table 15 | Scenario 1 thermal overloading results                                                                                                             | 14 |
| Table 16 | Load flow results at field feeder out of service- scenario 1                                                                                       | 14 |
| Table 17 | Thermal overloading results at field feeder out of service- scenario 1                                                                             | 15 |
| Table 18 | Load flow results at express feeder out of service- scenario 1                                                                                     | 15 |
| Table 19 | Thermal overloading results at express feeder out of service- scenario 1                                                                           | 16 |
| Table 20 | Scenario 2 load flow results                                                                                                                       | 17 |
| Table 21 | Scenario 2 thermal overloading results                                                                                                             | 17 |
| Table 22 | Scenario 3 load flow results                                                                                                                       | 18 |
| Table 23 | Scenario 3 thermal overloading results                                                                                                             | 19 |
| Table 24 | Scenario 4 load flow results                                                                                                                       | 19 |
| Table 25 | Scenario 4 thermal overloading results                                                                                                             | 20 |
| Table 26 | Scenario 5 load flow results                                                                                                                       | 20 |
| Table 27 | Scenario 5 thermal overloading results                                                                                                             | 21 |
| Table 28 | Scenario 6 load flow results                                                                                                                       | 21 |
| Table 29 | Scenario 6 thermal overloading results                                                                                                             | 22 |
| Table 30 | Summary of Maximum 3-Phase Fault Levels – BESS fault contribution 2.0 p.u , Solar contribution 1.5 p.u                                             | 23 |
| Table 31 | Summary of Minimum 3-Phase Fault Levels – BESS fault contribution = 2.0 p.u., Solar contribution = 1.5 p.u.                                        | 24 |
| Table 32 | Diesel OFF fault levels (Scenario 1) – BESS fault contribution = 2.0 p.u., Solar fault contribution = 1.5 p.u.                                     | 25 |
| Table 33 | Diesel ON fault levels (Scenario 3) – BESS fault contribution = 2.0 p.u., Solar fault contribution = 1.5 p.u.                                      | 25 |
| Table 38 | Scenario 1 Maximum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed)   | 32 |
| Table 39 | Scenario 3 Maximum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed)   | 32 |
| Table 40 | Scenario 5 Maximum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed)   | 33 |
| Table 41 | Scenario 2 - Minimum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed) | 36 |
| Table 42 | Scenario 4 - Minimum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed) | 37 |

|          |                                                                                                                                                    |    |
|----------|----------------------------------------------------------------------------------------------------------------------------------------------------|----|
| Table 43 | Scenario 5 - Minimum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed) | 37 |
| Table 44 | Scenario 6 - Minimum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed) | 38 |

## Figure index

|          |                                                                                                                      |    |
|----------|----------------------------------------------------------------------------------------------------------------------|----|
| Figure 1 | Scenario 1 Load Flow                                                                                                 | 30 |
| Figure 2 | Fault Level One Line Diagram for Scenario 5, BESS fault contribution = 2.0 p.u., Solar fault contribution = 1.5 p.u. | 35 |
| Figure 3 | Fault Level One Line Diagram for Scenario 1, BESS fault contribution = 2.0 p.u., Solar fault contribution = 1.5 p.u. | 40 |
| Figure 4 | Fault Level One Line Diagram for Scenario 6, BESS fault contribution = 2.0 p.u., Solar fault contribution = 1.5 p.u. | 41 |

## Appendices

|            |                                                                           |
|------------|---------------------------------------------------------------------------|
| Appendix A | EPC Contractor Solar & BESS SLD                                           |
| Appendix B | Load Flow SLD                                                             |
| Appendix C | Fault Level One Line Diagram and Detailed Three-Phase Fault Study Results |
| Appendix D | NUC Network Configuration & Interconnection SLDs                          |
| Appendix E | Contractor's Response on Equipment Capability                             |
| Appendix F | PV and BESS SLD                                                           |

# 1. Introduction

This study is based on the findings from the Solar Power Expansion Plan, and a subsequent submission made to the Government of Nauru Cabinet by NUC in September 2018. The impact of renewable energy integration to the grid and installation of battery capacity of 2.5 MWh / 5 MW initially is studied in this report. Based on this, and discussions with NUC and ADB, GHD commenced this study for the development of 6 MWac solar coupled with 5 MW / 2.5 MWh of battery storage located at the Canstruct site.

The aim of the Nauru Solar Power Development Project is to increase the supply of cleaner electricity for Nauru. The country has a target of achieving 50% of its energy demand to be sourced from renewable energy, all of which is expected to be from solar power installations, by 2020, in accordance with the Republic of Nauru Energy Road Map 2014-2020. The investigation of the feasibility of expanding the solar power installation and battery energy storage system in Nauru considered multiple criteria, such as technical, financial and economic, environmental and social aspects, and associated project risks and constraints. The multi-criteria analysis, as outlined in the Solar Power Expansion Plan, led to identifying options, and determining the preferred option to achieve 50% renewable energy targets, with the date of achieving this target moved to 2025.

## 1.1 Purpose of this report

Power system studies are required to be carried out to assess system network performance to facilitate integration of renewables into NUC network. In this report, GHD has carried out steady state studies of NUC network for six scenarios to analyse network performance.

## 1.2 Scope

The scope of this report includes steady state studies to assess the performance of the NUC network with and without the integration of solar PV and BESS using DIgSILENT PowerFactory. This study will allow to identify any requirement of upgrade of existing asset and assess the integration of the PV/BESS to the NUC network.

## 1.3 Limitations

This study does not confirm the stability of the scenarios discussed.

No analysis or recommendations in this report limit the Solar and BESS Contractor's (CHEC) detailed design responsibilities including with respect to protection, SCADA and control and earthing design.

This report: has been prepared by GHD for Nauru Utilities Corporation and may only be used and relied on by Nauru Utilities Corporation for the purpose agreed between GHD and Nauru Utilities Corporation as set out in Section 1.1 this report.

GHD otherwise disclaims responsibility to any person other than Nauru Utilities Corporation arising in connection with this report. GHD also excludes implied warranties and conditions, to the extent legally permissible.

The services undertaken by GHD in connection with preparing this report were limited to those specifically detailed in the report and are subject to the scope limitations set out in the report.

The opinions, conclusions and any recommendations in this report are based on conditions encountered and information reviewed at the date of preparation of the report. GHD has no responsibility or obligation to update this report to account for events or changes occurring subsequent to the date that the report was prepared.

The opinions, conclusions and any recommendations in this report are based on assumptions made by GHD described in this report. GHD disclaims liability arising from any of the assumptions being incorrect.

## 1.4 Inputs, Assumptions and Reliance

GHD has prepared the “NauruADBSolarCMexpsrfr2022-202403.pfd” (“Model”) which has informed this technical note for, and for the benefit and sole use of, NUC to support the connection of the solar PV and BESS and must not be used for any other purpose or by any other person.

The Model is a representation only and does not reflect reality in every aspect. The Model contains simplified assumptions to derive a modelled outcome. The actual variables will inevitably be different to those used to prepare the Model. Accordingly, the outputs of the Model cannot be relied upon to represent actual conditions without due consideration of the inherent and expected inaccuracies. Such considerations are beyond GHD’s scope.

The information, data and assumptions (“Inputs”) used as inputs into the Model are from publicly available sources or provided by or on behalf of the NUC (including possibly through stakeholder engagements). GHD has not independently verified or checked Inputs beyond its agreed scope of work. GHD’s scope of work does not include review or update of the Model as further Inputs becomes available.

The Model is limited by the mathematical rules and assumptions that are set out in the Report or included in the Model and by the software environment in which the Model is developed. The Model is a customised model and not intended to be amended in any form or extracted to other software for amending. Any change made to the Model, other than by GHD, is undertaken on the express understanding that GHD is not responsible, and has no liability, for the changed Model including any outputs.

GHD has not undertaken an independent validation or verification of the previous work or As Built data provided by NUC or the Contractor (CHEC).

Assumptions are as detailed throughout this report including all load data, SLD and as built information as provided by NUC and the Contractor. Specific assumptions include:

- Network configurations (including normally open points) and equipment ratings are as per provided SLDs
- Load scaling is based on nameplate rating of distribution transformers
- Fault current contribution of solar and BESS inverters is modelled as a fixed current source (i.e. irrespective of impedance of fault for balanced and unbalanced faults)
- Duration of PV and BESS inverter fault current contribution is long enough to operate the considered protection schemes (Sensitivity of per unit fault current magnitude analysed in Section 4.2.2)

## 1.5 Acronyms and Standards

The following terms and abbreviations are applicable to this document:

Table 1 Acronyms

| Acronym    | Description                                                                |
|------------|----------------------------------------------------------------------------|
| AC         | Alternating Current                                                        |
| DC         | Direct Current                                                             |
| HV (or MV) | High Voltage as defined by Australian Standards (> 1000 Vac or > 1500 Vdc) |
| IEC        | International Electrotechnical Commission                                  |
| LV         | Low Voltage                                                                |
| MVA        | Mega Volt Ampere                                                           |
| MVAR       | Mega Volt Ampere Reactive                                                  |
| MW         | Mega Watt                                                                  |
| O&M        | Operation and Maintenance                                                  |
| O/H        | Overhead                                                                   |
| PF         | Power factor                                                               |

| Acronym | Description             |
|---------|-------------------------|
| PS      | Power Station           |
| RMU     | Ring Main Unit          |
| SLD     | Single Line Diagram     |
| SPD     | Surge Protection Device |
| U/G     | Underground             |

A list of standards applicable to this report is listed below.

**Table 2**                **Standards**

| Standard        |                                                  |
|-----------------|--------------------------------------------------|
| Complete Method | Superposition method of short-circuit analysis   |
| IEC 60909       | Short-Circuit currents in three phase AC systems |

**Table 3**                **Symbols**

| Symbols  | Description                                                                                                                                                                                                          |
|----------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| $I_p$    | Peak short circuit current, maximum possible instantaneous short-circuit current                                                                                                                                     |
| $I_b$    | Symmetrical short circuit breaking current, RMS value of an integral cycle of the symmetrical ac component of the short circuit current at the instant of contact separation of the first pole of a switching device |
| $I_k$    | Steady state short circuit current, RMS value of short circuit current which remains after the decay of the transient component                                                                                      |
| $I_{th}$ | Thermal equivalent short circuit current, RMS value of a current having the same thermal effect and the same duration as the actual short circuit current, which may contain a dc component and may subside in time  |

## 2. Methodology

The load flow and fault study methodologies are described in this section.

### 1. Load Flow Calculation

- a. Newton-Raphson algorithm was used.
- b. The loading current capacity of equipment used in this report are from the vendor data.
- c. The following standards are used to assess the load flow study results:
  - i. Except as a consequence of a non-credible contingency event, the minimum steady-state voltage on the system operating at voltages of 11 kV must be 90% of nominal voltage and the maximum steady state voltage must be 110% of nominal voltage.
  - ii. For those parts of the distribution system operating below voltages of 11 kV, the steady state voltage must be within:  $\pm 6\%$  of the nominal voltage during normal operating state.
- d. No transformer tap setting optimization and voltage control mechanism have been considered.

### 2. Short-Circuit Calculation

- a. The IEC 60909 method was used to calculate maximum three-phase fault currents at all the buses in the network and fault is implemented to all the buses.
- b. The complete method was used to calculate the maximum single phase to ground currents, the minimum three-phase fault currents and minimum single phase to ground currents at all the buses in the network and fault is implemented to all the buses.
- c. For IEC 60909 method, a c factor of 1 is used.
- d. Fault current contribution from equipment is as per Section 3.3.2.
- e. The main objective of this fault study is to determine the following:
  - i. the maximum fault levels at bus locations within the NUC network to determine the required fault rating of circuit breakers/switchgears; and
  - ii. the minimum fault levels at bus locations within the NUC network to investigate if overcurrent protection will operate or not.

## 3. Model Development & Scenarios

An electrical model of the Nauru electrical network has been built in PowerFactory to carry out the steady state analysis presented in this report. This section describes the development of the steady state base model for the network and the input data used for the model.

### 3.1 Model Updates from the Previous Study

The previous issued report for this project was “Revised System Study - TA-9242 REG: Pacific Renewable Energy Investment Facility- NAU-01 Project Preparation-Consultancy (49450-001)”. Updates have been made to the GHD’s developed DigSILENT PowerFactory Model of the Nauru grid. The model was developed as a part of feasibility study done by GHD to assess and plan for the agreed renewable penetration through the design of a PV solar and a BESS system to complement the existing diesel power station and distributed solar PV. Changes to the model were made in accordance with the updated single line diagram (refer to Appendix A and Appendix D) and feedback provided by AS, who confirmed the planned changes in design to the grid. This principally involved the following:

- The generators connected to the 3.3 kV bus are updated as per on site setup and recently provided SLD- “ADB SOLAR INTERFACE TO 11KV SLD-Model – UPDATED 20-10-2022” (see Appendix D).
- Fuel Tank Farm Load increased to 200 kW
- ODIN AIWO load connected to Ringmain East- Civic Bus
- Transformer impedances were updated (see Tables 9 and 10: Transformer and Generator Transformer Particulars)
- A moderate load scenario was added.
- The diesel generators were recommended to be loaded above 60% for the Scenario 3 and Scenario 5 (Refer to section 3.3.1).
- An additional case of 2.0 p.u. BESS fault contribution was considered upon CHEC’s confirmation that they will comply with the 2.0 p.u. requirement.

### 3.2 Steady State Modelling Approach

In considering grid stability implications and effect of high penetration renewables in a microgrid, the primary consideration is to ensure the output (and intermittency) of the new installation (centralised PV and BESS) does not result in any flow-on impacts to operation of the existing generation equipment or loads. This can be achieved through equipment loading studies and steady-state voltage regulation studies, among others.

### 3.3 List of Scenarios

A list of scenarios considered for load flow studies and fault studies is provided below.

#### 3.3.1 Load Flow Study Scenarios

Several scenarios are investigated in the load flow study. The objectives of this study are as follows:

- 1) To assess the effect of network voltage variations
- 2) To assess the loading of the cables and verify the selected cable sizes
- 3) To assess the thermal overloading of any of the assets in the network

A steady state modelling is done for the following scenarios to cover all credible operating modes and scenarios:

- **Scenario 1:** Annual maximum load of 7.5 MW @ 0.93 p.f. 100% supply from BESS and PV (in diesel off mode);
- **Scenario 2:** Annual minimum load of 2 MW @ 0.93 p.f. 100% supply from BESS and PV (in diesel off mode);

- **Scenario 3:** Annual maximum load of 7.5 MW @ 0.93 p.f. 100% supply from diesel power station (in existing location);
- **Scenario 4:** Annual minimum load of 2 MW @ 0.93 p.f. 100% supply from diesel power station (in existing location)
- **Scenario 5:** Moderate load of 5.5 MW @ 0.93 p.f., with 52% of supply coming from PV and 48% from diesel generation; and
- **Scenario 6:** Annual minimum load of 2 MW @ 0.93 p.f. 100% supply from BESS (PV off and diesel off mode).

As per “Solar Power Development Project: Feasibility Study”, the solar PV plant will have an AC capacity of 6.0 MWac and 6.9 MWdc (at STC) and the battery energy storage system (BESS) capacity of 5 MW and 2.5 MWh. The BESS will be composed of two separate systems of 2.5 MW, 1.25 MWh capacity. The drawing “DQ01-001 Electrical Single Line Diagram2022.09.23” shows the electrical arrangement of the PV and BESS.

Table 4 to Table 8 show the generator loading and voltages for each study scenario.

**Table 4** Scenario 1 (maximum load) Diesel off

| Generator   | Busbar    | Bus type | Active power (MW) | Reactive power (MVar) | Apparent Power (MVA) | Rating (MVA) | Voltage (p.u.) | Power Factor | Loading (%) | Spinning reserve (MW) |
|-------------|-----------|----------|-------------------|-----------------------|----------------------|--------------|----------------|--------------|-------------|-----------------------|
| MANG2       | G2-1      | PV       |                   |                       |                      |              | Offline        |              |             |                       |
| Cummins G5  | G5        | PQ       |                   |                       |                      |              | Offline        |              |             |                       |
| Cummins G10 | G10       | PQ       |                   |                       |                      |              | Offline        |              |             |                       |
| Cummins G2A | G2        | PQ       |                   |                       |                      |              | Offline        |              |             |                       |
| Cummins G7  | G7-8      | PQ       |                   |                       |                      |              | Offline        |              |             |                       |
| G4 Ruston   | G4        | PQ       |                   |                       |                      |              | Offline        |              |             |                       |
| ADB Solar   | ADBSolar  | PQ       | 6                 | 0                     | 6                    | 6            | 1.063          | 1            | 100         | 0                     |
| MFAT Solar  | MFATSolar | PQ       | 0.9               | 0                     | 0.9                  | 0.9          | 1.063          | 1            | 100         | 0                     |
| UAE Solar   | UAESolar  | PQ       | 0.3               | 0                     | 0.3                  | 0.3          | 1.032          | 1            | 100         | 0                     |
| BESS        | ADB Solar | PV       | 0.63              | 3.7                   | 3.8                  | 5            | 1.063          | 0.166        | 76          | 2.69                  |

**Table 5** Scenario 2 (minimum load) Generator loading

| Generator   | Busbar    | Bus type | Active power (MW) | Reactive power (MVar) | Apparent Power (MVA) | Rating (MVA) | Voltage (p.u.) | Power Factor | Loading (%) | Spinning reserve (MW) |
|-------------|-----------|----------|-------------------|-----------------------|----------------------|--------------|----------------|--------------|-------------|-----------------------|
| MANG2       | G2-1      | PV       |                   |                       |                      |              | Offline        |              |             |                       |
| Cummins G5  | G5        | PQ       |                   |                       |                      |              | Offline        |              |             |                       |
| Cummins G10 | G10       | PQ       |                   |                       |                      |              | Offline        |              |             |                       |
| Cummins G2A | G2        | PQ       |                   |                       |                      |              | Offline        |              |             |                       |
| Cummins G7  | G7-8      | PQ       |                   |                       |                      |              | Offline        |              |             |                       |
| G4 Ruston   | G4        | PQ       |                   |                       |                      |              | Offline        |              |             |                       |
| ADB Solar   | ADBSolar  | PQ       | 1.35              | 0                     | 1.35                 | 6            | 1.015          | 1            | 22.5        | 4.650                 |
| MFAT Solar  | MFATSolar | PQ       | 0.27              | 0                     | 0.27                 | 0.9          | 1.015          | 1            | 30          | 0.630                 |
| UAE Solar   | UAESolar  | PQ       | 0.3               | 0                     | 0.3                  | 0.3          | 1.052          | 1            | 100         | 0                     |
| BESS        | ADB Solar | PV       | 0.29              | 0.92                  | 1.00                 | 5            | 1.015          | 0.29         | 20.0        | 4.62                  |

**Table 6** Scenario 3 (maximum load) Generator loading

| Generator   | Busbar    | Bus type | Active power (MW) | Reactive power (MVar) | Apparent Power (MVA) | Rating (MVA) | Voltage (p.u.) | Power Factor | Loading (%) | Spinning reserve (MW) |
|-------------|-----------|----------|-------------------|-----------------------|----------------------|--------------|----------------|--------------|-------------|-----------------------|
| MANG2       | G2-1      | PV       | 2.8297            | 1.604                 | 3.253                | 3.562        | 1.000          | 0.870        | 91.3        | 0.350                 |
| G4 Ruston   | G4        | PQ       | 1.739             | 0.61                  | 1.843                | 2.2          | 0.965          | 0.944        | 83.8        | 0.375                 |
| Cummins G2A | G2        | PQ       | 1.12              | 0.61                  | 1.275                | 1.4          | 1.031          | 0.878        | 91.1        | 0.140                 |
| Cummins G5  | G5        | PQ       | 1.12              | 0.61                  | 1.275                | 1.4          | 1.031          | 0.878        | 91.1        | 0.140                 |
| Cummins G7  | G7-8      | PQ       | 1.12              | 0.61                  | 1.275                | 1.4          | 1.044          | 0.878        | 91.1        | 0.140                 |
| Cummins G10 | G10       | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| ADB Solar   | ADBSolar  | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| MFAT Solar  | MFATSolar | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| UAE Solar   | UAESolar  | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| BESS        | ADB Solar | PV       | Offline           |                       |                      |              |                |              |             |                       |

**Table 7** Scenario 4 (minimum load) Generator loading

| Generator   | Busbar    | Bus type | Active power (MW) | Reactive power (MVar) | Apparent Power (MVA) | Rating (MVA) | Voltage (p.u.) | Power Factor | Loading (%) | Spinning reserve (MW) |
|-------------|-----------|----------|-------------------|-----------------------|----------------------|--------------|----------------|--------------|-------------|-----------------------|
| MANG2       | G2-1      | PV       | 1.5394            | 0.837                 | 1.752                | 3.562        | 1              | 0.879        | 49.2        | 1.923                 |
| Cummins G2A | G2        | PQ       | 0.685             | 0.155                 | 0.702                | 1.4          | 1.028          | 0.975        | 50.2        | 0.706                 |
| G4 Ruston   | G4        | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| Cummins G5  | G5        | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| Cummins G7  | G7-8      | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| Cummins G10 | G10       | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| ADB Solar   | ADBSolar  | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| MFAT Solar  | MFATSolar | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| UAE Solar   | UAESolar  | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| BESS        | ADB Solar | PV       | Offline           |                       |                      |              |                |              |             |                       |

**Table 8** Scenario 5 (moderate load) Generator loading

| Generator   | Busbar    | Bus type | Active power (MW) | Reactive power (MVar) | Apparent Power (MVA) | Rating (MVA) | Voltage (p.u.) | Power Factor | Loading (%) | Spinning reserve (MW) |
|-------------|-----------|----------|-------------------|-----------------------|----------------------|--------------|----------------|--------------|-------------|-----------------------|
| MANG2       | G2-1      | PV       | 1.8523            | 1.389                 | 2.315                | 3.562        | 1.099          | 0.8          | 65          | 1.428                 |
| Cummins G5  | G5        | PQ       | 0.9               | 0                     | 0.9                  | 1.4          | 1.061          | 1            | 64.3        | 0.5                   |
| Cummins G2A | G2        | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| G4 Ruston   | G4        | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| Cummins G7  | G7-8      | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| Cummins G10 | G10       | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| ADB Solar   | ADBSolar  | PQ       | 2.1               | 0                     | 2.1                  | 6            | 1.011          | 1            | 35          | 3.9                   |
| MFAT Solar  | MFATSolar | PQ       | 0.7               | 0                     | 0.7                  | 0.9          | 1.011          | 1            | 78          | 0.2                   |
| UAE Solar   | UAESolar  | PQ       | 0.2               | 0                     | 0.2                  | 0.3          | 1.041          | 1            | 67          | 0.1                   |
| BESS        | ADB Solar | PV       | Offline           |                       |                      |              |                |              |             |                       |

**Table 9** Scenario 6 (minimum load) Generator loading

| Generator   | Busbar    | Bus type | Active power (MW) | Reactive power (MVar) | Apparent Power (MVA) | Rating (MVA) | Voltage (p.u.) | Power Factor | Loading (%) | Spinning reserve (MW) |
|-------------|-----------|----------|-------------------|-----------------------|----------------------|--------------|----------------|--------------|-------------|-----------------------|
| MANG2       | G2-1      | PV       | Offline           |                       |                      |              |                |              |             |                       |
| Cummins G5  | G5        | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| Cummins G2A | G2        | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| G4 Ruston   | G4        | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| Cummins G7  | G7-8      | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| Cummins G10 | G10       | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| ADB Solar   | ADBSolar  | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| MFAT Solar  | MFATSolar | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| UAE Solar   | UAESolar  | PQ       | Offline           |                       |                      |              |                |              |             |                       |
| BESS        | ADB Solar | PV       | 2.21              | 0.999                 | 2.75                 | 5            | 1.015          | 0.805        | 36.4        | 2.01                  |

### 3.3.2 Fault Study Scenarios

The same scenarios used in the load flow studies are considered for the fault studies.

## 3.4 Summary of System Loads

The load is modelled according to the same method as per previous studies – i.e. total system demand figures distributed proportionally based on distribution transformer nameplate kVA with LV loads modelled as lumped loads. A summary of the system loads is presented below:

**Table 10** Summary of system loads

| Load            | Feeder | Scenario 1 & 3 (kW) | Scenario 2, 4 & 6 (kW) | Scenario 5 (kW) | Power factor (pf) |
|-----------------|--------|---------------------|------------------------|-----------------|-------------------|
| Command Ridge   | Field  | 94                  | 25                     | 69              | 0.93              |
| Domestic sub    | Field  | 47                  | 13                     | 34              | 0.93              |
| Fuel tank farm  | Field  | 94                  | 25                     | 69              | 0.93              |
| Prison          | Field  | 47                  | 13                     | 34              | 0.93              |
| Rehab workshop  | Field  | 469                 | 125                    | 344             | 0.93              |
| RONPHOS crusher | Field  | 919                 | 245                    | 674             | 0.93              |
| RPC1            | Field  | 563                 | 150                    | 413             | 0.93              |
| RPC2            | Field  | 375                 | 100                    | 275             | 0.93              |
| RPC3            | Field  | 188                 | 50                     | 138             | 0.93              |
| RONPHOS drier   | 3.3 kV | 459                 | 122                    | 337             | 0.93              |
| Airport         | East   | 134                 | 36                     | 98              | 0.93              |
| Civic           | East   | 67                  | 18                     | 49              | 0.93              |
| Fresh Centre    | East   | 157                 | 42                     | 115             | 0.93              |
| Gon             | East   | 349                 | 93                     | 256             | 0.93              |
| Pago            | East   | 67                  | 18                     | 49              | 0.93              |
| Anabar          | North  | 191                 | 51                     | 140             | 0.93              |
| Arijejen        | North  | 620                 | 165                    | 455             | 0.93              |
| Ijuw            | North  | 250                 | 67                     | 184             | 0.93              |
| Ronave          | North  | 258                 | 69                     | 189             | 0.93              |
| Waboe           | North  | 398                 | 106                    | 292             | 0.93              |

|                         |       |             |             |             |      |
|-------------------------|-------|-------------|-------------|-------------|------|
| The Bay                 | North | 129         | 34          | 95          | 0.93 |
| Junct1                  | South | 419         | 112         | 308         | 0.93 |
| Junct2                  | South | 341         | 91          | 250         | 0.93 |
| Terrace                 | South | 427         | 114         | 313         | 0.93 |
| <b>Additional loads</b> |       |             |             |             |      |
| Government office       | East  | 144         | 38          | 106         | 0.93 |
| Menen Hotel             | North | 145         | 39          | 106         | 0.93 |
| Anibar Workers Camp     | North | 63          | 17          | 46          | 0.93 |
| Nibok Camp              | North | 43          | 11          | 32          | 0.93 |
| Ewa Camp                | North | 43          | 11          | 32          | 0.93 |
| <b>Total demand</b>     |       | <b>7500</b> | <b>2000</b> | <b>5502</b> |      |

Source: Initial data from MFAT, scaled by GHD. For Scenario 5, the individual loads were calculated by scaling the loads from Scenario 1&3 by a factor = (moderate demand of 5.5 MW)/(total maximum demand of 7.5 MW).

## 3.5 Model Inputs

### 3.5.1 Network Configuration

- The network configuration has been modelled as per Appendix D.
- Transformer T4 has been modelled out of service for all scenarios.
- Field Feeder (FF) and Express Feeder (EF) are modelled closed for the base case scenarios. With this network configuration, FF and EF effectively operate as parallel interconnectors as far as the supply to the North, South and East feeders are concerned. This is envisioned to be the default network configuration as it is more efficient and provides partial redundancy.
- The nominal MV network configuration and the location of Normally Open Points (NOP) between the South, North, East and Field feeders are shown as green circles in the SLD in Appendix D. NOPs by the Fresh Centre, the New Prison and the Menen Hotel are modelled by open circuit breakers. The existing line between the Gon and Gonway busbars is also disconnected and is a NOP in the SLD.

### 3.5.2 Transformer and conductor

#### Transformers:

- PV1&2 0.48/11kV transformer – 6% at 2MVA
- PV3 0.48/11kV transformer – 6% at 2.5MVA
- BESS 0.4/11kV transformer – 6% at 2.75MVA

Table 11 Network Transformer Particulars

| PARTICULARS                | RM SOUTH | RM EAST | RM NORTH |
|----------------------------|----------|---------|----------|
| Rated KVA                  | 2500     | 2500    | 2500     |
| Phases                     | 3        | 3       | 3        |
| Frequency                  | 50       | 50      | 50       |
| Volts, HV                  | 11000    | 11000   | 11000    |
| Volts, no load LV          | 3300     | 3300    | 3300     |
| Amperes, HV                | 131.2    | 131.2   | 131.2    |
| Amperes, LV                | 437.4    | 437.4   | 437.4    |
| Vector Symbol              | YNd 11   | Dyn 11  | YNd 11   |
| Impedance (Rated KVA) @75% | 5.97     | 5.97    | 5.96     |

Table 12 Generator Transformer Particulars

| PARTICULARS                | GEN 2A & G2B | GEN 3  | GEN 4 Rus | GEN 5  | G7B    | MAN    |
|----------------------------|--------------|--------|-----------|--------|--------|--------|
| Rated KVA                  | 1500         | 1500   | 33500     | 1500   | 1500   | 4000   |
| Phases                     | 3            | 3      | 3         | 3      | 3      | 3      |
| Frequency                  | 50           | 50     | 50        | 50     | 50     | 50     |
| Volts, HV                  | 3300         | 3300   | 11000     | 3300   | 3300   | 11000  |
| Volts, no load LV          | 415          | 433    | 3300      | 415    | 433    | 3300   |
| Amperes, HV                | 262          | 262    | 612.3     | 262    | 262    | 209.95 |
| Amperes, LV                | 2087         | 2000   | 183.7     | 2087   | 2000   | 699.82 |
| Vector Symbol              | YNd 11       | Dyn 11 | Dyn11     | YNd 11 | Dyn 11 | Dyn 11 |
| Impedance (Rated KVA) @75% | 5.79%        | 6.04%  | 4.71%     | 5.72%  | 5.99%  | 7.25%  |

Table 13 Conductor Particulars

| PARTICULARS  | AC Resistance |
|--------------|---------------|
| Krypton AAAC | 0.227 Ohm/km  |
| ABC 150 Al   | 0.261 Ohm/km  |
| 185CuUG      | 0.099 Ohm/km  |

### 3.5.3 Fault contributions

Fault current contribution impacts steady-state fault levels. As such, the fault current contribution of synchronous generation and inverter-coupled sources are considered as follows.

#### Synchronous Generation (alternator-based)

Sources as follows:

- Cummins Diesel Sync gen units – 692% of rated output, 6.92 pu
- MAN Diesel Sync unit - 703% of rated output, 7.03 pu
- Ruston Diesel Sync gen units – 692% of rated output, 6.92 pu
- Fault current contribution of the diesel genset's alternator is modelled with a 15% sub-transient impedance. Specific AVR settings are not considered.

#### Inverter-Coupled Source

Following the initial power system modelling studies/memo (i.e. pre-EPC contract award), the Contractor advised that their proposed equipment did not comply with the minimum required fault current contribution requirements of the Contract (i.e., 200% of rated output or 2.0 p.u.) and was only capable of the following:

- BESS units – 150%<sup>1</sup> of rated output (i.e. 1.5 p.u.)
- PV units – 150%<sup>1</sup> of rated output (i.e. 1.5 p.u.)

The above values were therefore used for base modelling. However, due to subsequent clarification from the Contractor that the inverters were only capable of supplying this for a short duration for fault current contribution (i.e. <1ms), the following reduced fault contribution cases were also analysed to assess minimum fault current through the solar interconnector:

- The PV and the BESS fault current contributions are set to 1.0 p.u. and 1.3 p.u., respectively, in section 4.2.2 to determine the fault currents that may be seen based on different potential fault current contribution capabilities of the inverters.
- A BESS fault contribution of 1.04 p.u. was considered per the contractor's response on equipment capability (Appendix E).
- Also, a fault contribution of 1.0 p.u. for both PV and BESS is also considered in a study in the above-mentioned section of the report.

More recently, the BESS supplier confirmed that they will be designing the BESS to supply 2.0 p.u. fault current contribution. Hence, a BESS fault contribution of 2.0 p.u. was considered in addition.

## 4. Study Results

The load flow and fault study results are shown in the following sections.

The following colour scheme is used in the result tables to represent voltage, thermal loading, and fault currents that require attention or might require future attention.

|               |                                                                                                                                                                                                                                                                                                 |
|---------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>red</b>    | Issues that require immediate attention, e.g., if the bus voltage is not within $\pm 10\%$ of rated voltage, if the equipment loading exceeds 100% of its thermal capacity, and if the fault current level exceeds the equipment's fault rating.                                                |
| <b>yellow</b> | Issues that are marginally OK and might need future attention, e.g., bus voltage is not within $\pm 5\%$ of rated voltage, if the equipment loading exceeds 90% of its thermal capacity, and if the fault current level is above 90% of the corresponding network-allowed maximum fault rating. |

<sup>1</sup> As per RFI - NUC\_06122022(Contractor response2022.12.16) provided in Appendices.

Table 14 to Table 27 provide the load flow results of the different operating scenarios. The tables give key information about the solar farm such as conductor loadings and the voltage levels within the solar farm.

## 4.1.1 Scenario 1

In **Scenario 1**: Annual maximum load of 7.5 MW @ 0.93 p.f. 100% supply from BESS (in grid forming mode) and PV,

- No voltage and thermal loading issues have been identified.
- The highest voltages in the network are at ADBSolar and MFATSolar (1.063 p.u.). Since the ADBSolar and MFATSolar bus voltages are 11 kV i.e. >6 kV this is acceptable as per target criteria.
- The lowest voltages in the network are at Ijew (1.017 p.u.), Menen\_N1 (1.016 p.u.), and TheBay (1.016 p.u.).
- Marginally loaded transformers are the 2-winding PV transformers at ADBSolar at 94.1% loading.

**Table 14** Scenario 1 load flow results

| Name            | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|-----------------|-------------|------------|--------------|
| 11kVEast        | 11.0        | 11.4       | 1.036        |
| 11kVField       | 11.0        | 11.4       | 1.036        |
| 11kVNorth       | 11.0        | 11.4       | 1.036        |
| 11kVSolar       | 11.0        | 11.4       | 1.036        |
| 11kVSouth       | 11.0        | 11.4       | 1.036        |
| ADBSolar        | 11.0        | 11.7       | 1.063        |
| Airport         | 11.0        | 11.4       | 1.034        |
| Anabar          | 11.0        | 11.2       | 1.018        |
| Arijejen        | 11.0        | 11.4       | 1.033        |
| Civic           | 11.0        | 11.4       | 1.034        |
| CommandRidge    | 11.0        | 11.4       | 1.039        |
| DomSub          | 11.0        | 11.4       | 1.039        |
| EUSolar         | 11.0        | 11.6       | 1.053        |
| FreshCentre     | 11.0        | 11.4       | 1.033        |
| FreshCentre_S1  | 11.0        | 11.3       | 1.030        |
| FuelTankFarm    | 11.0        | 11.4       | 1.039        |
| G10             | 0.4         | 0.0        | 0.000        |
| G2              | 0.4         | 0.0        | 0.000        |
| G2-1            | 11.0        | 0.0        | 0.000        |
| G3              | 0.4         | 0.0        | 0.000        |
| G3-1            | 11.0        | 0.0        | 0.000        |
| G4              | 11.0        | 0.0        | 0.000        |
| G5              | 0.4         | 0.0        | 0.000        |
| G6              | 0.4         | 0.0        | 0.000        |
| G7-8            | 0.4         | 0.0        | 0.000        |
| Gon             | 11.0        | 11.4       | 1.034        |
| Gonway          | 11.0        | 11.4       | 1.033        |
| Ijew            | 11.0        | 11.2       | 1.017        |
| Junct1          | 11.0        | 11.4       | 1.033        |
| Junct2          | 11.0        | 11.4       | 1.032        |
| Junct5          | 11.0        | 11.3       | 1.031        |
| MFATSolar       | 11.0        | 11.7       | 1.063        |
| Menen_E1        | 11.0        | 11.4       | 1.033        |
| Menen_E1(1)     | 11.0        | 11.6       | 1.053        |
| Menen_N1        | 11.0        | 11.2       | 1.016        |
| Menen_S2        | 11.0        | 11.3       | 1.028        |
| PS3.3kV-A       | 3.3         | 3.4        | 1.034        |
| PS3.3kV-B       | 3.3         | 3.4        | 1.034        |
| Pago            | 11.0        | 11.4       | 1.034        |
| RPC1            | 11.0        | 11.7       | 1.061        |
| RPC3RPC2Ronphos | 11.0        | 11.6       | 1.051        |
| RehabWorkshops  | 11.0        | 11.6       | 1.053        |

| Name     | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|----------|-------------|------------|--------------|
| Ronave   | 11.0        | 11.2       | 1.020        |
| Terrace  | 11.0        | 11.3       | 1.028        |
| TheBay   | 11.0        | 11.2       | 1.016        |
| UAESolar | 11.0        | 11.4       | 1.032        |
| Waboe    | 11.0        | 11.3       | 1.027        |

Table 15 Scenario 1 thermal overloading results

| Name                             | HV-Side     | LV-Side        | HV-Side V p.u. | LV-Side Vn p.u. | Loading (%) |
|----------------------------------|-------------|----------------|----------------|-----------------|-------------|
| 2-Winding Transformer            | MFATSolar   | Terminal       | 1.063          | 1.063           | 84.7        |
| 2-Winding Transformer - UAESolar | UAESolar    | Terminal(6)    | 1.032          | 1.071           | 23.2        |
| BESS1 2-Winding Transformer      | ADBSolar    | BESS1 Terminal | 1.063          | 1.100           | 64.6        |
| BESS2 2-Winding Transformer      | ADBSolar    | BESS2 Terminal | 1.063          | 1.100           | 61.0        |
| PV1 2-Winding Transformer        | ADBSolar    | PV1 Terminal   | 1.063          | 1.274           | 94.1        |
| PV2 2-Winding Transformer        | ADBSolar    | PV2 Terminal   | 1.063          | 1.274           | 94.1        |
| PV3 2-Winding Transformer        | ADBSolar    | PV3 Terminal   | 1.063          | 1.275           | 75.3        |
| T1                               | 11kVEast    | PS3.3kV-A      | 1.036          | 1.034           | 6.4         |
| T2                               | 11kVSouth   | PS3.3kV-A      | 1.036          | 1.034           | 6.4         |
| T3                               | 11kVNorth   | PS3.3kV-B      | 1.036          | 1.034           | 6.4         |
| T4                               | - 11kVField | PS3.3kV-B      | 1.034          | 1.034           | 0.0         |

Contingencies at FF and EF were simulated for the maximum demand scenario (diesel off). When the FF tie is modelled open for “diesel off” operating scenarios, the PV/BESS supply power through the solar interconnector to the old power station and all the way back to the FF loads. This configuration results in higher losses, wider voltage regulation, lower fault levels and overload constraints. It is believed to be used operationally only in a contingency event, i.e., when the feeder is partially faulted. Below sections show the results of the contingency simulations.

#### 4.1.1.1 Contingency at Field Feeder/Solar Interconnector

In this section, voltage regulation and thermal constraints are assessed for a contingency at Field Feeder/Solar Interconnector for scenario 1. Following are the results for field feeder out of service:

- The lowest voltages in the network can be found at RPC3RPC2Ronphos (0.929 p.u.), EUSolar (0.929 p.u.), and RPC1 (0.937 p.u.).
- Undervoltages are observed for Anabar, EUSolar, Ijew, Menen\_E1(1), Menen\_N1, RPC1, RPC3RPC2Ronphos, RehabWorkshops, and TheBay.
- Line(32) - Express Feeder is overloaded at 107.9%

Table 16 Load flow results at field feeder out of service- scenario 1

| Name           | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|----------------|-------------|------------|--------------|
| 11kVEast       | 11.0        | 10.6       | 0.968        |
| 11kVField      | 11.0        | 10.6       | 0.968        |
| 11kVNorth      | 11.0        | 10.6       | 0.968        |
| 11kVSolar      | 11.0        | 10.6       | 0.968        |
| 11kVSouth      | 11.0        | 10.6       | 0.968        |
| ADBSolar       | 11.0        | 11.6       | 1.056        |
| Airport        | 11.0        | 10.6       | 0.966        |
| Anabar         | 11.0        | 10.4       | 0.949        |
| Arijejen       | 11.0        | 10.6       | 0.965        |
| Civic          | 11.0        | 10.6       | 0.966        |
| CommandRidge   | 11.0        | 10.6       | 0.963        |
| DomSub         | 11.0        | 10.6       | 0.963        |
| EUSolar        | 11.0        | 10.2       | 0.929        |
| FreshCentre    | 11.0        | 10.6       | 0.965        |
| FreshCentre_S1 | 11.0        | 10.6       | 0.962        |
| FuelTankFarm   | 11.0        | 10.6       | 0.963        |
| G10            | 0.4         | 0.0        | 0.000        |
| G2             | 0.4         | 0.0        | 0.000        |

| Name            | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|-----------------|-------------|------------|--------------|
| G2-1            | 11.0        | 0.0        | 0.000        |
| G3              | 0.4         | 0.0        | 0.000        |
| G3-1            | 11.0        | 0.0        | 0.000        |
| G4              | 11.0        | 0.0        | 0.000        |
| G5              | 0.4         | 0.0        | 0.000        |
| G6              | 0.4         | 0.0        | 0.000        |
| G7-8            | 0.4         | 0.0        | 0.000        |
| Gon             | 11.0        | 10.6       | 0.966        |
| Gonway          | 11.0        | 10.6       | 0.965        |
| Ijew            | 11.0        | 10.4       | 0.948        |
| Junct1          | 11.0        | 10.6       | 0.965        |
| Junct2          | 11.0        | 10.6       | 0.964        |
| Junct5          | 11.0        | 10.6       | 0.963        |
| MFATSolar       | 11.0        | 11.6       | 1.056        |
| Menen E1        | 11.0        | 10.6       | 0.965        |
| Menen E1(1)     | 11.0        | 10.2       | 0.929        |
| Menen N1        | 11.0        | 10.4       | 0.947        |
| Menen S2        | 11.0        | 10.6       | 0.960        |
| PS3.3kV-A       | 3.3         | 3.2        | 0.966        |
| PS3.3kV-B       | 3.3         | 3.2        | 0.966        |
| Pago            | 11.0        | 10.6       | 0.966        |
| RPC1            | 11.0        | 10.3       | 0.937        |
| RPC3RPC2Ronphos | 11.0        | 10.2       | 0.926        |
| RehabWorkshops  | 11.0        | 10.2       | 0.929        |
| Ronave          | 11.0        | 10.5       | 0.951        |
| Terrace         | 11.0        | 10.6       | 0.960        |
| TheBay          | 11.0        | 10.4       | 0.947        |
| UAESolar        | 11.0        | 10.6       | 0.964        |
| Waboe           | 11.0        | 10.5       | 0.959        |

Table 17 Thermal overloading results at field feeder out of service- scenario 1

| Name                             | HV-Side     | LV-Side        | HV-Side V p.u. | LV-Side Vn p.u. | Loading (%) |
|----------------------------------|-------------|----------------|----------------|-----------------|-------------|
| Line(32) - Express Feeder        | MFATSolar   | 11kVSolar      | 1.056          | 0.968           | 107.9       |
| 2-Winding Transformer            | MFATSolar   | Terminal       | 1.056          | 1.055           | 85.3        |
| 2-Winding Transformer - UAESolar | UAESolar    | Terminal(6)    | 0.964          | 1.000           | 24.9        |
| BESS1 2-Winding Transformer      | ADBSolar    | BESS1 Terminal | 1.056          | 1.100           | 82.0        |
| BESS2 2-Winding Transformer      | ADBSolar    | BESS2 Terminal | 1.056          | 1.100           | 73.2        |
| PV1 2-Winding Transformer        | ADBSolar    | PV1 Terminal   | 1.056          | 1.265           | 94.8        |
| PV2 2-Winding Transformer        | ADBSolar    | PV2 Terminal   | 1.056          | 1.265           | 94.8        |
| PV3 2-Winding Transformer        | ADBSolar    | PV3 Terminal   | 1.056          | 1.266           | 75.8        |
| T1                               | 11kVEast    | PS3.3kV-A      | 0.968          | 0.966           | 6.8         |
| T2                               | 11kVSouth   | PS3.3kV-A      | 0.968          | 0.966           | 6.8         |
| T3                               | 11kVNorth   | PS3.3kV-B      | 0.968          | 0.966           | 6.8         |
| T4                               | - 11kVField | PS3.3kV-B      | 0.966          | 0.966           | 0.0         |

#### 4.1.1.2 Contingency at Express Feeder

Following are the results for express feeder out of service.

- No voltage issues have been identified.
- Line(5) - Field Feeder is overloaded at 101.4%.

Table 18 Load flow results at express feeder out of service- scenario 1

| Name      | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|-----------|-------------|------------|--------------|
| 11kVEast  | 11.0        | 11.0       | 1.003        |
| 11kVField | 11.0        | 11.0       | 1.003        |
| 11kVNorth | 11.0        | 11.0       | 1.003        |
| 11kVSolar | 11.0        | 11.0       | 1.003        |
| 11kVSouth | 11.0        | 11.0       | 1.003        |
| ADBSolar  | 11.0        | 11.7       | 1.062        |

| Name            | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|-----------------|-------------|------------|--------------|
| Airport         | 11.0        | 11.0       | 1.000        |
| Anabar          | 11.0        | 10.8       | 0.985        |
| Arijejen        | 11.0        | 11.0       | 1.000        |
| Civic           | 11.0        | 11.0       | 1.001        |
| CommandRidge    | 11.0        | 11.1       | 1.010        |
| DomSub          | 11.0        | 11.1       | 1.010        |
| EUSolar         | 11.0        | 11.5       | 1.050        |
| FreshCentre     | 11.0        | 11.0       | 1.000        |
| FreshCentre_S1  | 11.0        | 11.0       | 0.997        |
| FuelTankFarm    | 11.0        | 11.1       | 1.010        |
| G10             | 0.4         | 0.0        | 0.000        |
| G2              | 0.4         | 0.0        | 0.000        |
| G2-1            | 11.0        | 0.0        | 0.000        |
| G3              | 0.4         | 0.0        | 0.000        |
| G3-1            | 11.0        | 0.0        | 0.000        |
| G4              | 11.0        | 0.0        | 0.000        |
| G5              | 0.4         | 0.0        | 0.000        |
| G6              | 0.4         | 0.0        | 0.000        |
| G7-8            | 0.4         | 0.0        | 0.000        |
| Gon             | 11.0        | 11.0       | 1.000        |
| Gonway          | 11.0        | 11.0       | 1.000        |
| Ijew            | 11.0        | 10.8       | 0.983        |
| Junct1          | 11.0        | 11.0       | 1.000        |
| Junct2          | 11.0        | 11.0       | 0.999        |
| Junct5          | 11.0        | 11.0       | 0.998        |
| MFATSolar       | 11.0        | 11.7       | 1.062        |
| Menen_E1        | 11.0        | 11.0       | 1.000        |
| Menen_E1(1)     | 11.0        | 11.5       | 1.050        |
| Menen_N1        | 11.0        | 10.8       | 0.983        |
| Menen_S2        | 11.0        | 10.9       | 0.995        |
| PS3.3kV-A       | 3.3         | 3.3        | 1.001        |
| PS3.3kV-B       | 3.3         | 3.3        | 1.001        |
| Pago            | 11.0        | 11.0       | 1.001        |
| RPC1            | 11.0        | 11.6       | 1.057        |
| RPC3RPC2Ronphos | 11.0        | 11.5       | 1.047        |
| RehabWorkshops  | 11.0        | 11.5       | 1.050        |
| Ronave          | 11.0        | 10.9       | 0.987        |
| Terrace         | 11.0        | 10.9       | 0.995        |
| TheBay          | 11.0        | 10.8       | 0.983        |
| UAESolar        | 11.0        | 11.0       | 0.999        |
| Waboe           | 11.0        | 10.9       | 0.994        |

Table 19 Thermal overloading results at express feeder out of service- scenario 1

| Name                             | HV-Side     | LV-Side        | HV-Side V p.u. | LV-Side Vn p.u. | Loading (%) |
|----------------------------------|-------------|----------------|----------------|-----------------|-------------|
| Line(5) - Field Feeder           | RPC1        | ADBSolar       | 1.057          | 1.062           | 101.0       |
| 2-Winding Transformer            | MFATSolar   | Terminal       | 1.062          | 1.061           | 84.9        |
| 2-Winding Transformer - UAESolar | UAESolar    | Terminal(6)    | 0.999          | 1.036           | 24          |
| BESS1 2-Winding Transformer      | ADBSolar    | BESS1 Terminal | 1.062          | 1.1             | 68.9        |
| BESS2 2-Winding Transformer      | ADBSolar    | BESS2 Terminal | 1.062          | 1.1             | 64.1        |
| PV1 2-Winding Transformer        | ADBSolar    | PV1 Terminal   | 1.062          | 1.272           | 94.3        |
| PV2 2-Winding Transformer        | ADBSolar    | PV2 Terminal   | 1.062          | 1.272           | 94.3        |
| PV3 2-Winding Transformer        | ADBSolar    | PV3 Terminal   | 1.062          | 1.273           | 75.4        |
| T1                               | 11kVEast    | PS3.3kV-A      | 1.003          | 1.001           | 6.6         |
| T2                               | 11kVSouth   | PS3.3kV-A      | 1.003          | 1.001           | 6.6         |
| T3                               | 11kVNorth   | PS3.3kV-B      | 1.003          | 1.001           | 6.6         |
| T4                               | - 11KVField | PS3.3kV-B      | 1.001          | 1.001           | 0           |

## 4.1.2 Scenario 2

In **Scenario 2**: Annual minimum load of 2 MW @ 0.93 p.f. 100% supply from BESS (in grid forming mode) and PV,

- No voltage and thermal loading issues have been identified.

**Table 20** Scenario 2 load flow results

| Name            | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|-----------------|-------------|------------|--------------|
| 11kVEast        | 11.0        | 11.1       | 1.008        |
| 11kVField       | 11.0        | 11.1       | 1.008        |
| 11kVNorth       | 11.0        | 11.1       | 1.008        |
| 11kVSolar       | 11.0        | 11.1       | 1.008        |
| 11kVSouth       | 11.0        | 11.1       | 1.008        |
| ADBSolar        | 11.0        | 11.2       | 1.015        |
| Airport         | 11.0        | 11.1       | 1.007        |
| Anabar          | 11.0        | 11.0       | 1.003        |
| Arijejen        | 11.0        | 11.1       | 1.007        |
| Civic           | 11.0        | 11.1       | 1.007        |
| CommandRidge    | 11.0        | 11.1       | 1.009        |
| DomSub          | 11.0        | 11.1       | 1.009        |
| EUSolar         | 11.0        | 11.1       | 1.012        |
| FreshCentre     | 11.0        | 11.1       | 1.007        |
| FreshCentre_S1  | 11.0        | 11.1       | 1.007        |
| FuelTankFarm    | 11.0        | 11.1       | 1.009        |
| G10             | 0.4         | 0.0        | 0.000        |
| G2              | 0.4         | 0.0        | 0.000        |
| G2-1            | 11.0        | 0.0        | 0.000        |
| G3              | 0.4         | 0.0        | 0.000        |
| G3-1            | 11.0        | 0.0        | 0.000        |
| G4              | 11.0        | 0.0        | 0.000        |
| G5              | 0.4         | 0.0        | 0.000        |
| G6              | 0.4         | 0.0        | 0.000        |
| G7-8            | 0.4         | 0.0        | 0.000        |
| Gon             | 11.0        | 11.1       | 1.007        |
| Gonway          | 11.0        | 11.1       | 1.007        |
| Ijew            | 11.0        | 11.0       | 1.003        |
| Junct1          | 11.0        | 11.1       | 1.007        |
| Junct2          | 11.0        | 11.1       | 1.007        |
| Junct5          | 11.0        | 11.1       | 1.007        |
| MFATSolar       | 11.0        | 11.2       | 1.015        |
| Menen_E1        | 11.0        | 11.1       | 1.007        |
| Menen_E1(1)     | 11.0        | 11.1       | 1.012        |
| Menen_N1        | 11.0        | 11.0       | 1.002        |
| Menen_S2        | 11.0        | 11.1       | 1.007        |
| PS3.3kV-A       | 3.3         | 3.3        | 1.007        |
| PS3.3kV-B       | 3.3         | 3.3        | 1.007        |
| Pago            | 11.0        | 11.1       | 1.007        |
| RPC1            | 11.0        | 11.2       | 1.014        |
| RPC3RPC2Ronphos | 11.0        | 11.1       | 1.012        |
| RehabWorkshops  | 11.0        | 11.1       | 1.012        |
| Ronave          | 11.0        | 11.0       | 1.004        |
| Terrace         | 11.0        | 11.1       | 1.007        |
| TheBay          | 11.0        | 11.0       | 1.002        |
| UAESolar        | 11.0        | 11.1       | 1.008        |
| Waboe           | 11.0        | 11.1       | 1.005        |

**Table 21** Scenario 2 thermal overloading results

| Name                             | HV-Side   | LV-Side        | HV-Side V p.u. | LV-Side V p.u. | Loading (%) |
|----------------------------------|-----------|----------------|----------------|----------------|-------------|
| 2-Winding Transformer            | MFATSolar | Terminal       | 1.015          | 1.015          | 26.6        |
| 2-Winding Transformer - UAESolar | UAESolar  | Terminal(6)    | 1.008          | 1.045          | 23.8        |
| BESS1 2-Winding Transformer      | ADBSolar  | BESS1 Terminal | 1.015          | 1.025          | 19.3        |
| BESS2 2-Winding Transformer      | ADBSolar  | BESS2 Terminal | 1.015          | 1.025          | 16.3        |
| PV1 2-Winding Transformer        | ADBSolar  | PV1 Terminal   | 1.015          | 1.218          | 22.2        |
| PV2 2-Winding Transformer        | ADBSolar  | PV2 Terminal   | 1.015          | 1.218          | 22.2        |
| PV3 2-Winding Transformer        | ADBSolar  | PV3 Terminal   | 1.015          | 1.218          | 17.7        |
| T1                               | 11kVEast  | PS3.3kV-A      | 1.008          | 1.007          | 1.7         |
| T2                               | 11kVSouth | PS3.3kV-A      | 1.008          | 1.007          | 1.7         |

| Name | HV-Side     | LV-Side   | HV-Side V p.u. | LV-Side V p.u. | Loading (%) |
|------|-------------|-----------|----------------|----------------|-------------|
| T3   | 11kVNorth   | PS3.3kV-B | 1.008          | 1.007          | 1.7         |
| T4   | - 11kVField | PS3.3kV-B | 1.007          | 1.007          | 0           |

### 4.1.3 Scenario 3

In **Scenario 3**: Annual maximum load of 7.5 MW @ 0.93 p.f. 100% supply from diesel power station (in existing location),

- The highest voltages in the network can be found at G7-8 (1.044 p.u.), G2 and G5 (1.031 p.u.).
- The lowest voltage in the network can be found at RPC3RPC2Ronphos (0.899 p.u.).
- The 2-winding transformers at T1, T2 and T3 are overloaded at ~113.6% loading.

Table 22 Scenario 3 load flow results

| Name            | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|-----------------|-------------|------------|--------------|
| 11kVEast        | 11.0        | 10.2       | 0.927        |
| 11kVField       | 11.0        | 10.2       | 0.927        |
| 11kVNorth       | 11.0        | 10.2       | 0.927        |
| 11kVSolar       | 11.0        | 10.2       | 0.927        |
| 11kVSouth       | 11.0        | 10.2       | 0.927        |
| ADBSolar        | 11.0        | 10.0       | 0.911        |
| Airport         | 11.0        | 10.2       | 0.924        |
| Anabar          | 11.0        | 10.0       | 0.907        |
| Arijejen        | 11.0        | 10.2       | 0.923        |
| Civic           | 11.0        | 10.2       | 0.925        |
| CommandRidge    | 11.0        | 10.2       | 0.924        |
| DomSub          | 11.0        | 10.2       | 0.924        |
| EUSolar         | 11.0        | 9.9        | 0.902        |
| FreshCentre     | 11.0        | 10.2       | 0.924        |
| FreshCentre_S1  | 11.0        | 10.1       | 0.919        |
| FuelTankFarm    | 11.0        | 10.2       | 0.924        |
| G10             | 0.4         | 0.4        | 1.000        |
| G2              | 0.4         | 0.4        | 1.031        |
| G2-1            | 11.0        | 11.0       | 1.000        |
| G3              | 0.4         | 0.0        | 0.000        |
| G3-1            | 11.0        | 0.0        | 0.000        |
| G4              | 11.0        | 10.6       | 0.965        |
| G5              | 0.4         | 0.4        | 1.031        |
| G6              | 0.4         | 0.0        | 0.000        |
| G7-8            | 0.4         | 0.4        | 1.044        |
| Gon             | 11.0        | 10.2       | 0.924        |
| Gonway          | 11.0        | 10.2       | 0.924        |
| Ijew            | 11.0        | 10.0       | 0.906        |
| Junct1          | 11.0        | 10.2       | 0.923        |
| Junct2          | 11.0        | 10.1       | 0.922        |
| Junct5          | 11.0        | 10.1       | 0.920        |
| MFATSolar       | 11.0        | 10.0       | 0.911        |
| Menen_E1        | 11.0        | 10.2       | 0.923        |
| Menen_E1(1)     | 11.0        | 9.9        | 0.902        |
| Menen_N1        | 11.0        | 10.0       | 0.905        |
| Menen_S2        | 11.0        | 10.1       | 0.917        |
| PS3.3kV-A       | 3.3         | 3.2        | 0.964        |
| PS3.3kV-B       | 3.3         | 3.2        | 0.964        |
| Pago            | 11.0        | 10.2       | 0.924        |
| RPC1            | 11.0        | 10.0       | 0.911        |
| RPC3RPC2Ronphos | 11.0        | 9.9        | 0.899        |
| RehabWorkshops  | 11.0        | 9.9        | 0.902        |
| Ronave          | 11.0        | 10.0       | 0.909        |
| Terrace         | 11.0        | 10.1       | 0.917        |
| TheBay          | 11.0        | 10.0       | 0.905        |
| UAESolar        | 11.0        | 10.1       | 0.921        |

| Name  | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|-------|-------------|------------|--------------|
| Waboe | 11.0        | 10.1       | 0.917        |

Table 23 Scenario 3 thermal overloading results

| Name                     | HV-Side     | LV-Side   | HV-Side V p.u. | LV-Side Vn p.u. | Loading (%) |
|--------------------------|-------------|-----------|----------------|-----------------|-------------|
| CATG7TX                  | PS3.3kV-A   | G7-8      | 0.964          | 1.044           | 0.1         |
| GEN 2A & G2B Transformer | PS3.3kV-B   | G2        | 0.964          | 1.031           | 85.6        |
| GEN 4 Rus Transformer    | G4          | PS3.3kV-B | 0.965          | 0.964           | 5.7         |
| GEN 5 TX                 | PS3.3kV-B   | G5        | 0.964          | 1.031           | 85.6        |
| MAN2TX                   | G2-1        | PS3.3kV-B | 1.000          | 0.964           | 81.3        |
| T1 <sup>2</sup>          | 11kVEast    | PS3.3kV-A | 0.927          | 0.964           | 113.6       |
| T2                       | 11kVSouth   | PS3.3kV-A | 0.927          | 0.964           | 113.6       |
| T3                       | 11kVNorth   | PS3.3kV-B | 0.927          | 0.964           | 113.8       |
| T4                       | - 11kVField | PS3.3kV-B | 0.965          | 0.965           | 0           |

## 4.1.4 Scenario 4

In **Scenario 4**: Annual minimum load of 2 MW @ 0.93 p.f. 100% supply from diesel power station (in existing location),

- No voltage and thermal loading issues have been identified.
- The highest voltage in the network are at G7-8 (1.062 p.u.).

Table 24 Scenario 4 load flow results

| Name           | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|----------------|-------------|------------|--------------|
| 11kVEast       | 11.0        | 10.7       | 0.971        |
| 11kVField      | 11.0        | 10.7       | 0.971        |
| 11kVNorth      | 11.0        | 10.7       | 0.971        |
| 11kVSolar      | 11.0        | 10.7       | 0.971        |
| 11kVSouth      | 11.0        | 10.7       | 0.971        |
| ADBSolar       | 11.0        | 10.6       | 0.967        |
| Airport        | 11.0        | 10.7       | 0.970        |
| Anabar         | 11.0        | 10.6       | 0.966        |
| Arijejen       | 11.0        | 10.7       | 0.970        |
| Civic          | 11.0        | 10.7       | 0.970        |
| CommandRidge   | 11.0        | 10.7       | 0.971        |
| DomSub         | 11.0        | 10.7       | 0.971        |
| EUSolar        | 11.0        | 10.6       | 0.965        |
| FreshCentre    | 11.0        | 10.7       | 0.970        |
| FreshCentre_S1 | 11.0        | 10.7       | 0.969        |
| FuelTankFarm   | 11.0        | 10.7       | 0.971        |
| G10            | 0.4         | 0.4        | 1.018        |
| G2             | 0.4         | 0.4        | 1.028        |
| G2-1           | 11.0        | 11.0       | 1.000        |
| G3             | 0.4         | 0.0        | 0.000        |
| G3-1           | 11.0        | 0.0        | 0.000        |
| G4             | 11.0        | 0.0        | 0.000        |
| G5             | 0.4         | 0.0        | 0.000        |
| G6             | 0.4         | 0.0        | 0.000        |
| G7-8           | 0.4         | 0.4        | 1.062        |
| Gon            | 11.0        | 10.7       | 0.970        |
| Gonway         | 11.0        | 10.7       | 0.970        |
| Ijew           | 11.0        | 10.6       | 0.966        |
| Junct1         | 11.0        | 10.7       | 0.970        |
| Junct2         | 11.0        | 10.7       | 0.970        |
| Junct5         | 11.0        | 10.7       | 0.970        |
| MFATSolar      | 11.0        | 10.6       | 0.967        |
| Menen_E1       | 11.0        | 10.7       | 0.970        |
| Menen_E1(1)    | 11.0        | 10.6       | 0.965        |

<sup>2</sup> There will be no overloading at T1, T2, and T3 if T4 is connected.

| Name            | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|-----------------|-------------|------------|--------------|
| Menen_N1        | 11.0        | 10.6       | 0.966        |
| Menen_S2        | 11.0        | 10.7       | 0.969        |
| PS3.3kV-A       | 3.3         | 3.2        | 0.981        |
| PS3.3kV-B       | 3.3         | 3.2        | 0.981        |
| Pago            | 11.0        | 10.7       | 0.970        |
| RPC1            | 11.0        | 10.6       | 0.967        |
| RPC3RPC2Ronphos | 11.0        | 10.6       | 0.964        |
| RehabWorkshops  | 11.0        | 10.6       | 0.965        |
| Ronave          | 11.0        | 10.6       | 0.967        |
| Terrace         | 11.0        | 10.7       | 0.969        |
| TheBay          | 11.0        | 10.6       | 0.966        |
| UAESolar        | 11.0        | 10.7       | 0.970        |
| Waboe           | 11.0        | 10.7       | 0.969        |

Table 25 Scenario 4 thermal overloading results

| Name                     | HV-Side     | LV-Side   | HV-Side V p.u. | LV-Side Vn p.u. | Loading (%) |
|--------------------------|-------------|-----------|----------------|-----------------|-------------|
| GEN 2A & G2B Transformer | PS3.3kV-B   | G2        | 0.981          | 1.028           | 47.3        |
| MAN2TX                   | G2-1        | PS3.3kV-B | 1              | 0.981           | 43.8        |
| T1                       | 11kVEast    | PS3.3kV-A | 0.971          | 0.981           | 30.8        |
| T2                       | 11kVSouth   | PS3.3kV-A | 0.971          | 0.981           | 30.8        |
| T3                       | 11kVNorth   | PS3.3kV-B | 0.971          | 0.981           | 30.8        |
| T4                       | - 11kVField | PS3.3kV-B | 0.981          | 0.981           | 0           |

## 4.1.5 Scenario 5

In **Scenario 5**: Moderate load of 5.5 MW @ 0.93 p.f., with 52% of supply coming from PV and 48% from diesel generation.

- No overvoltage and thermal overloading of the transformers were observed.

Table 26 Scenario 5 load flow results

| Name           | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|----------------|-------------|------------|--------------|
| 11kVEast       | 11.0        | 10.7       | 0.971        |
| 11kVField      | 11.0        | 10.7       | 0.971        |
| 11kVNorth      | 11.0        | 10.7       | 0.971        |
| 11kVSolar      | 11.0        | 10.7       | 0.971        |
| 11kVSouth      | 11.0        | 10.7       | 0.971        |
| ADBSolar       | 11.0        | 10.6       | 0.967        |
| Airport        | 11.0        | 10.7       | 0.970        |
| Anabar         | 11.0        | 10.6       | 0.966        |
| Arijejen       | 11.0        | 10.7       | 0.970        |
| Civic          | 11.0        | 10.7       | 0.970        |
| CommandRidge   | 11.0        | 10.7       | 0.971        |
| DomSub         | 11.0        | 10.7       | 0.971        |
| EUSolar        | 11.0        | 10.6       | 0.965        |
| FreshCentre    | 11.0        | 11.1       | 1.008        |
| FreshCentre_S1 | 11.0        | 11.1       | 1.008        |
| FuelTankFarm   | 11.0        | 11.1       | 1.008        |
| G10            | 11.0        | 11.1       | 1.008        |
| G2             | 11.0        | 11.1       | 1.008        |
| G2-1           | 11.0        | 11.1       | 1.013        |
| G3             | 11.0        | 11.1       | 1.006        |
| G3-1           | 11.0        | 10.9       | 0.995        |
| G4             | 11.0        | 11.1       | 1.005        |
| G5             | 11.0        | 11.1       | 1.006        |
| G6             | 11.0        | 11.1       | 1.008        |
| G7-8           | 11.0        | 11.1       | 1.008        |
| Gon            | 11.0        | 11.1       | 1.006        |
| Gonway         | 11.0        | 11.1       | 1.006        |
| Ijew           | 11.0        | 11.0       | 1.003        |

| Name            | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|-----------------|-------------|------------|--------------|
| Junct1          | 11.0        | 11.1       | 1.008        |
| Junct2          | 0.4         | 0.4        | 1.058        |
| Junct5          | 0.4         | 0.4        | 1.058        |
| MFATSolar       | 11.0        | 12.1       | 1.100        |
| Menen_E1        | 0.4         | 0.0        | 0.000        |
| Menen_E1(1)     | 11.0        | 0.0        | 0.000        |
| Menen_N1        | 11.0        | 11.2       | 1.019        |
| Menen_S2        | 0.4         | 0.4        | 1.063        |
| PS3.3kV-A       | 0.4         | 0.0        | 0.000        |
| PS3.3kV-B       | 0.4         | 0.4        | 1.103        |
| Pago            | 11.0        | 11.1       | 1.006        |
| RPC1            | 11.0        | 11.1       | 1.006        |
| RPC3RPC2Ronphos | 11.0        | 10.9       | 0.993        |
| RehabWorkshops  | 11.0        | 11.1       | 1.006        |
| Ronave          | 11.0        | 11.1       | 1.005        |
| Terrace         | 11.0        | 11.0       | 1.004        |
| TheBay          | 11.0        | 11.1       | 1.013        |
| UAEsolar        | 11.0        | 11.1       | 1.005        |
| Waboe           | 11.0        | 11.1       | 1.006        |

Table 27 Scenario 5 thermal overloading results

| Name                             | HV-Side     | LV-Side        | HV-Side V p.u. | LV-Side Vn p.u. | Loading (%) |
|----------------------------------|-------------|----------------|----------------|-----------------|-------------|
| 2-Winding Transformer            | MFATSolar   | Terminal       | 1.013          | 1.012           | 69.2        |
| 2-Winding Transformer - UAESolar | UAESolar    | Terminal(6)    | 1.005          | 1.042           | 15.9        |
| BESS1 2-Winding Transformer      | ADBSolar    | BESS1 Terminal | 1.013          | 1.025           | 20.3        |
| BESS2 2-Winding Transformer      | ADBSolar    | BESS2 Terminal | 1.013          | 1.025           | 20.3        |
| GEN 5 TX                         | PS3.3kV-B   | G5             | 1.019          | 1.063           | 58.6        |
| MAN2TX                           | G2-1        | PS3.3kV-B      | 1.1            | 1.019           | 55.2        |
| PV1 2-Winding Transformer        | ADBSolar    | PV1 Terminal   | 1.013          | 1.215           | 34.6        |
| PV2 2-Winding Transformer        | ADBSolar    | PV2 Terminal   | 1.013          | 1.215           | 34.6        |
| PV3 2-Winding Transformer        | ADBSolar    | PV3 Terminal   | 1.013          | 1.215           | 27.6        |
| T1                               | 11kVEast    | PS3.3kV-A      | 1.008          | 1.019           | 34.7        |
| T2                               | 11kVSouth   | PS3.3kV-A      | 1.008          | 1.019           | 34.7        |
| T3                               | 11kVNorth   | PS3.3kV-B      | 1.008          | 1.019           | 34.7        |
| T4                               | - 11kVField | PS3.3kV-B      | 1.019          | 1.019           | 0           |

## 4.1.6 Scenario 6

**Scenario 6:** Annual minimum load of 2 MW @ 0.93 p.f. 100% supply from BESS (PV off and diesel off mode);

- No overvoltage and thermal overloading of the transformers were observed.

Table 28 Scenario 6 load flow results

| Name           | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|----------------|-------------|------------|--------------|
| 11kVEast       | 11.0        | 11.1       | 1.006        |
| 11kVField      | 11.0        | 11.1       | 1.006        |
| 11kVNorth      | 11.0        | 11.1       | 1.006        |
| 11kVSolar      | 11.0        | 11.1       | 1.006        |
| 11kVSouth      | 11.0        | 11.1       | 1.006        |
| ADBSolar       | 11.0        | 11.2       | 1.015        |
| Airport        | 11.0        | 11.1       | 1.006        |
| Anabar         | 11.0        | 11.0       | 1.002        |
| Arijejen       | 11.0        | 11.1       | 1.005        |
| Civic          | 11.0        | 11.1       | 1.006        |
| CommandRidge   | 11.0        | 11.1       | 1.007        |
| DomSub         | 11.0        | 11.1       | 1.007        |
| EUSolar        | 11.0        | 11.1       | 1.012        |
| FreshCentre    | 11.0        | 11.1       | 1.005        |
| FreshCentre S1 | 11.0        | 11.0       | 1.004        |
| FuelTankFarm   | 11.0        | 11.1       | 1.007        |

| Name            | Nom.L-L kV. | Voltage kV | Voltage p.u. |
|-----------------|-------------|------------|--------------|
| G10             | 0.4         | 0.0        | 0.000        |
| G2              | 0.4         | 0.0        | 0.000        |
| G2-1            | 11.0        | 0.0        | 0.000        |
| G3              | 0.4         | 0.0        | 0.000        |
| G3-1            | 11.0        | 0.0        | 0.000        |
| G4              | 11.0        | 0.0        | 0.000        |
| G5              | 0.4         | 0.0        | 0.000        |
| G6              | 0.4         | 0.0        | 0.000        |
| G7-8            | 0.4         | 0.0        | 0.000        |
| Gon             | 11.0        | 11.1       | 1.005        |
| Gonway          | 11.0        | 11.1       | 1.005        |
| Ijew            | 11.0        | 11.0       | 1.001        |
| Junct1          | 11.0        | 11.1       | 1.005        |
| Junct2          | 11.0        | 11.1       | 1.005        |
| Junct5          | 11.0        | 11.1       | 1.005        |
| MFATSolar       | 11.0        | 11.2       | 1.015        |
| Menen E1        | 11.0        | 11.1       | 1.005        |
| Menen E1(1)     | 11.0        | 11.1       | 1.012        |
| Menen N1        | 11.0        | 11.0       | 1.001        |
| Menen S2        | 11.0        | 11.0       | 1.004        |
| PS3.3kV-A       | 3.3         | 3.3        | 1.006        |
| PS3.3kV-B       | 3.3         | 3.3        | 1.006        |
| Pago            | 11.0        | 11.1       | 1.006        |
| RPC1            | 11.0        | 11.2       | 1.014        |
| RPC3RPC2Ronphos | 11.0        | 11.1       | 1.011        |
| RehabWorkshops  | 11.0        | 11.1       | 1.012        |
| Ronave          | 11.0        | 11.0       | 1.002        |
| Terrace         | 11.0        | 11.0       | 1.004        |
| TheBay          | 11.0        | 11.0       | 1.001        |
| UAESolar        | 11.0        | 11.1       | 1.005        |
| Waboe           | 11.0        | 11.0       | 1.004        |

Table 29 Scenario 6 thermal overloading results

| Name                        | HV-Side     | LV-Side        | HV-Side V p.u. | LV-Side Vn p.u. | Loading (%) |
|-----------------------------|-------------|----------------|----------------|-----------------|-------------|
| BESS1 2-Winding Transformer | ADBSolar    | BESS1 Terminal | 1.015          | 1.025           | 80.7        |
| BESS2 2-Winding Transformer | ADBSolar    | BESS2 Terminal | 1.015          | 1.025           | 16.8        |
| T1                          | 11kVEast    | PS3.3kV-A      | 1.006          | 1.006           | 1.7         |
| T2                          | 11kVSouth   | PS3.3kV-A      | 1.006          | 1.006           | 1.7         |
| T3                          | 11kVNorth   | PS3.3kV-B      | 1.006          | 1.006           | 1.7         |
| T4                          | - 11kVField | PS3.3kV-B      | 1.006          | 1.006           | 1.7         |

## 4.2 Fault Study Results

The results presented below are for the maximum and minimum fault level cases. Three-phase short-circuit and single phase to ground faults are performed at every bus within the NUC network. Various fault contribution levels were considered for the solar PV and BESS. Several variations in the network configuration, i.e., whether FF and/or EF are closed or open, were also considered.

The results of the fault currents for three-phase short-circuit and single phase to ground faults at individual buses are shown in the following sections. As per DQ01-001 Electrical Single Line Diagram 2022.09.23 11 kV solar busbar is rated to 31.5 kA for 3 seconds. For each scenario, the ADBSolar fault currents are compared with this rating of the busbar.

## 4.2.1 Summary of Fault Study

- For all six scenarios simulated, the ADBSolar fault currents are within the rating of the busbar.
- Maximum fault currents are observed during scenario 5 at mixed operation of renewables and diesel. Minimum fault currents are observed during scenarios 6 at BESS only (PV and diesel off) operation.
- The maximum fault currents at the 11kV solar busbar even for shorter durations are well under the limit of 31.5 kA.

Table 30 and Table 31 provide the maximum and minimum three-phase fault levels, respectively, calculated for all the buses in the network.

- Table 30 may be used as reference to determine whether the maximum fault currents for all buses are within the fault current ratings of their respective circuit breakers and switchgears. serves as a reference for the assessment of overcurrent protection to ensure that the protective devices will operate at the lowest possible level of short-circuit current that can occur. A separate Nauru Protection System Assessment report contains the said assessment.

**Table 30** Summary of Maximum 3-Phase Fault Levels – BESS fault contribution 2.0 p.u , Solar contribution 1.5 p.u

| Name           | S1 1k" kA | S3 1k" kA | S5 1k" kA | Maximum kA (Scenario 5) |
|----------------|-----------|-----------|-----------|-------------------------|
| 11kVEast       | 0.984     | 1.713     | 2.671     | 2.671                   |
| 11kVField      | 0.984     | 1.713     | 2.671     | 2.671                   |
| 11kVNorth      | 0.984     | 1.713     | 2.671     | 2.671                   |
| 11kVSolar      | 0.984     | 1.713     | 2.671     | 2.671                   |
| 11kVSouth      | 0.984     | 1.713     | 2.671     | 2.671                   |
| ADBSolar       | 1.103     | 1.451     | 2.538     | 2.538                   |
| Airport        | 0.949     | 1.630     | 2.454     | 2.454                   |
| Anabar         | 0.738     | 1.110     | 1.418     | 1.418                   |
| Arijejen       | 0.954     | 1.634     | 2.474     | 2.474                   |
| Civic          | 0.962     | 1.661     | 2.535     | 2.535                   |
| CommandRidge   | 0.984     | 1.641     | 2.561     | 2.561                   |
| DomSub         | 0.984     | 1.641     | 2.562     | 2.562                   |
| EUSolar        | 0.932     | 1.186     | 1.803     | 1.803                   |
| FreshCentre    | 0.931     | 1.584     | 2.342     | 2.342                   |
| FreshCentre_S1 | 0.851     | 1.380     | 1.896     | 1.896                   |
| FuelTankFarm   | 0.984     | 1.641     | 2.562     | 2.562                   |
| G10            | 0.000     | 14.665    | 26.305    | 26.305                  |
| G2             | 0.000     | 31.454    | 34.184    | 34.184                  |
| G2-1           | 0.000     | 1.982     | 2.268     | 2.268                   |
| G3             | 0.000     | 0.000     | 0.000     | 0.000                   |
| G3-1           | 0.000     | 0.000     | 0.000     | 0.000                   |
| G4             | 0.000     | 2.249     | 2.990     | 2.990                   |
| G5             | 0.000     | 31.667    | 34.418    | 34.418                  |
| G6             | 0.000     | 0.000     | 0.000     | 0.000                   |
| G7-8           | 0.000     | 55.602    | 75.038    | 75.038                  |
| Gon            | 0.946     | 1.622     | 2.436     | 2.436                   |
| Gonway         | 0.933     | 1.589     | 2.354     | 2.354                   |
| Ijew           | 0.715     | 1.065     | 1.337     | 1.337                   |
| Junct1         | 0.936     | 1.581     | 2.354     | 2.354                   |
| Junct2         | 0.904     | 1.495     | 2.163     | 2.163                   |
| Junct5         | 0.871     | 1.425     | 1.997     | 1.997                   |
| MFATSolar      | 1.103     | 1.451     | 2.538     | 2.538                   |
| Menen_E1       | 0.891     | 1.487     | 2.114     | 2.114                   |
| Menen_E1(1)    | 0.864     | 1.082     | 1.566     | 1.566                   |
| Menen_N1       | 0.645     | 0.921     | 1.113     | 1.113                   |
| Menen_S2       | 0.738     | 1.114     | 1.416     | 1.416                   |
| PS3.3kV-A      | 2.857     | 7.726     | 10.497    | 10.497                  |
| PS3.3kV-B      | 2.857     | 7.726     | 10.497    | 10.497                  |
| Pago           | 0.951     | 1.633     | 2.463     | 2.463                   |
| RPC1           | 1.090     | 1.451     | 2.508     | 2.508                   |

| Name            | S1 1k" kA | S3 1k" kA | S5 1k" kA | Maximum kA (Scenario 5) |
|-----------------|-----------|-----------|-----------|-------------------------|
| RPC3RPC2Ronphos | 0.972     | 1.253     | 1.961     | 1.961                   |
| RehabWorkshops  | 1.008     | 1.311     | 2.113     | 2.113                   |
| Ronave          | 0.777     | 1.198     | 1.570     | 1.570                   |
| Terrace         | 0.790     | 1.231     | 1.618     | 1.618                   |
| TheBay          | 0.671     | 0.973     | 1.192     | 1.192                   |
| UAESolar        | 0.893     | 1.470     | 2.104     | 2.104                   |
| Waboe           | 0.881     | 1.445     | 2.048     | 2.048                   |

Table 31 Summary of Minimum 3-Phase Fault Levels – BESS fault contribution = 2.0 p.u., Solar contribution = 1.5 p.u.

| Name            | S2 1k" kA | S4 1k" kA | S5 1k" kA | S6 1k" kA | Minimum kA (Scenario 6) |
|-----------------|-----------|-----------|-----------|-----------|-------------------------|
| 11kVEast        | 0.868     | 0.870     | 2.057     | 0.277     | 0.277                   |
| 11kVField       | 0.868     | 0.870     | 2.057     | 0.272     | 0.272                   |
| 11kVNorth       | 0.868     | 0.870     | 2.057     | 0.240     | 0.240                   |
| 11kVSolar       | 0.868     | 0.870     | 2.057     | 0.238     | 0.238                   |
| 11kVSouth       | 0.868     | 0.870     | 2.057     | 0.273     | 0.273                   |
| ADBSolar        | 0.960     | 0.789     | 1.407     | 0.253     | 0.253                   |
| Airport         | 0.838     | 0.844     | 1.148     | 0.275     | 0.275                   |
| Anabar          | 0.655     | 0.663     | 0.789     | 0.275     | 0.275                   |
| Arijejen        | 0.843     | 0.846     | 1.792     | 0.252     | 0.252                   |
| Civic           | 0.850     | 0.854     | 1.461     | 0.222     | 0.222                   |
| CommandRidge    | 0.868     | 0.848     | 1.830     | 0.246     | 0.246                   |
| DomSub          | 0.868     | 0.849     | 1.831     | 0.275     | 0.275                   |
| EUSolar         | 0.820     | 0.694     | 0.919     | 0.000     | 0.000                   |
| FreshCentre     | 0.821     | 0.829     | 0.848     | 0.000     | 0.000                   |
| FreshCentre S1  | 0.750     | 0.759     | 1.006     | 0.000     | 0.000                   |
| FuelTankFarm    | 0.868     | 0.849     | 1.831     | 0.000     | 0.000                   |
| G10             | 0.000     | 15.440    | 27.080    | 0.000     | 0.000                   |
| G2              | 0.000     | 22.083    | 38.453    | 0.000     | 0.000                   |
| G2-1            | 0.000     | 1.197     | 1.781     | 0.000     | 0.000                   |
| G3              | 0.000     | 0.000     | 0.000     | 0.000     | 0.000                   |
| G3-1            | 0.000     | 0.000     | 0.000     | 0.000     | 0.000                   |
| G4              | 0.000     | 0.000     | 1.750     | 0.237     | 0.237                   |
| G5              | 0.000     | 0.000     | 38.617    | 0.224     | 0.224                   |
| G6              | 0.000     | 0.000     | 0.000     | 0.228     | 0.228                   |
| G7-8            | 0.000     | 25.473    | 100.504   | 0.270     | 0.270                   |
| Gon             | 0.835     | 0.841     | 1.088     | 0.265     | 0.265                   |
| Gonway          | 0.823     | 0.830     | 0.874     | 0.253     | 0.253                   |
| Ijew            | 0.633     | 0.643     | 0.689     | 0.272     | 0.272                   |
| Junct1          | 0.828     | 0.830     | 1.642     | 0.191     | 0.191                   |
| Junct2          | 0.800     | 0.802     | 1.429     | 0.243     | 0.243                   |
| Junct5          | 0.769     | 0.776     | 1.140     | 0.214     | 0.214                   |
| MFATSolar       | 0.960     | 0.789     | 1.407     | 0.228     | 0.228                   |
| Menen_E1        | 0.785     | 0.796     | 0.518     | 0.916     | 0.916                   |
| Menen_E1(1)     | 0.761     | 0.651     | 0.779     | 0.916     | 0.916                   |
| Menen_N1        | 0.571     | 0.580     | 0.556     | 0.241     | 0.241                   |
| Menen_S2        | 0.651     | 0.660     | 0.711     | 0.272     | 0.272                   |
| PS3.3kV-A       | 2.549     | 3.345     | 12.818    | 0.258     | 0.258                   |
| PS3.3kV-B       | 2.549     | 3.345     | 12.818    | 0.262     | 0.262                   |
| Pago            | 0.839     | 0.845     | 1.177     | 0.245     | 0.245                   |
| RPC1            | 0.950     | 0.789     | 1.403     | 0.237     | 0.237                   |
| RPC3RPC2Ronphos | 0.854     | 0.720     | 1.021     | 0.219     | 0.219                   |
| RehabWorkshops  | 0.884     | 0.742     | 1.120     | 0.261     | 0.261                   |
| Ronave          | 0.690     | 0.698     | 0.902     | 0.262     | 0.262                   |
| Terrace         | 0.697     | 0.706     | 0.831     | 0.277     | 0.277                   |
| TheBay          | 0.594     | 0.604     | 0.602     | 0.272     | 0.272                   |
| UAESolar        | 0.789     | 0.793     | 1.312     | 0.240     | 0.240                   |
| Waboe           | 0.780     | 0.786     | 1.319     | 0.238     | 0.238                   |

## 4.2.2 Fault study with solar interconnector failure contingency event

Table 32 The impact of opening the interconnector-field tie for different fault scenarios which may be required in a solar interconnector failure contingency event is assessed in this section.

The fault levels at ADB solar, 11 kV field, Menen\_E1(1) and Menen\_N1 buses are presented in Table 32 and Table 33 below during following network arrangements.

**Table 32 Diesel OFF fault levels (Scenario 1) – BESS fault contribution = 2.0 p.u., Solar fault contribution = 1.5 p.u.**

| Network Configuration |        | Fault Location | Load Current | 3 ph Ik" kA | 3 ph Sk" MVA | 1 ph Ik" A kA | 1 ph Sk" A MVA |
|-----------------------|--------|----------------|--------------|-------------|--------------|---------------|----------------|
| NOP                   | FF     |                |              |             |              |               |                |
| Open                  | Closed | ADB Solar      | 0.366        | 0.959       | 18.3         | 0.618         | 3.9            |
|                       |        | 11kV Field     | 0.255        | 0.860       | 16.4         | 0.661         | 4.2            |
|                       |        | Menen_E1(1)    | 0.000        | 0.724       | 13.8         | 0.443         | 2.8            |
|                       |        | Menen_N1       | 0.000        | 0.519       | 9.9          | 0.328         | 2.1            |
| Closed                | Closed | ADB Solar      | 0.365        | 0.959       | 18.3         | 0.631         | 4.0            |
|                       |        | 11kV Field     | 0.193        | 0.887       | 16.9         | 0.671         | 4.3            |
|                       |        | Menen_E1(1)    | 0.060        | 0.867       | 16.5         | 0.572         | 3.6            |
|                       |        | Menen_N1       | 0.060        | 0.867       | 16.5         | 0.572         | 3.6            |
| Closed                | Open   | ADB Solar      | 0.399        | 0.955       | 18.2         | 0.538         | 3.4            |
|                       |        | 11kV Field     | 0.438        | 0.806       | 15.4         | 0.626         | 4.0            |
|                       |        | Menen_E1(1)    | 0.070        | 0.761       | 14.5         | 0.519         | 3.3            |
|                       |        | Menen_N1       | 0.093        | 0.761       | 14.5         | 0.519         | 3.3            |

**Table 33 Diesel ON fault levels (Scenario 3) – BESS fault contribution = 2.0 p.u., Solar fault contribution = 1.5 p.u.**

| Network Configuration |        | Fault Location | Load Current | 3 ph Ik" kA | 3 ph Sk" MVA | 1 ph Ik" A kA | 1 ph Sk" A MVA |
|-----------------------|--------|----------------|--------------|-------------|--------------|---------------|----------------|
| NOP                   | FF     |                |              |             |              |               |                |
| Open                  | Closed | ADB Solar      | 0.079        | 1.380       | 26.3         | 1.187         | 7.5            |
|                       |        | 11kV Field     | 0.174        | 1.676       | 31.9         | 1.764         | 11.2           |
|                       |        | Menen_E1(1)    | 0.000        | 0.973       | 18.5         | 0.688         | 4.4            |
|                       |        | Menen_N1       | 0.000        | 0.803       | 15.3         | 0.512         | 3.2            |
| Closed                | Closed | ADB Solar      | 0.054        | 1.442       | 27.5         | 1.270         | 8.1            |
|                       |        | 11kV Field     | 0.124        | 1.676       | 31.9         | 1.764         | 11.2           |
|                       |        | Menen_E1(1)    | 0.050        | 1.526       | 29.1         | 1.200         | 7.6            |
|                       |        | Menen_N1       | 0.076        | 1.526       | 29.1         | 1.200         | 7.6            |
| Closed                | Open   | ADB Solar      | 0.000        | 1.154       | 22.0         | 0.905         | 5.7            |
|                       |        | 11kV Field     | 0.102        | 1.676       | 31.9         | 1.765         | 11.2           |
|                       |        | Menen_E1(1)    | 0.073        | 1.522       | 29.0         | 1.168         | 7.4            |
|                       |        | Menen_N1       | 0.096        | 1.522       | 29.0         | 1.168         | 7.4            |

## 5. Conclusion and Next Steps

### 5.1 Thermal Constraints and Voltage Regulation

#### *Normal Conditions*

Six operation scenarios were considered in this study: minimum and maximum demand scenarios with either renewable only or diesel generation only, as well as a moderate load scenario with a mix of renewable and diesel generators in operation, and a minimum load scenario with BESS only.

No overvoltages were observed for the operation scenarios considered. At diesel only at maximum load operation, undervoltage was observed at RPC3RPC2Ronphos 11kV bus, which was at 9.89 kV (0.899 p.u.). In the same scenario, three main transformers T1, T2 and T3 were all overloaded at ~114%. This is however due to the load growth modelled and not associated with the connection of the solar or BESS.

#### *Contingency Events*

In Diesel Off mode at maximum demand (Scenario 1), two contingency events were simulated: (1) Express Feeder Network Configuration, in which the Field Feeder is open or faulted, and (2) Field Feeder Network Configuration, in which the Express Feeder is open or faulted.

During the Express Feeder network configuration (i.e. Field feeder open or faulted) and maximum load when running in diesel off mode (scenario 1), the Solar Interconnector Express Feeder conductor is overloaded (108.5%) based on the Krypton conductor rating of 410 A<sup>9</sup>. Conversely, during the Field Feeder network configuration (i.e., Express Feeder open or faulted) and maximum load when running in diesel off mode (scenario 1), the Field Feeder conductor is overloaded (101.4%). It is therefore recommended that a protection or control system be put in place to prevent this overload and dispatch additional gensets if required.

It is also recommended that the System to be nominally operated in Distributed Generation network configuration (i.e., both feeders closed).

#### **Study recommendations and future works:**

The primary objective of this steady state modelling is to ensure the equipment will not have thermal overloading, voltage regulation issues at different load and generation dispatch scenarios. GHD has developed the DigSILENT model based on information made available by NUC. However, the effective As Built information had a number of limitations and assumptions to be made. To further improve the model, a process of validation of the models could be undertaken by NUC including:

- Generator governor and real power capability curves.
- Transformer tap settings.
- Network configuration verification
- Equipment fault ratings
- Detailed load measurements per transformation (rather than scaling based on nameplate rating)

### 5.2 Fault Study

Fault studies were conducted to determine the minimum and maximum fault currents from the six operational scenarios.<sup>10</sup> Among the six scenarios, maximum fault currents were observed for the mixed operation of renewables and diesel (Scenario 5), while minimum fault currents were observed for the BESS only operation (Scenario 6).

<sup>9</sup> But at 1m/s wind-speed, 35 degrees Celsius and industrialised derating is 459 A (8.7 MVA @ 11 kV)

<sup>10</sup> Minimum short-circuit analyses for the minimum demand scenarios (Scenarios 2 and 4) were re-run to accommodate new information on transformer impedances, UAE Solar Farm location, and dispatch considerations. Additional maximum and minimum short-circuit analyses were also performed for the moderate load scenario (Scenario 5).

# Appendix A


## EPC Contractor Solar & BESS SLD



# Appendix B

## Load Flow SLD

Figure 1 Scenario 1



# Appendix C

## Fault Level One Line Diagram and Detailed Fault Study Results

## C-1 Maximum Short-Circuit Analyses

**Table 34** Scenario 1 Maximum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed)

| Name            | 3 ph Ik" kA | 3 ph Sk" MVA | 1 ph Ik" A kA | 1 ph Sk" A MVA |
|-----------------|-------------|--------------|---------------|----------------|
| 11kVEast        | 0.984       | 18.7         | 0.665         | 4.2            |
| 11kVField       | 0.984       | 18.7         | 0.665         | 4.2            |
| 11kVNorth       | 0.984       | 18.7         | 0.665         | 4.2            |
| 11kVSolar       | 0.984       | 18.7         | 0.665         | 4.2            |
| 11kVSouth       | 0.984       | 18.7         | 0.665         | 4.2            |
| ADBSolar        | 1.103       | 21.0         | 0.618         | 3.9            |
| Airport         | 0.949       | 18.1         | 0.459         | 2.9            |
| Anabar          | 0.738       | 14.1         | 0.425         | 2.7            |
| Arijejen        | 0.954       | 18.2         | 0.634         | 4.0            |
| Civic           | 0.962       | 18.3         | 0.523         | 3.3            |
| CommandRidge    | 0.984       | 18.8         | 0.645         | 4.1            |
| DomSub          | 0.984       | 18.8         | 0.645         | 4.1            |
| EUSolar         | 0.932       | 17.8         | 0.495         | 3.1            |
| FreshCentre     | 0.931       | 17.7         | 0.387         | 2.5            |
| FreshCentre_S1  | 0.851       | 16.2         | 0.476         | 3.0            |
| FuelTankFarm    | 0.984       | 18.8         | 0.645         | 4.1            |
| G10             | 0.000       | 0.0          | 0.000         | 0.0            |
| G2              | 0.000       | 0.0          | 0.000         | 0.0            |
| G2-1            | 0.000       | 0.0          | 0.000         | 0.0            |
| G3              | 0.000       | 0.0          | 0.000         | 0.0            |
| G3-1            | 0.000       | 0.0          | 0.000         | 0.0            |
| G4              | 0.000       | 0.0          | 0.000         | 0.0            |
| G5              | 0.000       | 0.0          | 0.000         | 0.0            |
| G6              | 0.000       | 0.0          | 0.000         | 0.0            |
| G7-8            | 0.000       | 0.0          | 0.000         | 0.0            |
| Gon             | 0.946       | 18.0         | 0.446         | 2.8            |
| Gonway          | 0.933       | 17.8         | 0.394         | 2.5            |
| Ijew            | 0.715       | 13.6         | 0.386         | 2.5            |
| Junct1          | 0.936       | 17.8         | 0.614         | 3.9            |
| Junct2          | 0.904       | 17.2         | 0.580         | 3.7            |
| Junct5          | 0.871       | 16.6         | 0.512         | 3.3            |
| MFATSolar       | 1.103       | 21.0         | 0.618         | 3.9            |
| Menen_E1        | 0.891       | 17.0         | 0.283         | 1.8            |
| Menen_E1(1)     | 0.864       | 16.5         | 0.447         | 2.8            |
| Menen_N1        | 0.645       | 12.3         | 0.334         | 2.1            |
| Menen_S2        | 0.738       | 14.1         | 0.390         | 2.5            |
| PS3.3kV-A       | 2.857       | 16.3         | 2.077         | 4.0            |
| PS3.3kV-B       | 2.857       | 16.3         | 2.077         | 4.0            |
| Pago            | 0.951       | 18.1         | 0.465         | 3.0            |
| RPC1            | 1.090       | 20.8         | 0.616         | 3.9            |
| RPC3RPC2Ronphos | 0.972       | 18.5         | 0.527         | 3.3            |
| RehabWorkshops  | 1.008       | 19.2         | 0.553         | 3.5            |
| Ronave          | 0.777       | 14.8         | 0.461         | 2.9            |
| Terrace         | 0.790       | 15.0         | 0.429         | 2.7            |
| TheBay          | 0.671       | 12.8         | 0.353         | 2.2            |
| UAESolar        | 0.893       | 17.0         | 0.554         | 3.5            |
| Waboe           | 0.881       | 16.8         | 0.560         | 3.6            |

**Table 35** Scenario 3 Maximum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed)

| Name      | 3 ph Ik" kA | 3 ph Sk" MVA | 1 ph Ik" A kA | 1 ph Sk" A MVA |
|-----------|-------------|--------------|---------------|----------------|
| 11kVEast  | 1.713       | 32.6         | 1.764         | 11.2           |
| 11kVField | 1.713       | 32.6         | 1.764         | 11.2           |
| 11kVNorth | 1.713       | 32.6         | 1.764         | 11.2           |
| 11kVSolar | 1.713       | 32.6         | 1.764         | 11.2           |
| 11kVSouth | 1.713       | 32.6         | 1.764         | 11.2           |

| Name            | 3 ph Ik" kA | 3 ph Sk" MVA | 1 ph Ik" A kA | 1 ph Sk" A MVA |
|-----------------|-------------|--------------|---------------|----------------|
| ADBSolar        | 1.451       | 27.6         | 1.191         | 7.6            |
| Airport         | 1.630       | 31.1         | 1.038         | 6.6            |
| Anabar          | 1.110       | 21.2         | 0.724         | 4.6            |
| Arijejen        | 1.634       | 31.1         | 1.558         | 9.9            |
| Civic           | 1.661       | 31.7         | 1.294         | 8.2            |
| CommandRidge    | 1.641       | 31.3         | 1.577         | 10.0           |
| DomSub          | 1.641       | 31.3         | 1.577         | 10.0           |
| EUSolar         | 1.186       | 22.6         | 0.810         | 5.1            |
| FreshCentre     | 1.584       | 30.2         | 0.781         | 5.0            |
| FreshCentre_S1  | 1.380       | 26.3         | 0.913         | 5.8            |
| FuelTankFarm    | 1.641       | 31.3         | 1.577         | 10.0           |
| G10             | 14.665      | 10.2         | 17.087        | 3.9            |
| G2              | 31.454      | 21.8         | 36.465        | 8.4            |
| G2-1            | 1.982       | 37.8         | 1.690         | 10.7           |
| G3              | 0.000       | 0.0          | 0.000         | 0.0            |
| G3-1            | 0.000       | 0.0          | 0.000         | 0.0            |
| G4              | 2.249       | 42.8         | 1.613         | 10.2           |
| G5              | 31.667      | 21.9         | 36.610        | 8.5            |
| G6              | 0.000       | 0.0          | 0.000         | 0.0            |
| G7-8            | 55.602      | 38.5         | 87.589        | 20.2           |
| Gon             | 1.622       | 30.9         | 0.988         | 6.3            |
| Gonway          | 1.589       | 30.3         | 0.805         | 5.1            |
| Ijew            | 1.065       | 20.3         | 0.637         | 4.0            |
| Junct1          | 1.581       | 30.1         | 1.438         | 9.1            |
| Junct2          | 1.495       | 28.5         | 1.265         | 8.0            |
| Junct5          | 1.425       | 27.1         | 1.026         | 6.5            |
| MFATSolar       | 1.451       | 27.6         | 1.191         | 7.6            |
| Menen_E1        | 1.487       | 28.3         | 0.486         | 3.1            |
| Menen_E1(1)     | 1.082       | 20.6         | 0.694         | 4.4            |
| Menen_N1        | 0.921       | 17.5         | 0.518         | 3.3            |
| Menen_S2        | 1.114       | 21.2         | 0.657         | 4.2            |
| PS3.3kV-A       | 7.726       | 44.2         | 11.199        | 21.3           |
| PS3.3kV-B       | 7.726       | 44.2         | 11.199        | 21.3           |
| Pago            | 1.633       | 31.1         | 1.062         | 6.7            |
| RPC1            | 1.451       | 27.6         | 1.191         | 7.6            |
| RPC3RPC2Ronphos | 1.253       | 23.9         | 0.893         | 5.7            |
| RehabWorkshops  | 1.311       | 25.0         | 0.972         | 6.2            |
| Ronave          | 1.198       | 22.8         | 0.824         | 5.2            |
| Terrace         | 1.231       | 23.5         | 0.762         | 4.8            |
| TheBay          | 0.973       | 18.5         | 0.559         | 3.6            |
| UAESolar        | 1.470       | 28.0         | 1.169         | 7.4            |
| Waboe           | 1.445       | 27.5         | 1.176         | 7.5            |


Table 36 Scenario 5 Maximum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed)

| Name         | 3 ph Ik" kA | 3 ph Sk" MVA | 1 ph Ik" A kA | 1 ph Sk" A MVA |
|--------------|-------------|--------------|---------------|----------------|
| 11kVEast     | 2.671       | 50.9         | 2.059         | 13.1           |
| 11kVField    | 2.671       | 50.9         | 2.059         | 13.1           |
| 11kVNorth    | 2.671       | 50.9         | 2.059         | 13.1           |
| 11kVSolar    | 2.671       | 50.9         | 2.059         | 13.1           |
| 11kVSouth    | 2.671       | 50.9         | 2.059         | 13.1           |
| ADBSolar     | 2.538       | 48.4         | 1.409         | 8.9            |
| Airport      | 2.454       | 46.8         | 1.155         | 7.3            |
| Anabar       | 1.418       | 27.0         | 0.795         | 5.1            |
| Arijejen     | 2.474       | 47.1         | 1.795         | 11.4           |
| Civic        | 2.535       | 48.3         | 1.467         | 9.3            |
| CommandRidge | 2.561       | 48.8         | 1.833         | 11.6           |
| DomSub       | 2.562       | 48.8         | 1.833         | 11.6           |
| EUSolar      | 1.803       | 34.4         | 0.924         | 5.9            |
| FreshCentre  | 2.342       | 44.6         | 0.854         | 5.4            |

| Name            | 3 ph lk" kA | 3 ph Sk" MVA | 1 ph lk" A kA | 1 ph Sk" A MVA |
|-----------------|-------------|--------------|---------------|----------------|
| FreshCentre_S1  | 1.896       | 36.1         | 1.015         | 6.4            |
| FuelTankFarm    | 2.562       | 48.8         | 1.833         | 11.6           |
| G10             | 26.305      | 18.2         | 27.083        | 6.3            |
| G2              | 34.184      | 23.7         | 38.457        | 8.9            |
| G2-1            | 2.268       | 43.2         | 1.781         | 11.3           |
| G3              | 0.000       | 0.0          | 0.000         | 0.0            |
| G3-1            | 0.000       | 0.0          | 0.000         | 0.0            |
| G4              | 2.990       | 57.0         | 1.750         | 11.1           |
| G5              | 34.418      | 23.8         | 38.622        | 8.9            |
| G6              | 0.000       | 0.0          | 0.000         | 0.0            |
| G7-8            | 75.038      | 52.0         | 100.575       | 23.2           |
| Gon             | 2.436       | 46.4         | 1.095         | 7.0            |
| Gonway          | 2.354       | 44.9         | 0.880         | 5.6            |
| Ijew            | 1.337       | 25.5         | 0.697         | 4.4            |
| Junct1          | 2.354       | 44.8         | 1.646         | 10.5           |
| Junct2          | 2.163       | 41.2         | 1.434         | 9.1            |
| Junct5          | 1.997       | 38.1         | 1.148         | 7.3            |
| MFATSolar       | 2.538       | 48.4         | 1.409         | 8.9            |
| Menen_E1        | 2.114       | 40.3         | 0.522         | 3.3            |
| Menen_E1(1)     | 1.566       | 29.8         | 0.784         | 5.0            |
| Menen_N1        | 1.113       | 21.2         | 0.562         | 3.6            |
| Menen_S2        | 1.416       | 27.0         | 0.719         | 4.6            |
| PS3.3kV-A       | 10.497      | 60.0         | 12.827        | 24.4           |
| PS3.3kV-B       | 10.497      | 60.0         | 12.827        | 24.4           |
| Pago            | 2.463       | 46.9         | 1.183         | 7.5            |
| RPC1            | 2.508       | 47.8         | 1.405         | 8.9            |
| RPC3RPC2Ronphos | 1.961       | 37.4         | 1.026         | 6.5            |
| RehabWorkshops  | 2.113       | 40.3         | 1.124         | 7.1            |
| Ronave          | 1.570       | 29.9         | 0.909         | 5.8            |
| Terrace         | 1.618       | 30.8         | 0.840         | 5.3            |
| TheBay          | 1.192       | 22.7         | 0.609         | 3.9            |
| UAESolar        | 2.104       | 40.1         | 1.319         | 8.4            |
| Waboe           | 2.048       | 39.0         | 1.325         | 8.4            |

Figure 2

Fault Level One Line Diagram for Scenario 5, BESS fault contribution = 2.0 p.u., Solar fault contribution = 1.5 p.u.



## C-2 Minimum Short-Circuit Analyses

Table 37 Scenario 2 - Minimum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed)

| Name            | 3 ph Ik" kA | 3 ph Sk" MVA | 1 ph Ik" A kA | 1 ph Sk" A MVA |
|-----------------|-------------|--------------|---------------|----------------|
| 11kVEast        | 0.868       | 16.5         | 0.288         | 1.8            |
| 11kVField       | 0.868       | 16.5         | 0.288         | 1.8            |
| 11kVNorth       | 0.868       | 16.5         | 0.288         | 1.8            |
| 11kVSolar       | 0.868       | 16.5         | 0.288         | 1.8            |
| 11kVSouth       | 0.868       | 16.5         | 0.288         | 1.8            |
| ADBSolar        | 0.960       | 18.3         | 0.282         | 1.8            |
| Airport         | 0.838       | 16.0         | 0.246         | 1.6            |
| Anabar          | 0.655       | 12.5         | 0.243         | 1.5            |
| Arijejen        | 0.843       | 16.1         | 0.283         | 1.8            |
| Civic           | 0.850       | 16.2         | 0.261         | 1.7            |
| CommandRidge    | 0.868       | 16.5         | 0.285         | 1.8            |
| DomSub          | 0.868       | 16.5         | 0.285         | 1.8            |
| EUSolar         | 0.820       | 15.6         | 0.260         | 1.6            |
| FreshCentre     | 0.821       | 15.6         | 0.227         | 1.4            |
| FreshCentre_S1  | 0.750       | 14.3         | 0.253         | 1.6            |
| FuelTankFarm    | 0.868       | 16.5         | 0.285         | 1.8            |
| G10             | 0.000       | 0.0          | 0.000         | 0.0            |
| G2              | 0.000       | 0.0          | 0.000         | 0.0            |
| G2-1            | 0.000       | 0.0          | 0.000         | 0.0            |
| G3              | 0.000       | 0.0          | 0.000         | 0.0            |
| G3-1            | 0.000       | 0.0          | 0.000         | 0.0            |
| G4              | 0.000       | 0.0          | 0.000         | 0.0            |
| G5              | 0.000       | 0.0          | 0.000         | 0.0            |
| G6              | 0.000       | 0.0          | 0.000         | 0.0            |
| G7-8            | 0.000       | 0.0          | 0.000         | 0.0            |
| Gon             | 0.835       | 15.9         | 0.243         | 1.5            |
| Gonway          | 0.823       | 15.7         | 0.229         | 1.5            |
| Ijew            | 0.633       | 12.1         | 0.232         | 1.5            |
| Junct1          | 0.828       | 15.8         | 0.280         | 1.8            |
| Junct2          | 0.800       | 15.2         | 0.275         | 1.7            |
| Junct5          | 0.769       | 14.7         | 0.261         | 1.7            |
| MFATSolar       | 0.960       | 18.3         | 0.282         | 1.8            |
| Menen_E1        | 0.785       | 15.0         | 0.192         | 1.2            |
| Menen_E1(1)     | 0.761       | 14.5         | 0.249         | 1.6            |
| Menen_N1        | 0.571       | 10.9         | 0.216         | 1.4            |
| Menen_S2        | 0.651       | 12.4         | 0.232         | 1.5            |
| PS3.3kV-A       | 2.549       | 14.6         | 0.952         | 1.8            |
| PS3.3kV-B       | 2.549       | 14.6         | 0.952         | 1.8            |
| Pago            | 0.839       | 16.0         | 0.248         | 1.6            |
| RPC1            | 0.950       | 18.1         | 0.282         | 1.8            |
| RPC3RPC2Ronphos | 0.854       | 16.3         | 0.266         | 1.7            |
| RehabWorkshops  | 0.884       | 16.8         | 0.271         | 1.7            |
| Ronave          | 0.690       | 13.1         | 0.251         | 1.6            |
| Terrace         | 0.697       | 13.3         | 0.242         | 1.5            |
| TheBay          | 0.594       | 11.3         | 0.222         | 1.4            |
| UAESolar        | 0.789       | 15.0         | 0.270         | 1.7            |
| Waboe           | 0.780       | 14.9         | 0.271         | 1.7            |

Table 38

Scenario 4 - Minimum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed)

| Name            | 3 ph Ik" kA | 3 ph Sk" MVA | 1 ph Ik" A kA | 1 ph Sk" A MVA |
|-----------------|-------------|--------------|---------------|----------------|
| 11kVEast        | 0.870       | 16.6         | 1.106         | 7.0            |
| 11kVField       | 0.870       | 16.6         | 1.106         | 7.0            |
| 11kVNorth       | 0.870       | 16.6         | 1.106         | 7.0            |
| 11kVSolar       | 0.870       | 16.6         | 1.106         | 7.0            |
| 11kVSouth       | 0.870       | 16.6         | 1.106         | 7.0            |
| ADBSolar        | 0.789       | 15.0         | 0.861         | 5.5            |
| Airport         | 0.844       | 16.1         | 0.840         | 5.3            |
| Anabar          | 0.663       | 12.6         | 0.602         | 3.8            |
| Arijejen        | 0.846       | 16.1         | 1.026         | 6.5            |
| Civic           | 0.854       | 16.3         | 0.953         | 6.1            |
| CommandRidge    | 0.848       | 16.2         | 1.033         | 6.6            |
| DomSub          | 0.849       | 16.2         | 1.034         | 6.6            |
| EUSolar         | 0.694       | 13.2         | 0.655         | 4.2            |
| FreshCentre     | 0.829       | 15.8         | 0.693         | 4.4            |
| FreshCentre_S1  | 0.759       | 14.5         | 0.717         | 4.6            |
| FuelTankFarm    | 0.849       | 16.2         | 1.034         | 6.6            |
| G10             | 15.440      | 10.7         | 19.482        | 4.5            |
| G2              | 22.083      | 15.3         | 28.857        | 6.7            |
| G2-1            | 1.197       | 22.8         | 1.301         | 8.3            |
| G3              | 0.000       | 0.0          | 0.000         | 0.0            |
| G3-1            | 0.000       | 0.0          | 0.000         | 0.0            |
| G4              | 0.000       | 0.0          | 0.000         | 0.0            |
| G5              | 0.000       | 0.0          | 0.000         | 0.0            |
| G6              | 0.000       | 0.0          | 0.000         | 0.0            |
| G7-8            | 25.473      | 17.6         | 39.725        | 9.2            |
| Gon             | 0.841       | 16.0         | 0.814         | 5.2            |
| Gonway          | 0.830       | 15.8         | 0.708         | 4.5            |
| Ijew            | 0.643       | 12.3         | 0.545         | 3.5            |
| Junct1          | 0.830       | 15.8         | 0.976         | 6.2            |
| Junct2          | 0.802       | 15.3         | 0.898         | 5.7            |
| Junct5          | 0.776       | 14.8         | 0.780         | 5.0            |
| MFATSolar       | 0.789       | 15.0         | 0.861         | 5.5            |
| Menen_E1        | 0.796       | 15.2         | 0.474         | 3.0            |
| Menen_E1(1)     | 0.651       | 12.4         | 0.582         | 3.7            |
| Menen_N1        | 0.580       | 11.0         | 0.460         | 2.9            |
| Menen_S2        | 0.660       | 12.6         | 0.557         | 3.5            |
| PS3.3kV-A       | 3.345       | 19.1         | 4.872         | 9.3            |
| PS3.3kV-B       | 3.345       | 19.1         | 4.872         | 9.3            |
| Pago            | 0.845       | 16.1         | 0.852         | 5.4            |
| RPC1            | 0.789       | 15.0         | 0.861         | 5.5            |
| RPC3RPC2Ronphos | 0.720       | 13.7         | 0.704         | 4.5            |
| RehabWorkshops  | 0.742       | 14.1         | 0.748         | 4.8            |
| Ronave          | 0.698       | 13.3         | 0.663         | 4.2            |
| Terrace         | 0.706       | 13.5         | 0.626         | 4.0            |
| TheBay          | 0.604       | 11.5         | 0.490         | 3.1            |
| UAESolar        | 0.793       | 15.1         | 0.852         | 5.4            |
| Waboe           | 0.786       | 15.0         | 0.856         | 5.4            |

Table 39

Scenario 5 - Minimum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed)

| Name      | 3 ph Ik" kA | 3 ph Sk" MVA | 1 ph Ik" A kA | 1 ph Sk" A MVA |
|-----------|-------------|--------------|---------------|----------------|
| 11kVEast  | 2.522       | 48.0         | 2.057         | 13.1           |
| 11kVField | 2.522       | 48.0         | 2.057         | 13.1           |
| 11kVNorth | 2.522       | 48.0         | 2.057         | 13.1           |
| 11kVSolar | 2.522       | 48.0         | 2.057         | 13.1           |
| 11kVSouth | 2.522       | 48.0         | 2.057         | 13.1           |
| ADBSolar  | 2.340       | 44.6         | 1.407         | 8.9            |
| Airport   | 2.300       | 43.8         | 1.148         | 7.3            |


| Name            | 3 ph Ik" kA | 3 ph Sk" MVA | 1 ph Ik" A kA | 1 ph Sk" A MVA |
|-----------------|-------------|--------------|---------------|----------------|
| Anabar          | 1.303       | 24.8         | 0.789         | 5.0            |
| Arijejen        | 2.331       | 44.4         | 1.792         | 11.4           |
| Civic           | 2.384       | 45.4         | 1.461         | 9.3            |
| CommandRidge    | 2.407       | 45.9         | 1.830         | 11.6           |
| DomSub          | 2.407       | 45.9         | 1.831         | 11.6           |
| EUSolar         | 1.654       | 31.5         | 0.919         | 5.8            |
| FreshCentre     | 2.185       | 41.6         | 0.848         | 5.4            |
| FreshCentre_S1  | 1.736       | 33.1         | 1.006         | 6.4            |
| FuelTankFarm    | 2.407       | 45.9         | 1.831         | 11.6           |
| G10             | 25.173      | 17.4         | 27.080        | 6.3            |
| G2              | 33.026      | 22.9         | 38.453        | 8.9            |
| G2-1            | 2.238       | 42.6         | 1.781         | 11.3           |
| G3(5)           | 0.000       | 0.0          | 0.000         | 0.0            |
| G3-1            | 0.000       | 0.0          | 0.000         | 0.0            |
| G4              | 2.839       | 54.1         | 1.750         | 11.1           |
| G5              | 33.215      | 23.0         | 38.617        | 8.9            |
| G6              | 0.000       | 0.0          | 0.000         | 0.0            |
| G7-8            | 75.707      | 52.5         | 100.504       | 23.2           |
| Gon             | 2.281       | 43.5         | 1.088         | 6.9            |
| Gonway          | 2.197       | 41.9         | 0.874         | 5.6            |
| Ijew            | 1.211       | 23.1         | 0.689         | 4.4            |
| Junct1          | 2.212       | 42.1         | 1.642         | 10.4           |
| Junct2          | 2.025       | 38.6         | 1.429         | 9.1            |
| Junct5          | 1.844       | 35.1         | 1.140         | 7.2            |
| MFATSolar       | 2.340       | 44.6         | 1.407         | 8.9            |
| Menen_E1        | 1.951       | 37.2         | 0.518         | 3.3            |
| Menen_E1(1)     | 1.428       | 27.2         | 0.779         | 4.9            |
| Menen_N1        | 0.993       | 18.9         | 0.556         | 3.5            |
| Menen_S2        | 1.278       | 24.3         | 0.711         | 4.5            |
| PS3.3kV-A       | 9.951       | 56.9         | 12.818        | 24.4           |
| PS3.3kV-B       | 9.951       | 56.9         | 12.818        | 24.4           |
| Pago            | 2.309       | 44.0         | 1.177         | 7.5            |
| RPC1            | 2.316       | 44.1         | 1.403         | 8.9            |
| RPC3RPC2Ronphos | 1.808       | 34.5         | 1.021         | 6.5            |
| RehabWorkshops  | 1.951       | 37.2         | 1.120         | 7.1            |
| Ronave          | 1.451       | 27.6         | 0.902         | 5.7            |
| Terrace         | 1.473       | 28.1         | 0.831         | 5.3            |
| TheBay          | 1.070       | 20.4         | 0.602         | 3.8            |
| UAESolar        | 1.960       | 37.3         | 1.312         | 8.3            |
| Waboe           | 1.916       | 36.5         | 1.319         | 8.4            |

**Table 40** Scenario 6 - Minimum Short-Circuit Currents, BESS Fault contribution = 2.0 p.u., PV Fault contribution = 1.5 p.u. (NOP open, FF closed, EF closed)


| Name           | 3 ph Ik" kA | 3 ph Sk" MVA | 1 ph Ik" A kA | 1 ph Sk" A MVA |
|----------------|-------------|--------------|---------------|----------------|
| 11kVEast       | 0.361       | 6.9          | 0.277         | 1.8            |
| 11kVField      | 0.361       | 6.9          | 0.277         | 1.8            |
| 11kVNorth      | 0.361       | 6.9          | 0.277         | 1.8            |
| 11kVSolar      | 0.361       | 6.9          | 0.277         | 1.8            |
| 11kVSouth      | 0.361       | 6.9          | 0.277         | 1.8            |
| ADBSolar       | 0.374       | 7.1          | 0.272         | 1.7            |
| Airport        | 0.356       | 6.8          | 0.240         | 1.5            |
| Anabar         | 0.322       | 6.1          | 0.238         | 1.5            |
| Arijejen       | 0.358       | 6.8          | 0.273         | 1.7            |
| Civic          | 0.358       | 6.8          | 0.253         | 1.6            |
| CommandRidge   | 0.361       | 6.9          | 0.275         | 1.7            |
| DomSub         | 0.361       | 6.9          | 0.275         | 1.7            |
| EUSolar        | 0.352       | 6.7          | 0.252         | 1.6            |
| FreshCentre    | 0.352       | 6.7          | 0.222         | 1.4            |
| FreshCentre_S1 | 0.338       | 6.4          | 0.246         | 1.6            |
| FuelTankFarm   | 0.361       | 6.9          | 0.275         | 1.7            |
| G10            | 0.000       | 0.0          | 0.000         | 0.0            |
| G2             | 0.000       | 0.0          | 0.000         | 0.0            |
| G2-1           | 0.000       | 0.0          | 0.000         | 0.0            |
| G3(5)          | 0.000       | 0.0          | 0.000         | 0.0            |
| G3-1           | 0.000       | 0.0          | 0.000         | 0.0            |

| Name            | 3 ph 1k" kA | 3 ph Sk" MVA | 1 ph 1k" A kA | 1 ph Sk" A MVA |
|-----------------|-------------|--------------|---------------|----------------|
| G4              | 0.000       | 0.0          | 0.000         | 0.0            |
| G5              | 0.000       | 0.0          | 0.000         | 0.0            |
| G6              | 0.000       | 0.0          | 0.000         | 0.0            |
| G7-8            | 0.000       | 0.0          | 0.000         | 0.0            |
| Gon             | 0.355       | 6.8          | 0.237         | 1.5            |
| Gonway          | 0.353       | 6.7          | 0.224         | 1.4            |
| Ijew            | 0.316       | 6.0          | 0.228         | 1.4            |
| Junct1          | 0.355       | 6.8          | 0.270         | 1.7            |
| Junct2          | 0.350       | 6.7          | 0.265         | 1.7            |
| Junct5          | 0.342       | 6.5          | 0.253         | 1.6            |
| MFATSolar       | 0.374       | 7.1          | 0.272         | 1.7            |
| Menen_E1        | 0.345       | 6.6          | 0.191         | 1.2            |
| Menen_E1(1)     | 0.341       | 6.5          | 0.243         | 1.5            |
| Menen_N1        | 0.301       | 5.7          | 0.214         | 1.4            |
| Menen_S2        | 0.318       | 6.1          | 0.228         | 1.4            |
| PS3.3kV-A       | 1.159       | 6.6          | 0.916         | 1.7            |
| PS3.3kV-B       | 1.159       | 6.6          | 0.916         | 1.7            |
| Pago            | 0.356       | 6.8          | 0.241         | 1.5            |
| RPC1            | 0.373       | 7.1          | 0.272         | 1.7            |
| RPC3RPC2Ronphos | 0.358       | 6.8          | 0.258         | 1.6            |
| RehabWorkshops  | 0.363       | 6.9          | 0.262         | 1.7            |
| Ronave          | 0.329       | 6.3          | 0.245         | 1.6            |
| Terrace         | 0.327       | 6.2          | 0.237         | 1.5            |
| TheBay          | 0.307       | 5.8          | 0.219         | 1.4            |
| UAESolar        | 0.347       | 6.6          | 0.261         | 1.7            |
| Waboe           | 0.347       | 6.6          | 0.262         | 1.7            |

5 p.u.



**Figure 4** Fault Level One Line Diagram for Scenario 6, BESS fault contribution = 2.0 p.u., Solar fault contribution = 1.5 p.u.




# Appendix D

## NUC Network Configuration & Interconnection SLDs

DRAFT

### NAURU DISTRIBUTION (3.3kV/11kV) SINGLE LINE DIAGRAM

[illegible]

# Appendix E

## Contractor's Response on Equipment Capability

September 3, 2024

|              |                                                          |             |                    |
|--------------|----------------------------------------------------------|-------------|--------------------|
| To           | CHEC                                                     | Contact No. |                    |
| Copy to      | Claude Morris                                            | Email       | amit.datta@ghd.com |
| From         | Amit Datta                                               | Project No. | 12543852           |
| Project Name | NUC Solar PIC                                            |             |                    |
| Subject      | RFI #2 – Fault current contribution of PV/BESS inverters |             |                    |

## Model Clarifications

CHEC is requested to please confirm the following information:

1. CHEC to confirm fault current contribution of the PV inverters in accordance with section 6 – employer's requirements, clause 2.2.1.4.

**HNAC/2022.12.16: After confirm with the PV inverter OEM Ginlong Technology, the maximum fault current contribution of the S5-GC60K-HV inverter is 1.5 times of the rated output current, that is  $1.5 \times 79.4A = 119.1A$ . If fault occurs, the inverter will send alarm signal to the monitoring/SCADA system and then shutdown within 100ms.**

As per fault ride through and fault current requirement described in section 6 – employer's requirement-Clause 2.2.2.1.5, "the BESS shall have fault current ride through capability, be capable of providing a fault current contribution of no less than 2 p.u. for the pcs for at least 3 seconds for all balanced and unbalanced fault types with and without fault impedance." CHEC to provide datasheet to confirm compliance.

**HNAC/2022.12.16:**

**After search the AS/NZS and IEC standards website or database, we have not found the related standard regarding the fault ride through capability of the power conversion system for battery storage system. We think this requirement "the BESS shall have fault current ride through capability, be capable of providing a fault current contribution of no less than 2 p.u. for the pcs for at least 3 seconds for all balanced and unbalanced fault types with and without fault impedance." is very strict for a BESS system, if the PCS should provide 2 p.u fault current contribution for the PCS, the rated power capacity of the BESS PCS should be 2 times of the 5MW as the ERQ specified, that is should be 10MW, the battery charging and discharging rate also should be 4C rather than 2C(as implied by 5MW/2.5MWh), otherwise, the battery will be damaged by this extremely high discharging current rate.**

**According to the Chinese standard GB/T 34120-2017 Technical specification for power conversion system of electrochemical energy storage system, the Fault Ride Through capability requirements are shown as below for your reference.**



# 中华人民共和国国家标准

GB/T 34120—2017

## 电化学储能系统储能变流器技术规范

Technical specification for power conversion system of  
electrochemical energy storage system

GB/T 34120—2017

PCS shall not disconnected to the grid




Fig 1 Low-voltage ride through capability requirements

注1：对于三相短路故障和两相短路故障，考核电压为并网点线电压；对于单相接地短路故障，考核电压为并网点相电压。

注2：对于并入10(6)kV以下电压等级电网的储能变流器，具备故障脱离功能即可。

Note2: for the PCS connected to the grid below 10(6)kV have fault disconnection capability is OK

图1 储能变流器的低电压耐受能力要求

### 5.4.12.2 动态无功支撑能力

当电力系统发生短路故障引起电压跌落时，电化学储能系统储能变流器注入电网的动态无功电流应满足以下要求：

- 自并网点电压跌落的时刻起，动态无功电流的响应时间应不大于30 ms。
- 自动态无功电流响应起直到电压恢复至0.85(p.u.)期间，储能变流器注入电力系统的动态无功电流应实时跟踪并网点电压变化，并应满足：

$$I_T \geq 1.6 \times (0.85 - U_T) I_N \quad (0.2 \leq U_T \leq 0.85)$$

$$I_T \geq 1.04 \times I_N \quad (U_T < 0.2)$$

$$I_T = 0 \quad (U_T > 0.85)$$

式中：

$U_T$  —— 储能变流器并网点电压标么值；

$I_N$  —— 储能变流器额定电流。

After confirm with the BESS PCS OEM Tianjin Electric Science Research Institute Co., Ltd, the maximum fault current contribution of the TPCS2-630-N32 BESS PCS is 1.5 times of the rated output current, that is  $1.5 \times 1000A = 1500A$  within 10us, and  $1.3 \times 1000A = 1200A$  within 2ms.

- BESS fault current contribution- what is the maximum fault current contribution that can be provided for ~1 second.
- **HNAC 2023.09.13:** The BESS inverter can meet the following requirements

| Voltage of POC(U)                                                                                                                                                                                         | Voltage response capability           |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|
| $U < 50\%U_N$                                                                                                                                                                                             | Maximum tripping time not exceed 0.2s |
| $50\%U_N \leq U \leq 85\%U_N$                                                                                                                                                                             | Maximum tripping time not exceed 0.2s |
| $85\%U_N \leq U < 110\%U_N$                                                                                                                                                                               | Continuous operating                  |
| $110\%U_N \leq U < 120\%U_N$                                                                                                                                                                              | Maximum tripping time not exceed 0.2s |
| $120\%U_N \leq U$                                                                                                                                                                                         | Maximum tripping time not exceed 0.2s |
| <p>Note 1: <math>U_N</math> is the rated voltage of the Point of Connection (POC)</p> <p>Note 2: Maximum tripping time is the time between fault occurs and converter disconnected to the power grid.</p> |                                       |

- **(Low-voltage ride through capability)** When a short-circuit fault occurs in the power system and causes a voltage drop, the dynamic reactive current injected into the power grid by the converter meets the following requirements:  
 From the moment the voltage at the point of connection(POC) drops, the response time of dynamic reactive current will not be greater than 30ms.  
 From the moment of dynamic reactive current response until the voltage recovers to 0.85P.U, the dynamic reactive current injected into the grid by the converter tracks the voltage changes at POC in real time and satisfies:

$$I_T \geq 1.6 \times (0.85 - U_T) I_N \quad (0.2 \leq U_T \leq 0.85)$$

$$I_T \geq 1.04 \times I_N \quad (U_T < 0.2)$$

$$I_T = 0 \quad (U_T > 0.85)$$

Where:  $U_T$ - Per Unit Voltage of POC


$I_T$ -Rated current of BESS inverter(A)




# Appendix F

## PV and BESS SLD

DRAFT





|     |                                                                                                               |          |    |     |     |           |              |                        |                                                                                       |                   |                    |           |                                                                               |           |  |                |    |
|-----|---------------------------------------------------------------------------------------------------------------|----------|----|-----|-----|-----------|--------------|------------------------|---------------------------------------------------------------------------------------|-------------------|--------------------|-----------|-------------------------------------------------------------------------------|-----------|--|----------------|----|
| 4   | REVISED ADDITION OF ADB SOLAR FARM SUB STATION                                                                | 20/10/22 | SB | JP  | AA  | REFERENCE |              |                        |  | DRAWN             | SEKOVE BARI        | 20/10/22  | NAURU UTILITES CORPORATION                                                    |           |  |                |    |
| 3   | REVISED ADDITION OF CHEC CAMP TRANSFORMER.                                                                    | 24/02/22 | SB | ALI | CP  |           |              |                        |                                                                                       | CHECKED           | J. RODIBEN         | 20/10/22  | NAURU ELECTRICITY DISTRIBUTION<br>11Kv SINGLE LINE SCHEMATIC DIAGRAM<br>NAURU |           |  | DRAWING NUMBER |    |
| 2   | REVISED ADDITION OF ANTERIA RMU, REMOVAL OF ADB 354, ADDITION OF FLY CAMP TRANSFORMER. Revision of Duavla RMU | 03/08/21 | SB | ALI | CP  |           |              |                        |                                                                                       | CHIEF DRAUGHTSMAN |                    |           |                                                                               |           |  | A2             | 04 |
| 1   | REVISED ADDITION OF BUADA RMU ETC.                                                                            | 25/11/20 | TB |     | ALI |           | AS           |                        |                                                                                       |                   | ENGINEER           | KEN BLAKE | 20/10/22                                                                      | SCALE NTS |  |                |    |
| 0   | ORIGINALISSUE                                                                                                 | 12/06/20 | TB |     | ALI |           | AS           |                        |                                                                                       |                   | HEAD OF DEPARTMENT | A. AREMWA | 20/10/22                                                                      |           |  |                |    |
| No. | REVISION                                                                                                      | DATE     | BY | CHK | PSD | APP       | CAD FILENAME | NAURU DISTRIBUTION SLD |                                                                                       |                   |                    |           |                                                                               |           |  |                |    |
|     |                                                                                                               |          |    |     |     |           | DRAWING No.  | TITLE                  |                                                                                       |                   |                    |           |                                                                               |           |  |                |    |



[ghd.com](http://ghd.com)

→ **The Power of Commitment**