

# Energy Fiji Limited



## **Tender Document**

Tender No. : MR 15/2026

**Supply of 8 x 1MW Containerized Prime Rating  
Diesel Generators For EFL Power Stations**

## **Table of Content**

<b>1.0 INVITATION FOR TENDERS</b>	<b>6</b>
<b>2.0 INSTRUCTION TO BIDDERS</b>	<b>7</b>
2.1 ELIGIBLE BIDDERS	7
2.2 ELIGIBLE MATERIALS, EQUIPMENT AND SERVICES	7
2.3 ONE BID PER BIDDER	7
2.4 COST OF BIDDING	7
2.5 SITE VISITS	7
2.6 CONTENTS OF THE BIDDING DOCUMENTS	7
2.7 CLARIFICATION OF BIDDING DOCUMENTS	9
2.8 AMENDMENT OF BIDDING DOCUMENT	9
2.9 LANGUAGE OF BID	9
2.10 BID PRICE	9
2.11 BID CURRENCIES	9
2.12 BID VALIDITY	10
2.13 FORMAT AND SIGNING OF BIDS	10
2.14 SEALING AND MARKING OF BIDS	10
2.15 DEADLINE FOR SUBMISSION OF BIDS	10
2.16 LATE BIDS	10
2.17 MODIFICATION AND WITHDRAWAL OF BIDS	10
2.18 REJECTION OF ONE OR ALL BIDS	10
2.19 PROCESS TO BE CONFIDENTIAL	11
2.20 CLARIFICATION OF BIDS	11
2.21 PRELIMINARY EXAMINATION	11
<b>3.0 GENERAL CONDITIONS OF CONTRACT</b>	<b>12</b>
3.1 GENERAL CONDITIONS'	12
3.2 DEFINITIONS	12
3.3 APPLICATION	12
3.4 COUNTRY OF ORIGIN	12
3.5 STANDARDS	12
3.6 USE OF CONTRACT DOCUMENTS AND INFORMATION	12
3.7 PERFORMANCE BOND	13
3.8 PROGRAMME TO BE FURNISHED	13
3.9 INSPECTION AND TESTS	13
3.10 PATENT RIGHTS	13
3.11 PACKING	13
3.12 DELIVERY AND DOCUMENTS	14
3.13 INSURANCE	14
3.14 WARRANTY	14
3.15 PAYMENT	14

<b>3.16</b>	<b>PRICES</b>	<b>15</b>
<b>3.17</b>	<b>ASSIGNMENT</b>	<b>15</b>
<b>3.18</b>	<b>SUBCONTRACTS</b>	<b>15</b>
<b>3.19</b>	<b>TERMINATION FOR DEFAULT</b>	<b>15</b>
<b>3.20</b>	<b>LIQUIDATED DAMAGES</b>	<b>15</b>
<b>3.21</b>	<b>RESOLUTION OF DISPUTES</b>	<b>15</b>
<b>3.22</b>	<b>LANGUAGE AND LAW</b>	<b>16</b>
<b>3.23</b>	<b>FORCE MAJEURE</b>	<b>16</b>
<b>3.24</b>	<b>SCHEDULE OF REQUIREMENTS</b>	<b>16</b>
<b>4.0</b>	<b><u>SPECIAL CONDITIONS OF CONTRACT</u></b>	<b><u>17</u></b>
<b>4.1</b>	<b>DEFINITIONS</b>	<b>17</b>
<b>4.2</b>	<b>APPLICATION</b>	<b>17</b>
<b>4.3</b>	<b>PROOF OF SUCCESSFUL COMPLETION OF PREVIOUS SIMILAR CONTRACTS</b>	<b>17</b>
<b>4.4</b>	<b>DELIVERY PERIOD</b>	<b>17</b>
<b>4.5</b>	<b>PAYMENT TERMS AND CONDITIONS</b>	<b>17</b>
<b>4.6</b>	<b>ADVANCE PAYMENT</b>	<b>17</b>
<b>4.7</b>	<b>PRICES</b>	<b>17</b>
<b>5.0</b>	<b><u>TECHNICAL SPECIFICATION</u></b>	<b><u>18</u></b>
<b>5.1</b>	<b>INFORMATION TO TENDERS</b>	<b>18</b>
<b>5.1.1</b>	<b>INFORMATION WITH TENDER</b>	<b>18</b>
<b>5.1.2</b>	<b>DRAWING AND INFORMATION TO BE SUPPLIED BY CONTRACTOR.</b>	<b>19</b>
<b>5.1.3</b>	<b>DESIGN AND STANDARDISATION</b>	<b>19</b>
<b>5.1.4</b>	<b>TOOLS AND INSTRUMENTS</b>	<b>20</b>
<b>5.1.5</b>	<b>PROVISION FOR HANDLING THE PLANT</b>	<b>20</b>
<b>5.1.6</b>	<b>PACKING</b>	<b>20</b>
<b>5.1.7</b>	<b>INSURANCE</b>	<b>20</b>
<b>5.2</b>	<b>SCOPE OF WORK</b>	<b>21</b>
<b>5.3</b>	<b>DESIGN REQUIREMENTS</b>	<b>21</b>
<b>5.4</b>	<b>REFERENCE CONDITIONS</b>	<b>21</b>
<b>5.5</b>	<b>CAPACITY AND RATING</b>	<b>22</b>
<b>5.5.1</b>	<b>GENSET CAPACITY</b>	<b>22</b>
<b>5.5.2</b>	<b>RATING</b>	<b>22</b>
<b>5.6</b>	<b>PLANT LAYOUT REQUIREMENTS</b>	<b>22</b>
<b>5.6.1</b>	<b>SAFETY ASPECTS</b>	<b>22</b>
<b>5.7</b>	<b>CONTROL</b>	<b>23</b>
<b>5.7.1</b>	<b>CONTROL SYSTEM</b>	<b>23</b>
<b>5.7.2</b>	<b>DIAGNOSTIC SOFTWARE</b>	<b>23</b>
<b>5.7.3</b>	<b>GENERATOR PROTECTION</b>	<b>23</b>
<b>5.7.4</b>	<b>GENERATOR CIRCUIT BEAKER</b>	<b>24</b>
<b>5.8</b>	<b>DIESEL ENGINE AND AUXILIARY EQUIPMENT</b>	<b>24</b>
<b>5.8.1</b>	<b>COMPLIANCE</b>	<b>24</b>
<b>5.8.2</b>	<b>ENGINE GOVERNING</b>	<b>24</b>

5.8.3	ENGINE COMBUSTION AIR SYSTEM AND SILENCER	25
5.8.4	ENGINE FUEL OIL SYSTEM	25
5.8.5	ENGINE LUBRICATION OIL SYSTEM	25
5.8.6	INSTRUMENTS & PROTECTION	26
5.8.7	LOCAL ENGINE INSTRUMENTATION SHOULD INCLUDE AT A MINIMUM:	26
<b>5.8.8</b>	<b>ENGINE SHUTDOWNS SHALL BE REQUIRED FOR:</b>	<b>26</b>
<b>5.8.9</b>	<b>ON THE OPERATION OF ANY ONE OF THE ABOVE PROTECTION:</b>	<b>27</b>
<b>5.9</b>	<b>ENGINE PROTECTION (ELECTRICAL)</b>	<b>27</b>
<b>5.10</b>	<b>ENGINE CRANKCASE VENTILATION</b>	<b>27</b>
<b>5.11</b>	<b>ENGINE EXHAUST SYSTEM</b>	<b>28</b>
<b>5.12</b>	<b>ENGINE COOLING SYSTEM</b>	<b>28</b>
<b>5.13</b>	<b>AUTOMATIC VOLTAGE REGULATOR PANEL</b>	<b>28</b>
<b>5.14</b>	<b>ALTERNATOR, EXCITATION AND CHANGEVER SWITCHING</b>	<b>28</b>
5.14.1	ALTERNATOR	28
5.14.2	EXCITATION	29
5.14.3	VOLTAGE REGULATION	29
<b>5.15</b>	<b>OTHER ELECTRICAL COMPONENTS</b>	<b>30</b>
<b>5.15.1</b>	<b>DESIGN STANDARDS FOR ELECTRICAL PLANT</b>	<b>30</b>
<b>5.16</b>	<b>WIRING, CABLE AND CONNECTIONS</b>	<b>30</b>
5.16.1	CABLE SIZE	31
5.16.2	TRAINING	31
<b>5.17</b>	<b>TESTING AND COMMISSIONING</b>	<b>31</b>
5.17.1	GENERAL REQUIREMENTS	31
5.17.2	THE TESTING PROGRAMME SHALL GENERALLY CONSIST OF;	31
<b>4.17.3</b>		<b>32</b>
<b>5.18</b>	<b>COMMISSIONING TESTS</b>	<b>32</b>
5.18.1	THE TEST SHALL CONSIST OF (IF APPLICABLE):	32
<b>5.19</b>	<b>SPARE PARTS</b>	<b>33</b>
<b>6.0</b>	<b><u>DELIVERABLES</u></b>	<b><u>34</u></b>
<b>6.1</b>	<b>SCHEDULE 1 - TECHNICAL PARTICULARS</b>	<b>34</b>
<b>7.0</b>	<b><u>SCHEDULE 2 - PARTS</u></b>	<b><u>44</u></b>
<b>8.0</b>	<b><u>SCHEDULE 3 SPECIAL TOOLS ETC.</u></b>	<b><u>45</u></b>
<b>9.0</b>	<b><u>SCHEDULE 4 – DEVIATIONS</u></b>	<b><u>46</u></b>
<b>10.0</b>	<b><u>SCHEDULE 5 OVERHAUL AND EXPECTED LIFE TIME OF COMPONENTS</u></b>	<b><u>47</u></b>
<b>11.0</b>	<b><u>SCHEDULE 6 MAINTENANCE SCHEDULE IN TERMS OF MACHINE HOURS</u></b>	<b><u>48</u></b>
<b>12.0</b>	<b><u>PRICE SCHEDULE</u></b>	<b><u>49</u></b>

<b>12.1</b>	<b>COMPLIANCE CHECKLIST DECLARATION</b>	<b>51</b>
<b>12.2</b>	<b>TENDER CHECK LIST</b>	<b>52</b>
<b>13.0</b>	<b>TENDER FORM</b>	<b>53</b>
<b>14.0</b>	<b>SUBMISSION TO TENDER</b>	<b>54</b>

## **1.0 INVITATION FOR TENDERS**

Energy Fiji Limited is inviting bids for Supply of 8 x 1MW Containerized Prime Rating Diesel Generators for EFL Power Stations. The Detailed scope of supply listed in the following pages.

Interested bidders may obtain tender documents from EFL website [www.efl.com.fj](http://www.efl.com.fj) or Tenderlink website <https://www.tenderlink.com/efl>

All tenders shall submit all documents required including spares pricing as per price template.

During evaluation of tenders, the Authority will invite a tenderer or tenderers for discussions, presentations and necessary clarification before awarding of the contract

The tender submissions close on the 4/03/26

## **2.0 INSTRUCTION TO BIDDERS**

### **2.1 Eligible Bidders**

- 2.1.1. This invitation is open to all Bidders who have sound Financial Background and have previous experience in supply of generating equipment & accessories.
- 2.1.2. Bidders shall provide such evidence of their continued eligibility satisfactory to EFL as EFL shall reasonably request.
- 2.1.3. Bidders shall not be under a declaration of ineligibility for corrupt or fraudulent practice.

### **2.2 Eligible Materials, Equipment and Services**

- 2.2.1. The materials, equipment, and services to be supplied under the Contract shall have their origin from reputable companies as specified by EFL and from various countries and all expenditures made under the Contract will be limited to such materials, equipment, and services. Upon request, bidders may be required to provide evidence of the origin of materials, equipment, and services.
- 2.2.2. For purposes of this Contract, "services" means the works and all project-related services including design services.
- 2.2.3. For purposes of this Contract, "origin" means the place where the materials and equipment are mined, grown, produced or manufactured, and from which the services are provided. Materials and equipment are produced when, through manufacturing, processing or substantial or major assembling of components, a commercial recognized product results that is substantially different in basic characteristics or in purpose or utility from its components.
- 2.2.4. The materials, equipment and services to be supplied under the Contract shall not infringe or violate any industrial property or intellectual property rights or claim of any third party.

### **2.3 One bid per Bidder**

- 2.3.1. Each bidder shall submit only one bid. A bidder who submits or participates in more than one bid will cause all those bids to be rejected.

### **2.4 Cost of Bidding**

- 2.4.1. The bidder shall bear all costs associated with the preparation and submission of its bid and EFL will in no case be responsible or liable for those costs.

### **2.5 Site Visits**

- 2.5.1. No Site Visit required for this tender

### **2.6 Contents of the Bidding Documents**

- 2.6.1. The technical proposal shall contain the following:
  - (i) Bid Form for Technical Proposal and Appendix to Technical Proposal
  - (ii) Form of Bid Security (optional).

- (iii) Power of Attorney (optional);
- (iv) Information on Technical Qualifications;
- (v) Confirmation of Eligibility;
- (vi) Schedule of Major Items of Equipment
- (vii) Schedule of Technical Particulars & Guarantees
- (viii) Schedule of Times for Delivery & Completion and Contract completion times
- (ix) Schedule of Subcontractors Statement of Experience
- (x) Schedule of Bidders Tools & Equipment
- (xi) Schedule of Contractors Health & Safety Plan
- (xii) Schedule of Other Documents and Drawings to be submitted with the bid
- (xiii) Any other materials required to be completed and submitted by bidders in accordance with these Instructions to Bidders.

2.6.2. The Financial proposal shall contain the following:

- (i) Bid Form for Price Proposal and Appendix to Price Proposal.
- (ii) Schedules of Prices:
  - I. Design, Drawings and Documentation
  - II. Civil Works, Installation and Other Services ( if required onsite).
  - III. Grand Summary; and
  - IV. Recommended Spare Parts for Generator maintenance
- (iii) Any other materials required to be completed and submitted by bidders in accordance with these Instructions to Bidders.

2.6.3. The bidder is expected to examine carefully the contents of this Bidding document. Failure to comply with the requirements of bid submission will be at the bidder's own risk. Bids which are not substantially responsive to the requirements of the bidding documents will be rejected.

2.6.4. The following are the mandatory submission of a successful tender bid;

- Pricing Schedule
- Program of Works
- Company Profile (Max 4 pages in standard A4 size)
  - Work History - Project/ Work done with referee, EFL work history.
  - Company background
  - Bidder available resources e.g. Manpower, Machines & Equipment.
  - OHS Policies or Plan
- Fiji Revenue & Customs Service (FRCA) compliance

- Fiji National Provident Fund (FNPF) compliance
- Signed checklist declaration (Appendix 5.1)

Failure to submit required documents may affect bid compliance even make it non-compliance.

## **2.7 Clarification of Bidding Documents**

- 2.7.1. A prospective bidder requiring any clarification of the bidding documents may notify EFL in writing by email addressed to:

Jitendra Reddy  
Manager Procurement, Inventory and Supply Chain  
2 Marlow Street,  
Suva, Fiji  
Phone: +679 3224 360  
Email: [tenders@efl.com.fj](mailto:tenders@efl.com.fj)

- 2.7.2. EFL will respond to any request for clarification which it receives earlier than 5 days prior to the deadline for submission of bids.

## **2.8 Amendment of Bidding Document**

- 2.8.1. At any time prior to the deadline for submission of bids, EFL may, for any reason, whether at its own initiative or in response to a clarification requested by a prospective bidder, modify the bidding documents by issuing addenda.

## **2.9 Language of Bid**

- 2.9.1. The bid, and all correspondence and documents related to the bid, exchanged between the bidder and the EFL shall be written in the English language.

## **2.10 Bid Price**

- 2.10.1. Unless specified otherwise, Bidders shall quote for the entire facilities on a "single responsibility" basis such that the total bid price covers all the Supplier's obligations mentioned in or to be reasonably inferred from the bidding documents in respect of the design, manufacture, including procurement and subcontracting (if any), testing and delivery.
- 2.10.2. Bidders shall give a breakdown of the prices in the manner and detail called for in this bidding document, or any issued addenda.
- 2.10.3. For Oversea Suppliers, bids shall be given on Cost and Freight (CFR) basis the point of delivery shall be Suva/Lautoka port for Sea or Nadi Airport for Air. The term CFR shall be governed by the rules prescribed in the current edition of Incoterms.
- 2.10.4. For Local Bidders, bids should be submitted in VIP price.

## **2.11 Bid Currencies**

- 2.11.1. Prices shall be quoted in a single currency only.

## **2.12 Bid Validity**

- 2.12.1. Bids shall remain valid for a period of 180 days from the date of Deadline for Submission of Bids specified in Sub-Clause 2.15.

## **2.13 Format and Signing of Bids**

- 2.13.1. The bidder shall provide one electronic copy of the Technical and Financial proposals on EFL's electronic tender hosting website; <https://www.tenderlink.com/efl>
- 2.13.2. The bid shall contain no alterations, omissions or additions, except those to comply with instructions issued by EFL, or as necessary to correct errors made by the bidder, in which case such corrections shall be initialled by the person or persons signing the bid.

## **2.14 Sealing and Marking of Bids**

- 2.14.1. Bidders are to submit bid via Tender link Portal.

## **2.15 Deadline for Submission of Bids**

- 2.15.1. Bids must be received by EFL at the address specified above no later than 1600 hours (Fiji Time) 4/03/26.
- 2.15.2. EFL may, at its discretion, extend the deadline for submission of bids by issuing an addendum, in which case all rights and obligations of EFL and the bidders previously subject to the original deadline will thereafter be subject to the deadlines extended.

## **2.16 Late Bids**

- 2.16.1. Any bid received by EFL after the deadline for submission of bids prescribed above will be rejected.

## **2.17 Modification and Withdrawal of Bids**

- 2.17.1. The bidder may modify or withdraw its bid after bid submission, provided that written notice of the modification or withdrawal is received by EFL prior to the deadline for submission of bids.
- 2.17.2. No bid may be modified by the bidder after the deadline for submission of bids.

## **2.18 Rejection of one or all Bids**

- 2.18.1. EFL reserves the right to accept or reject any bid, and to annul the bidding process and reject all bids, at any time prior to award of Contract, without thereby incurring any liability to the affected bidder or bidders or any obligation to inform the affected bidder or bidders of the grounds for the rejection.

## **2.19 Process to be Confidential**

- 2.19.1. Information relating to the examination, clarification, evaluation and comparison of bids and recommendations for the award of a contract shall not be disclosed to bidders or any other persons not officially concerned with such process.
- 2.19.2. Any effort by a bidder to influence EFL's processing of bids or award decisions may result in the rejection of the bidder's bid.
- 2.19.3. Lowest bid will not necessarily be accepted as the successful bid.

## **2.20 Clarification of Bids**

- 2.20.1. To assist in the examination, evaluation and comparison of bids, EFL may, at its discretion, ask any bidder for clarification of its bid. The request for clarification and the response shall be in writing, but no change in the price or substance of the bid shall be sought, offered or permitted except as required to confirm the correction of arithmetic errors discovered by EFL in the evaluation of the bids in.

## **2.21 Preliminary Examination**

- 2.21.1. Energy Fiji Limited (EFL) will examine the tenders to determine whether they are complete, whether any computational errors have been made, whether the documents have been properly signed, and whether the tenders are generally in order.
- 2.21.2. Arithmetical errors will be rectified on the following basis. If there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail, and the total price shall be corrected. If the tenderer does not accept the correction of the errors, its tender will be rejected. If there is a discrepancy between words and figures, the amount in words will prevail.
- 2.21.3. Energy Fiji Limited may waive any minor informality or non-conformity or irregularity in a tender which does not constitute a material deviation, provided such waiver does not prejudice or affect the relative ranking of any tenderer.
- 2.21.4. Prior to the detailed evaluation, pursuant to Clause 21, Energy Fiji Limited will determine the substantial responsiveness of each tender to the tender document. For purposes of these paragraphs, a substantially responsive tender is one, which conforms to all the terms and conditions of the tender document without material deviation Energy Fiji Limited's determination of a tender's responsiveness is to be based on the contents of the tender itself without recourse to extrinsic evidence.
- 2.21.5. If a tender is not substantially responsive, it will be rejected by Energy Fiji Limited and may not subsequently be made responsive by the tenderer by correction of the nonconformity. Any incomplete or missing price submission in the bid document may make the bid non-compliant.

## **3.0 GENERAL CONDITIONS OF CONTRACT**

### **3.1 General Conditions**

Energy Fiji Limited uses Federation Internationale Des Ingenieurs Conseil (FIDIC) Contract template. General conditions of this contract shall be governed by it.

### **3.2 Definitions**

3.2.1. In this Contract, the following terms shall be interpreted as indicated:

- “The Contract” means the agreement entered into between Energy Fiji Limited and the Supplier, as recorded in the Contract Form signed by the parties, including all attachments and appendices thereto and all documents incorporated by reference therein.
- “The Contract Price” means the price payable to the Supplier under the Contract for the full and proper performance of its contractual obligations.
- “The Supplier” means the individual or firm supplying the goods under this Contract.
- “The Goods” means all of the equipment, machinery, and/or other materials, which the Supplier is required to supply to Energy Fiji Limited under this Contract.

### **3.3 Application**

3.3.1. These General Conditions shall apply in all Contracts made by Energy Fiji Limited for the procurement of goods.

### **3.4 Country of Origin**

3.4.1. For purposes of this Clause, “origin” means the place where the Goods were manufactured or produced.

3.4.2. The origin of the Goods is distinct from the nationality of the Supplier.

### **3.5 Standards**

3.5.1. The Goods supplied under this Contract shall conform to the standards mentioned in the Technical Specifications.

### **3.6 Use of Contract Documents and Information**

3.6.1. The Supplier shall not, without Energy Fiji Limited’s prior written consent, disclose the Contract, or any provision thereof, or any specification, plan, drawing, pattern, sample, or

information furnished by or on behalf of Energy Fiji Limited in connection therewith, to any person other than a person employed by the Supplier in the performance of the Contract.

- 3.6.2. The Supplier shall not, without Energy Fiji Limited's prior written consent, make use of any document or information enumerated in Clause 3.2 above.
- 3.6.3. Any document, other than the Contract itself, enumerated in Clause 3.2 shall remain the property of Energy Fiji Limited and shall be returned (all copies) to Energy Fiji Limited on completion of the Supplier's performance obligations under the Contract if so required by Energy Fiji Limited.

### **3.7 Performance Bond**

- 3.7.1. Not Applicable

### **3.8 Programme to be Furnished**

- 3.8.1. Within 20 days of the acceptance of this tender the Contractor shall submit to the Employer, for approval, a programme showing the order in which he proposes to carry out the works, including design, manufacture and delivery.

### **3.9 Inspection and Tests**

- 3.9.1. The Employer's Engineer or his representative shall have the right to inspect and/or to witness test the Goods at the factory or place of manufacture, for their conformity to the Contract Specifications. A full Factory Acceptance (FAT) Test is mandatory. The Employer shall notify the Contractor in writing of the identity of its Engineer(s) or representative(s) retained for these purposes. The contractor shall provide the Employer with a detailed program for the inspections and/or witness tests and notice of at least 7 days of notice when the materials, equipment, system is ready for inspection & testing. Nothing in this clause shall in any way release the Contractor from any warranty or other obligations under this Contract in delivering a fully functional plant as specified elsewhere in this document or the contractors' design and specifications.

### **3.10 Patent Rights**

- 3.10.1. The Supplier shall indemnify Energy Fiji Limited against all third-party claims of infringement of patent, trademark, or industrial design rights arising from use of the Goods or any part thereof in Fiji.

### **3.11 Packing**

- 3.11.1. The Supplier shall provide such packing of the Goods as is required to prevent their damage or deterioration during transit to their final destination, as indicated in the Contract.
- 3.11.2. The packing, marking, and documentation within and outside the packages shall comply strictly with such special requirements as shall be expressly provided for in the Contract.

### **3.12 Delivery and Documents**

- 3.12.1. Delivery of the Goods shall be made by the Supplier in accordance with the terms specified by Energy Fiji Limited in its Schedule of Requirements and the Special Conditions of Contract.
- 3.12.2. The supplier shall provide Sea Freight Charges and Incoterms.

### **3.13 Insurance**

- 3.13.1. The contractor shall provide for 100% insurance cover for the equipment supply, transport and contractor's personnel, including third-party liabilities and Contractors All Risk (CAR) insurance for the equipment scope and consequential damage insurance to existing facilities due to contractor activity/negligence. They shall include the Employer and their representatives as co-insured and hold them harmless from all liabilities and claims.

### **3.14 Warranty**

- 3.14.1. The Supplier warrants that the Goods supplied under the Contract are new, unused, of the most recent or current models and they incorporate all recent improvements in design and materials unless provided otherwise in the Contract. The Supplier further warrants that all Goods supplied under this Contract shall have no defect, arising from design, materials, workmanship, or from any act or omission of the Supplier, that may develop under normal use of the supplied Goods in the conditions prevailing in the country.
- 3.14.2. This warranty shall remain valid for minimum of **twelve (12) months** after the Goods, or any portion thereof as the case may be, have been delivered to and accepted at the final destination indicated in the Contract.
- 3.14.3. Energy Fiji Limited shall promptly notify the Supplier in writing of any claims arising under this warranty.
- 3.14.4. Upon receipt of such notice, the Supplier shall, within a period of 30 days, and with all reasonable speed, repair or replace the defective Goods or parts thereof, without costs to Energy Fiji Limited.
- 3.14.5. If the Supplier, having been notified, fails to remedy the defect(s) within the period specified in 3.14.4 above, within a reasonable period, Energy Fiji Limited may proceed to take such remedial action as may be necessary, at the Supplier's risk and expense and without prejudice to any other rights which Energy Fiji Limited may have against the Supplier under the Contract.

### **3.15 Payment**

- 3.15.1. The method and conditions of payment to be made to the Supplier under this Contract shall be specified in Special Conditions of Contract.
- 3.15.2. Payments shall be made promptly by Energy Fiji Limited as specified in the Contract.

### **3.16 Prices**

- 3.16.1. Prices charged by the Supplier for Goods delivered under the Contract shall not, with the exception of any price adjustments authorized in Special Conditions of Contract, vary from the prices quoted by the Supplier in its tender.

### **3.17 Assignment**

- 3.17.1. The Supplier shall not assign, in whole or in part, its obligations to perform under this Contract, except with Energy Fiji Limited's prior written consent.

### **3.18 Subcontracts**

- 3.18.1. The Supplier shall notify Energy Fiji Limited in writing of all subcontracts awarded under this Contract if not already specified in the tender. Such notification, in the original tender or later, shall not relieve the Supplier from any liability or obligation under the Contract.

### **3.19 Termination for Default**

- 3.19.1. Energy Fiji Limited may, without prejudice to any other remedy for breach of Contract, by written notice of default sent to the Supplier, terminate this Contract in whole or in part:
- a) If the Supplier fails to deliver the Goods within the period(s) specified in the Contract, or within any extension thereof granted by Energy Fiji Limited.
  - b) If the Supplier fails to perform any other obligation(s) under the Contract.
  - c) If the Supplier, in the judgment of Energy Fiji Limited has engaged in corrupt or fraudulent practices in competing for or in executing the Contract.
- 3.19.2. In the event Energy Fiji Limited terminates the Contract in whole or in part, it may procure, upon such terms and in such manner, as it deems appropriate, Goods similar to those undelivered, and the Supplier shall be liable to Energy Fiji Limited for any excess costs for such Goods.

### **3.20 Liquidated Damages**

- 3.20.1. If the Supplier fails to deliver the Goods within the period(s) specified in the Contract, Energy Fiji Limited shall claim for Liquidated Damages, without prejudice to its other remedies under the Contract.

### **3.21 Resolution of Disputes**

- 3.21.1. Energy Fiji Limited and the Supplier shall make every effort to resolve amicably by direct informal negotiation any disagreement or dispute arising between them under or in connection with the Contract.
- 3.21.2. If, after thirty (30) days from the commencement of such informal negotiations both parties have been unable to resolve amicably a Contract dispute, either party may require that the dispute be referred for resolution to formal mechanisms. These mechanisms include, but are not restricted to, conciliation by a third party, adjudication in an agreed national or international forum, and/or international arbitration.

**3.22 Language and Law**

3.22.1. The language of the Contract and the law governing the Contract shall be English language and the Laws of Fiji respectively unless otherwise stated.

**3.23 Force Majeure**

The Supplier shall not be liable for forfeiture of termination for default if and to the extent that it's delay in performance or other failure to perform its obligations under the Contract is the result of an event of Force Majeure.

**3.24 Schedule of Requirements**

Schedule	Description of materials
A	Supply of 8 x 1MW Containerized Prime Rating Diesel Generators For EFL Power Stations

**Schedule on performance to be completed by all Bidders.**

Past performance of delivery of similar items.

Item No.	Types of Diesel Generator Set	Name of Company delivered to	Date of Order	Delivery Time	Fully or partial or not delivered

## **4.0 SPECIAL CONDITIONS OF CONTRACT**

### **4.1 Definitions**

“The Purchaser” is Energy Fiji Limited, 2 Marlow Street, Private Mail Bag, Suva, and includes its legal representatives, successors or assigns.

### **4.2 Application**

The following Special Conditions of Contract shall supplement the General Conditions of Contract. Whenever there is a conflict, the provisions herein shall prevail over those in the General Conditions of Contract.

### **4.3 Proof of Successful Completion of Previous Similar Contracts**

Tenderers shall provide proof of successful completion within the stipulated delivery period of similar contracts undertaken in the past.

### **4.4 Delivery Period**

The Generators shall be delivered within **12 Weeks** after the date of contract award. Delivery must be for a complete schedule. Partial delivery shall not be accepted.

### **4.5 Payment Terms and Conditions**

Energy Fiji Limited’s payment terms are 30 days upon receipt of certified invoices and delivery notes confirming that the invoiced material has been delivered and are in accordance with the contract. Payment shall be made for the amount of contract.

### **4.6 Advance Payment**

Any advance payment will require a bank guarantee.

### **4.7 Prices**

Prices shall be fixed during the Supplier’s performance of the Contract and not subject to variation on any account.

## **5.0 TECHNICAL SPECIFICATION**

### **5.1 Information to Tenders**

The contract includes for the Supply of 8 x 1MW Containerized Prime Rating Diesel Generators for EFL Power Stations.

The contract also includes:

- (i) Two (2) print copies of Operating, Servicing and Maintenance Manuals. A set of printed Spare Parts Manuals. Additionally, a softcopy of all the Manuals to be provided.
- (ii) One set of diagnostics software with required equipment e.g., Laptop, software, license and connecting cables.
- (iii) Any necessary erection materials including a complete set of special tools and equipment necessary to erect, operate, service and maintain the Genset.
- (iv) A list and price of spare parts for operating and maintaining the Plant up to 8,000 hrs, to include but not limited to the following:
  - Normal maintenance spares for engines and all other auxiliaries
  - Emergency and safety spares for engine and all other auxiliaries
  - General and special tools for engine and all other auxiliaries
  - Test and calibration tools for engine and all other controls and auxiliaries
  - Cleaning/reconditioning/remanufacturing tools for engine components and auxiliaries
  - Machine shop tools
  - Duplicates of software/programs, licenses, software keys, passwords, etc. supplied in this contract shall be hand over and shall form part of the completed installation.
- (v) Detailed design calculations, specifications and drawings used in the contract.

#### **5.1.1 Information with Tender**

Tenders must fill in all Schedules and give all particulars pertaining to the Diesel Generating Plant offered.

In particular, they shall supply the following in their tender:

- a) Preliminary performance schedule, which shall form the basis of the contract performance program.
- b) Drawings showing all dimensions of the complete Diesel Generating Plant.
- c) Drawings or Schedules showing the shipping dimensions and weights.
- d) One copy in the English Language of the Design Codes to which the tenderer elects to design the Diesel Generating Plant and its ancillaries.
- e) A list of recommended maintenance, safety, and emergency spares for engines and auxiliary equipment for a service period of 8,000 hrs with all prices quoted. Other parts, tools and equipment specified in clause 5.1.

A maintenance programme in terms of machine operating hours, indicating when minor and major maintenance, such as oil change periods, filter changes, protection tests, top overhauls and major overhauls, are to be carried out. The programme should also include the spare parts anticipated to be changed and the time and manpower required to carry out the work.

## **5.1.2 Drawing and Information to be supplied by Contractor.**

### **5.1.2.1 The following must be submitted with the tender:**

- (i) General arrangements for the plant, giving dimensions, weights and basic specifications of diesel engine and generator and other equipment.
- (ii) Illustrations and printed matter showing constructional details and details of instrumentation, protection and accessories.
- (iii) Life cycle cost calculations.
- (iv) Preliminary Project Schedule.
- (v) List of spare parts, tools, diagnostic & calibration tools instruments and other equipment necessary to carry out maintenance, overhauls, inspections, and repairs expeditiously.
- (vi) Special tools list and spare parts list with pricing required for operation and maintenance

### **5.1.2.2 The following drawings are to be submitted with the contract, in printed and electronic/AutoCAD formats:**

- (i) Certified general arrangement drawings showing all fittings and accessories provided and including dimensions and weights and the specifications for diesel engines, generator and accessories.
- (ii) Electrical and instrument diagrams showing the local/auto start, stop and output control circuit and the protection, instrument systems, auto voltage and governor controls.
- (iii) Excitation System and AVR detailed drawings.
- (iv) Governor details (Type, Model, Block diagram and optional droop settings if any).
- (v) Combined Instrumentation and piping diagram with operational parameters.
- (vi) Certification of all the final design calculations, drawings and evidence of compliance to such design parameters.

### **5.1.2.3 Submission of Drawing**

All drawings submitted pursuant to this clause, shall form part of the contract, after approval by the Engineer. The sequence of submission of all drawings shall be such that all information is available for checking each drawing when it is received.

Notation on drawings shall be in the English language.

## **5.1.3 Design and Standardisation**

The generating plants together with its auxiliaries shall be designed and manufactured to ensure:

- (i) Satisfactory operation under prevailing atmospheric conditions at the site.
- (ii) Safety of operation and maintenance personnel.
- (iii) Facilitate economical, easy and simple inspection, maintenance and operations

#### **5.1.4 Tools and Instruments**

The Contractor shall supply all special tools and instruments which may be necessary to carry out the installation, commissioning, operation maintenance, overhauls, inspections and repairs expeditiously, for all the equipment supplied through this contract. These tools and instruments should cover:

- Normal maintenance, emergency, and insurance spares for engines and auxiliary equipment.
- General and special tools for engine, auxiliary mechanical & electrical equipment.
- Testing and calibration tools for control & instrumentation on engine, mechanical and electrical equipment.
- Computer programs (Software/hardware) used in the operation, monitoring, setting and /or maintenance of all the equipment supplied through this contract

Exceptions and items required but not supplied must be highlighted along with the current market rate for each of such items. Unless the Employer has granted any relief or exemption, the contractor is expected to include all such tools and instruments in the bid price. List of such tools and instruments should be provided with the Tender with their unit prices.

#### **5.1.5 Provision for Handling the Plant**

All heavy parts of the plant supplied under the contract shall have provisions for lifting, slinging and handling during delivery, erection, maintenance and overhauls. A legible name plate indicating the safe limits shall be prominently displayed where possible.

#### **5.1.6 Packing**

All material and equipment are to be packed to be transported to the site so that they are protected against climatic conditions and handling to which they may be subjected to in transit and storage at the site.

Spare parts or components supplied shall be individually and suitably preserved, packed and sealed to withstand tropical weather conditions. The packing shall be sufficient to withstand, rough handling during transit and exposure to extreme temperatures, salt, high humidity and precipitation during transit and open or prolonged storage. Preservation chemicals/agents may be employed to ensure that goods delivered are received in good shape and that they can be stored for long durations without fear of corrosion or contamination.

All markings within the inside and on the outside of casings or packaging are to be either of a water proof ink, material or protected by Shellac or varnish to protect obliteration in transit, handling and storage.

#### **5.1.7 Insurance**

The Tenderer shall deliver the complete equipment supply, Delivered Duty Unpaid to the transfer point identified in the Tender specification.

## 5.2 Scope of Work

The scope of work to be carried out under the terms of this specification comprises the Supply of 8 x 1MW Containerized Prime Rating Diesel Generating sets at 0.8 PF lagging, 415 Volt Output, complete with all necessary mechanical and electrical auxiliaries including but not limited to, excitation equipment, cooling system, engine alarm control panel - both local and provisions for remote starting, metering and instrumentation, generator alternator and engine protection, engine auxiliary drives and associated controls, an integrated 1000 Liters Fuel Vertical Day Tank, Fuel Tank External breather with rain cap and isolation valve, Electronic Automatic Fuel Valve for filling, Visible Fuel Tank Level Indicator, A Capped Manual Fill Point, Internal Drain Points, and 1.5m Exhaust flanged pipe with Exhaust Lid (Flap Type), Fuel Cooler Assembly on radiator and associated piping, Engine Crankcase breather outlet.

Failure to meet the Scope requirements will render the tender bid as non-compliant.

EFL has mainly Containerized 1MW High Speed Cummins KTA50-G3 Gensets with Stamford Alternators.

For general long-term maintenance and operations requirements, similar setup units are preferred.

## 5.3 Design Requirements

The work performed and equipment offered to this specification shall have a proven track record of satisfactory service in similar applications under site conditions, similar or more severe than those specified herein. The contractor shall provide a detailed schedule of each of the equipment having met the required design criteria and standards and include deviations from the current standards used in the design. The decision of the Employer in certifying and acceptance of the result shall be one of the main factors in evaluation and certifying completion of the contractor's performance and settling the payments due to the contractor for the performance.

The specification provided in the tender document is for guidance; however, the contractor is allowed to improve on such conditions and indicate in the tender documents if the intent of such deviations establishes that the products provided are equal to or better than what is mentioned in the tender document.

## 5.4 Reference Conditions

The following environmental conditions are applicable to this site.

- i. Elevation above mean sea level
  - 100 meters
  
- ii. Ambient air temperature
  - Design Temperature           45 °C
  - Minimum                           15 °C
  
- iii. Relative Humidity
  - Maximum relative humidity   95%
  - Minimum relative humidity   70%

iv. Seismic Condition

- All equipment shall be capable of withstanding an acceleration of 3.3 m/sec<sup>2</sup> in any direction without sustaining any damage.

The temperature of the fresh water supply is always less than 30°C at the site. The following is an analysis of the supply water available:

pH	8.3
Alkalinity	mg CaCO <sub>3</sub> B/Ltr 68.2
Chloride	mg/Ltr 7.3
Sulphate	mg SO <sub>4</sub> B/Ltr 8.4
Free CO <sub>2</sub> B	mg/Ltr 0.62
Temporary Hardness	mg/Ltr 3.6
Permanent Hardness	mg/Ltr 64.0
Total Hardness	mg CaCO <sub>3</sub> B/Ltr 68.2
Total suspension solids	mg/Ltr < 1
Total dissolved solids	mg/ltr 126

## 5.5 Capacity and Rating

### 5.5.1 Genset Capacity

The net maximum continuous site rated capacity of the generating plant shall not be less than 1MW (e) at the specified reference conditions and 0.8 power factor lagging. The output shall be 3 phase and 415 Volts at 50 Hertz.

The net maximum continuous site rated capacity of the diesel generating Genset shall be defined as the electrical output available at the alternator output terminals LESS the sum of rated full load electrical power requirements of all auxiliaries.

### 5.5.2 Rating

The maximum continuous and short time rating of the alternator at the specified site conditions shall comply with AS1359 and shall be sufficient to enable the maximum continuous site rated capacity and overload capacity of the gen set to be obtained at the specified reference conditions.

The continuous and overload rating of the diesel engine shall be in accordance with ISO 3046 Part I and shall be sufficient to enable specified maximum continuous rated capacity and overload capacity of the Genset to be obtained at the specified reference conditions in accordance with the adjustment provisions of ISO 3046 Part I.

In determining the ratings of individual items of the equipment, reference shall be taken of the conditions at the Power Station as specified in clause 5.4.

## 5.6 Plant Layout Requirements

### 5.6.1 Safety Aspects

All items of the equipment shall inherently be designed for safe operation, and the plant shall be designed such that, the plant may be operated in compliance with the Health and Safety Act Work Act 1996 of the Republic of Fiji, or existing OHS regulations in Australia/New Zealand.

## **5.7 Control**

All panels, cubicles, mountings, instruments, protective devices, control equipment and connections necessary for the safe, convenient and reliable operation of the generating plant and for effective fault indication shall be provided and installed. Effective dissipation of heat generated by components shall be provided.

Where appropriate, solid state electrical circuitry is preferred. Relays shall be of the plug-in type, fitted with retaining clips and provided with adequate dust covers. Relays shall have a reliability of operation appropriate to the application.

All control components shall be clearly identified and labeled in accordance with a scheme. Cable identification shall be of the slip on type sized to fit neatly over the cables.

Indication of the status of the control system shall be displayed on the diesel generator control board (and duplicated as specified at the remote control panel).

The control system shall disable operation of the generating units under fault conditions.

### **5.7.1 Control System**

A control system shall be provided to enable control of the diesel generating unit, through start, run, load, unload and stop, to be exercised from engine room or control room and this control mode shall be defined as local control.

**The following Control Mode should be available for Mode of Operation for the Generator;**

- I. MW Mode for Base Loading
- II. Droop Mode for Remote Control of these Generator as they be controlled from our remote Control Centre. Provision for remote raise and lower of Speed and Voltage should be provided in this mode of operation.
- III. Isochronous Control Mode for Frequency Control.

### **5.7.2 Diagnostic Software**

The generator shall be provided with an effective tool for diagnosing problems of the engine and ability to configure system parameters. This shall allow access to the Electronic Control Modules with a communication adapter to connect to ECM.

### **5.7.3 Generator Protection**

Generator Warning & shutdowns shall be required for;

- (i) Warning/shutdown with indication for:
  - Low oil pressure
  - High coolant temperature
  - Over speed
  - Emergency stop
  - Failure to start (over crank)
  - Low coolant temperature

- Low coolant level
- (ii) Programmable protective relaying functions include:
  - Generator phase sequence
  - Over/Under voltage
  - Over/Under Frequency
  - Reverse Power (KW)
  - Reverse reactive power (KVAR)
  - Overcurrent

All protection must comply to Standard Planning Data for Synchronous Generators and filled in.

#### **5.7.4 Generator Circuit Breaker**

Circuit Breaker must be a withdrawable type such as **ABB and Schneider Models** with rating of **2500** Amperes.

### **5.8 Diesel Engine and Auxiliary Equipment**

#### **5.8.1 Compliance**

The diesel engine shall operate satisfactorily on the fuel oil as specified and generally in accordance to ISO 3046, unless specified otherwise. The diesel engine shall be equipped with all ancillary equipment required to satisfactorily achieve the required performance under the specified site conditions.

Generator shall be provided with following installation for protection and safety of machine:

- (i) Generator system;
  - Anti-condensation space heaters
  - Coastal Insulation protection
- (ii) Charging system;
  - 24 volts, 45 amps charging alternator
  - Battery disconnection switch
  - Battery charger

#### **5.8.2 Engine Governing**

The engine shall be provided with an electronic controlled actuator/governor having programmable provisions/adjustment of droop, speed synchronizing, load sharing and limiting, and isochronous operation and synchronizing indications.

For engine speed control, it shall be set up for direct-acting operation whereby a loss or interruption of electrical/electronic signal, the fuel shutoff valve will shut off fuel and cause engine shutdown.

The governor shall be capable of parallel operation with other Gensets within the power plant.

The governing requirements must comply with ISO 3046, class M2, the genset to comply with ISO 8528-5, class G2.

### 5.8.3 Engine combustion air system and Silencer

Exhaust gas driven turbochargers are to be provided. The turbocharger rotor shall be statically and dynamically balanced to ensure a smooth and vibration free operation.

The generator supplied must be weather and soundproof to meet noise level: 50Hz – 85dBA @5m @80% Load. A 'critical grade' silencing is required.

### 5.8.4 Engine Fuel Oil System

Specification of Industrial Diesel Fuel available for use is as follows:

Characteristic	Clear and Bright at Ambient Temp	Test Method	Average of last 12 months
Colour	4.0 max.	D1500	2.0
Density @ 15°C (Kg /m <sup>3</sup> )	920 max.	D1298/D4052	851.0
Ash (% by mass)	0.01 max.	D482	< 0.01
Carbon residue	0.2 max.	D189/D4530	< 0.20
Cetane number	35 min.	D613	-
Cetane index	35 min.	D4737	54
Cold filter plugging point (°C)	11 max.	IP309	9
Flash point (°C)	65 min.	D93	80
Sulphur (% by mass)	1.0 max.	IP336	0.45
Water (% by volume)	0.1 max.	D95	0.07
Sediment (% by mass)	0.02 max.	D473	< 0.02
Viscosity @ 40°C (mm <sup>2</sup> / s)	1.8 - 5.8	D445	3.1
Neutralisation Value (Strong Acid #) (MgKOH/g )	nil	D664/D974	nil
Conductivity @ 23°C (Ex refinery) (pS/m )	100 - 450	D2624	200
Conductivity @ 23°C (Within terminal) (pS/m)	70 - 450		-

### 5.8.5 Engine Lubrication Oil System

- a) The engine shall be equipped with a positive pressure forced-feed lubrication system to all moving parts of the engine. There shall be no moving part which requires manual lubrication whilst in operation. The engine lubricating oil system pressurising pump shall be attached to and driven from the engine. It shall be of the positive displacement type and shall be equipped with a pressure relief valve (with provisions to adjust the pressure) to regulate oil pressure at the engine bearings and to prevent a build-up of excessive pressure within the system
- b) Provisions to check the oil level with a graduated dipstick while engine is running should be provided.
- c) If the engine sump is wet type a sump drain facility shall be provided with positive locking against accidental opening. A high and low oil level shall be provided on the oil sump to allow

shutting down of generating set in case of very low oil level and very high oil level due to fuel or water leakage into oil sump.

- d) The engine shall be fitted with full flow type lubricating oil filters. The Tenderer is required to specify the type of lubricating oil filter recommended with its economic justification. PetroOceania, Pacific Energy, and Total presently provide lubrication oil in Fiji. Tenderer is asked to specify at least one type of recommended lubrication oil.

#### **5.8.6 Instruments & Protection**

All engine sensors, gauges; automation/instrumentation shall be mounted/located in a manner allowing ease of access for service, testing, maintenance, troubleshooting and replacement of faulty components. Mounting of control panels and terminal boxes on the engine shall be extremely minimal and where it cannot be avoided, they shall be fitted with vibration mounts. Instrumentation and Control wires/cables as well as connection plugs and terminations to be used shall be double insulated and additional measures taken to avoid damage caused by excessive heat and vibration. Sufficient spare plugs, terminal lugs, and/or jackets shall be provided.

#### **5.8.7 Local engine instrumentation should include at a minimum:**

- a) Lubricating oil temperature
- b) Lubricating oil pressure
- c) Coolant temperature
- d) Water outlet pressure
- e) Cylinder exhaust temperature.
- f) Operating hours
- g) System DC volts
- h) AC Volts, phase, Hz and Kilowatt Hour
- i) Indication to identify when the normal/mains source is supplying and one to indicate when the standby set is online. Also provide indication for both normal and standby source availability.

#### **5.8.8 Engine shutdowns shall be required for:**

- a) Coolant Water outlet temperature high
- b) Alternator bearing temperature high.
- c) Engine lubricating oil pressure low.
- d) Engine lubricating oil temperature high.
- e) Radiator water level low
- f) High oil sump level
- g) Low oil sump level
- h) Over speed trip (Electrical, which shall be set lower than mechanical overspeed).
- i) Electrical fault which is a group alarm for differential fault on the generator.
- j) Emergency stop both local and remote.
- k) Control supply failed.
- l) Over Cranking

### **5.8.9 On the operation of any one of the above Protection:**

- a) The engine should shut down completely.
- b) The generator circuit breaker should trip and display C/B open remote alarm.
- c) Data logging with time sequence of all alarms.

To avoid the engine restarting when the trip is reset, the engine override shutdown timer should be locked out to the desired stop down time.

In addition, a provision must be available for remote engine shutdown as per above list.

### **5.9 Engine Protection (Electrical)**

The engine shall be fitted with all protection devices necessary to ensure safe operation of the engine under the specified operating conditions. Such devices shall, where applicable, be integrated with other protection devices specified.

The following protection equipment is a minimum requirement. However, the tenderer shall also include any additional items deemed necessary to satisfy the requirements of this section.

- a) Overspeed Trip
  - The engine shall be provided with an over-speed trip which shall operate independently of the normal speed governor and shall act directly upon the supply fuel to the engine. Operation of the over-speed trip shall also operate auxiliary contacts for the initiation of all alarms and for switchgear tripping
- b) Low lubricating oil pressure shutdown
  - The engine shall be provided with a mechanically operated device which shall operate independently of normal speed governor and shall act directly upon the engine fuel supply. Operation of this trip shall also operate auxiliary contacts for the initiation of all alarms and for switchgear tripping. The setting pressure of the device shall be much lower than the electrically operated device but above the safe operational requirements.
- c) High coolant temperature
- d) Low coolant Level
- e) Failure to start (over crank)
- f) Emergency stop

### **5.10 Engine Crankcase Ventilation**

The engines shall be equipped with an engine crankcase breather or condensation trap, together with associated electrics, valves and pipe work to effectively condense lubricating oil fumes so that no lubricating oil is discharged outside the power station.

### **5.11 Engine Exhaust System**

The engine shall be provided with an exhaust system comprising steel exhaust piping, expansion bellows, exhaust silencers and all necessary hangers and supports for a horizontal mounted arrangement. The exhaust piping shall be of thick-walled steel sized in accordance with the engine manufacturer's requirements.

### **5.12 Engine Cooling System**

- a) The engine shall be water cooled. The radiators shall be engine mounted and cooling fan engine driven. EFL also prefers for a Remote Radiator package be provided. The radiators shall be of the heavy duty and pressurised type protected for humid and salt air conditions and shall be designed with adequate core cooling capacity. The radiators shall have a cooling capacity under the specified site conditions of 40 °C, sufficient to adequately satisfy the cooling requirements of the diesel engine operating at 100% of continuous site rating. In the design of the radiator, an allowance of not less than 20% shall be made for reduction in heat transfer capacity by fouling. Sizing calculations are to be provided with engineering submittals. Coolant water conditioning system shall be provided to adequately maintain cool water chemistry.
- b) A thermostatically controlled diverting device shall be installed in the cooling water circuit to maintain the temperature of the water entering the engine jacket at the required level and to facilitate rapid warming up of the engine during start up.
- c) All rigid piping shall have provisions to absorb shock and vibration caused by the engine while running.

### **5.13 Automatic Voltage Regulator Panel**

A separate free standing panel or a panel incorporate within the control panel with anti-vibration mountings to house a Thyristor divert Automatic Voltage Regulator (or manufacturers standard), with a field circuit breaker (if required) and associated instruments and indications as listed below are required:

- a) Generator volts
- b) Field volts
- c) Divert current
- d) Field current
- e) Field circuit breaker trip indicator

**Note:** A separate field suppression switch will be required if an alternative Automatic Voltage Regulator is used. The Contractor will have to supply information on the type and make of the automatic voltage regulator and provide the installation details.

### **5.14 Alternator, Excitation and Changeover Switching**

#### **5.14.1 Alternator**

- a) The alternator shall be flexibly connected to the prime mover. The alternator covers and vent openings shall have screens to protect any foreign objects from entry. The main rotor shall be of a rotating field type fitted with damper windings and should be self-ventilated.

- b) The alternator offered shall be suitable for parallel operation with other generators in the National grid. The phase rotation of the existing plant is Red, Yellow, Blue or A, B, C.
- c) Windings shall be star connected with both ends of each winding brought out to separate terminals for external star connection for appropriate neutral earthing resistor and isolator. Suitably sized switchgear and resistor shall be provided. The Neutral earthing system supplied shall be designed in manner that overheating of the resistor or associated connection accessories due to harmonics or load unbalance is minimized.
- d) Output voltage must be 415V
- e) Each phase winding shall incorporate positive temperature coefficient thermistor for over temperature detection
- f) A terminal box shall be fitted to the stator frame to enclose the winding and thermistor terminals. The terminal box shall be suitable for right angle termination of main cables in the alternator on either side of the stator.
- g) The alternator frame earthing shall be external to the terminal box or to a suitable location within stator frame.
- h) The Stator and Rotor windings shall be insulated to Class F standard or higher.
- i) The wave form of the output voltage shall be sinusoidal for the full range of loads and power factors and should comply to AS1359. The zero sequence reactance of the alternator shall not exceed 30%.
- j) Winding temperature rise above reference conditions shall remain within the limits stated in AS1359 under specified load and a 1-hour overload condition. The rotor shall be statically balanced and remain in dynamic balance up to 125% of rated speed.

#### **5.14.2 Excitation**

If the alternator is provided with a direct coupled shunt wound exciter, adequate access to the brush gear for inspection and maintenance shall be provided.

A Brushless type excitation is preferred that is fitted with protection for the diodes. Diode failure indication shall be provided and the machine shall continue to operate in the event of a single diode failure. Excitation transformer shall be protected by fuse and located in the alternator pit. It may be oil or air insulated.

Preference will be given to a dynamic excitation system.

Windings shall be insulated to Class H standard or higher with tropicalization and anti-abrasion.

Provisions for the connection of automatic field suppression shall be provided.

#### **5.14.3 Voltage Regulation**

- a) The regulated voltage shall remain within  $\pm 1.5\%$  of the set value under all specified steady load conditions for frequencies between 46 and 54 hertz. The engine-generator shall be able to operate on-load without limitation on the above-specified frequencies as per condition specified in (d) below.
- b) The output voltage shall be adjustable within  $\pm 10\%$  of nominal.
- c) The regulated voltage shall be taken as the average of phase to neutral RMS voltages of the three windings excluding cases where the current ratio between highest and lowest phases exceeds 2:1.
- d) Under the condition of sudden application of (Specify Maximum Allowed) xx% rated load or the removal of full load, the voltage shall remain within a minimum of  $\pm 7\%$  and a maximum of  $\pm 10\%$  of the set value with 99% recovery effected within 0.5 seconds and full recovery within

- 1 second for frequencies between 46 and 54 Hertz. Tenderer shall provide performance test results of proposed equipment impact loading/load rejection capability.
- e) The Contractor could provide, if possible, a value better than the above voltage regulation.
  - f) The maximum deviation in voltage shall conform to the requirements of IEC34.
  - g) Additional manual field regulation shall be provided with the selector and controls mounted on the front of the AVR panel (if available).
  - h) Voltage regulation equipment shall be suitable for parallel operation of alternators in the Fiji National Grid.
  - i) Equivalent characteristics for voltage regulation must be provided with a clear statement describing the type of voltage regulation offered so that reactive power loading can be shared equally or as desired between the existing generators and the one offered.
  - j) Control, Protection and Monitoring requirements are specified elsewhere. Alternator output shall collapse on short circuiting the output terminals in a manner which operates the protection relays.
  - k) Set voltage shall be re-established within 2 seconds of removing the short circuit. The differences in phase to neutral voltages for an out of balance loading between any two phases should not exceed  $\pm 2.15\%$  of nominal voltage.
  - l) On start-up, with automatic voltage control on and with a resistive load of 30% rated capacity applied to the output voltage, regulation shall be achieved within 3 seconds of the genset reaching a shaft speed corresponding to 46 Hz.

## **5.15 Other Electrical Components**

### **5.15.1 Design Standards for Electrical Plant**

All electrical components shall be designed for continuous operation when the plant is operating at full rated output under the conditions specified. Design standard for electrical works shall be IEC

Except for the Alternator and Exciter, the electrical components and cables shall be selected such that, under full rated plant output, the current and voltage conditions for the components do not exceed 80% of the manufacturer's safe working rating.

The temperature rise of the air within the enclosed cubicles shall not exceed 30°C at the full rated output at the specified reference conditions. The IEC Wiring Regulations shall apply to all electrical works. All capacitors used, shall be designed to withstand 2.5 times the test voltage for 1 minute at its rated values. Electrolytic capacitors could only be used in printed circuit boards according to the design.

Note: Synchronising facilities for parallel operation of the generating plant should be provided with installation. Provision for generating plant to close on dead bus should be provided.

All circuit components shall have provisions for testing, fault tracing and shall have Test/Disconnect terminal blocks with relevant drawings.

## **5.16 Wiring, Cable and Connections**

All wiring work shall be carried out neatly to the satisfaction of the Employer and in accordance with the SAA regulations or better.

Insulation shall be non-flammable, non-hygroscopic, fungus resistant and shall not be affected by normal plant operating temperatures or by oils and lubricants.

Insulation resistance shall not be less than 100 MΩ at a voltage which is the greater than 500 V dc or equivalent to a DC voltage equal to twice the peak working voltage.

Wiring for control and monitoring system shall be colour coded PVC insulated complete with wire numbers inserted and enclosed in "galvanised screwed conduits" terminating in terminal boxes. The connections should also be water tight.

#### **5.16.1 Cable size**

The minimum cable size shall be:

- a) Control Wiring, 1.5 mm<sup>2</sup>
- b) Power Wiring, 2.5 mm<sup>2</sup>

A copper Busbar or multi strand soft drawn copper cable shall be used where the cross sectional area of conductor exceeds 95 mm<sup>2</sup>.

Wiring terminations shall be identified according to the wiring diagrams and the conductors shall be securely clamped in approved terminal blocks by means of self-locking screwed clamps.

Any High voltage cables used shall be XLPE and armoured with steel wire.

#### **5.16.2 Training**

The contractor shall provide on-site training for up to 4 persons nominated by the Employer in the correct operation of plant installed for a period of one week prior to preliminary site testing of the gensets is completed. The tenderer shall include this training cost in their proposal.

Operating and Maintenance Manuals as specified shall be made available by the contractor before such training is commenced.

### **5.17 Testing and Commissioning**

#### **5.17.1 General Requirements**

The Contractor shall be responsible for performing all required tests, including the provision of materials, test equipment, measuring equipment and any specific arrangements that may be deemed necessary by the Employer to achieve the testing required with the exception of the supply and cost of fuel, electricity and water required for site preliminary and acceptance tests. The required tests are specified in the following sections of this specification.

#### **5.17.2 The Testing programme shall generally consist of:**

- a) Tests prior to delivery to the site. Such tests are intended to ensure no faulty or unsuitable items are delivered to site.
- b) Preliminary tests at site for individual and assembled components. Such tests shall demonstrate the ability of components to perform their designed function in accordance with the Specification and performance.
- c) Commissioning tests on the completed installation. Such tests shall demonstrate that the performance of the installation that meets the Specification and guaranteed performances.

The sequence of tests shall be subject to the prior approval of the Employer. The proposed programme of tests shall be submitted to the Employer at least 6 weeks before the commencement of the commissioning tests. The Contractor shall perform any additional tests that the Employer may deem necessary to satisfy that the plant complies with the Specification.

All tests shall be performed in the presence of and to the satisfaction of the Employer or nominated representative. The limits of accuracy shall be as specified in ISO 3046/111. The results of all tests shall be recorded and certified by the Contractor and copies of the certified results delivered to the Employer within 2 weeks of the completion of the tests.

Defects revealed during testing shall be rectified at the Contractor's expense and the tests subsequently repeated until all defects are eliminated. Live load shall be available at the site to provide suitable loading conditions at the time of testing. The frequency of measurements proposed during the tests shall be subject to an agreement by the Employer in advance.

A regulatory certificate and approval required for the installation and equipment shall be obtained by the Contractor on the Employer's behalf and supplied to the Employer prior to operation of that equipment

**4.17.3 The TEST for the generating plant shall comprise:**

- a) A general inspection of the equipment to check its compliance with the specified requirements.
- b) Measurement of the cold resistance of the electrical windings.
- c) Determination of the alternator opens circuit and short circuit characteristics.
- d) Pre-starting and start-up procedures, alarm and shutdown tests, synchronising tests and engine compression tests.
- e) A continuous trial sequence shall be performed on site.
- f) Generator Circuit Breaker Closer on Dead Bus and load up

At the above mentioned loads, all the parameters listed in the local instrumentation and those in remote engine control panel shall be monitored. The accuracy of the measurements shall be as in ISO 3046. In addition, the specific fuel consumption and the specific lubricating oil consumption shall be calculated and provided with the tender document.

**5.18 Commissioning Tests**

**5.18.1 The test shall consist of (if applicable):**

- a) Inspection and verification of the complete plant to determine the overall compliance, correctness of all adjustments and settings, operational suitability of the installation against the specified requirements and shall include checking the tightness of all connections and fastening devices.
- b) Verification of the correctness of operation of all protection devices and systems, including the related relative sensors settings. Induced faults imposed to simulate the responses shall be as close as possible to the actual fault conditions.
- c) During the continuous trial the following parameters shall be measured at intervals not exceeding 30 minutes.
  - (i) Alternator output, KW or KVA.
  - (ii) Alternator output voltage
  - (iii) Alternator output current and Temperatures

- (iv) Alternator output frequency
  - (v) Power Factor
  - (vi) Exciter voltage
  - (vii) Exciter current
  - (viii) Engine parameters as specified
  - (ix) Fuel consumption
- d) Verification of the correctness of operation of all starting, synchronising, paralleling, stopping control systems and dead bus closing both automatic and manual.
- e) Verification of compliance with the total harmonic distortions as specified.
- f) Verification of specific fuel and specific lubricating oil consumption.
- g) Verification of the operation of the changeover switching, both automatic and manual. The following must be confirmed:
- (i) On mains failure, supply be restored from the standby set
  - (ii) Standby set is running and mains is restored
  - (iii) Supply restored via mains, standby set goes in cool down mode
  - (iv) Fail mains again and ensure standby set picks up from cool down mode

The Contractor shall carry out such further tests as the Employer may require to satisfy the Contractor's installation meets all the specified requirements.

If the condition of components inspected is considered unsatisfactory by the Employer, necessary remedial action shall be taken by the Contractor and the appropriate test repeated until satisfactory results are obtained. All such work shall be at the expense of the Contractor.

## **5.19 Spare Parts**

The tenderer shall provide a guarantee from the Manufacturers that all spare parts, materials and components used in all the equipment supplied in this tender shall be available for procurement for a period of 10 years after the equipment has been successfully commissioned and accepted by the Employer.

## 6.0 DELIVERABLES

### 6.1 Schedule 1 - Technical Particulars

1. **Tender's Name:**

\_\_\_\_\_

2. **Diesel Generator Plants**

2.1. Make of Engine/s \_\_\_\_\_

Type of Engine/s \_\_\_\_\_

Year of Manufacture \_\_\_\_\_

Make of Alternator \_\_\_\_\_

Type of Alternator \_\_\_\_\_

Rated Speed (rpm) \_\_\_\_\_

2.2. Engine/s manufactured by and Country \_\_\_\_\_

Alternator/s manufacture and Country \_\_\_\_\_

2.3. Continuous/standby rated output at Alternator terminals:

(i) ISO 3046/1 Conditions \_\_\_\_\_

(ii) At specified site conditions \_\_\_\_\_

3. **Fuel Consumption Guarantee**

(i) Based on fuel oil having a net calorific value of 42,700 kJ/kg and specific gravity of 0.84 at ISO 3046/1 conditions in kJ/kWh e, net plant:

% of Full Load	Specific Fuel Consumption in Kg/kwh electrical Output for fuel type specified
	Net kg/kWh measured at alternator terminals
75	
85	
100	

(ii) 0% Tolerance in above consumption at rated load per ISO 3046/1

#### 4. Lubricating Oil Consumption Guarantee

(i) Lubricating oil consumption

% of Full Load	Specific Lubricating Oil Consumption Litres/kWh
100	

(ii) 0% Tolerance in above lube oil consumption at 100% load

#### 5. Ancillary Power

The continuous/standby net site rating should be measured with all the electrical driven engine ancillaries and auxiliaries when the diesel generating plant is operating at maximum continuous rating.

#### 6. Engine governor

- (i) Manufacturer \_\_\_\_\_
- (ii) Model \_\_\_\_\_
- (iii) Type \_\_\_\_\_
- (iv) Conforms to Class a Regulations [Yes / No]  
If no, please specify \_\_\_\_\_
- (v) Is the load control motor  
24V dc, 3 wire system [Yes / No]  
If no, please specify \_\_\_\_\_

#### 7. Installation Data

- (i) Overall Dimensions of the plant  
Length \_\_\_\_\_ mm  
Width \_\_\_\_\_ mm  
Height \_\_\_\_\_ mm
- (ii) Total weight of engine and alternator \_\_\_\_\_ kg
- (iii) Minimum turning radius for the assembled plant \_\_\_\_\_ mm
- (iv) Weight of heaviest part to be lifted for:  
Installation \_\_\_\_\_ kg  
Maintenance \_\_\_\_\_ kg
- (v) Minimum recommended clear access space for operation and/or maintenance at:  
Free end of engine \_\_\_\_\_ mm

Sides of plant \_\_\_\_\_ mm

Excitor end of plant \_\_\_\_\_ mm

(vi) Type of installation selected i.e. solidly mounted or with a combined under base:

\_\_\_\_\_

## 8. Vibration Characteristics

8.1. Anti-Vibration Mounting (if applicable)

(i) Make and type \_\_\_\_\_

(ii) Number per genset \_\_\_\_\_

(iii) Isolation efficiency over a range of frequencies (%) \_\_\_\_\_

## 9. Diesel Engine

9.1. Specification

(i) Number of cylinders \_\_\_\_\_

(ii) Bore \_\_\_\_\_ mm

(iii) Stroke \_\_\_\_\_ mm

(iv) Speed \_\_\_\_\_ rpm

(v) Type of aspiration \_\_\_\_\_

(vi) I.S.O. Standard Power at ISO 3046/1 conditions (MW) \_\_\_\_\_

(vii) Recommended lubricating oil \_\_\_\_\_

(viii) Method of starting \_\_\_\_\_

## 10. Alternator

(i) Type \_\_\_\_\_

(ii) Make \_\_\_\_\_

(iii) Maximum continuous rating:

• \_\_\_\_\_ KW at U.PF

• \_\_\_\_\_ KW at 0.8 PF

(iv) Rated Voltage \_\_\_\_\_ KV

(v) Rated Frequency \_\_\_\_\_ Hz

- (vi) Full rated load current \_\_\_\_\_ Amps
- (vii) State compliance to what Standard to which the alternator is made and tested

\_\_\_\_\_

- (viii) Insulation class of:

- Rotor \_\_\_\_\_
- Stator \_\_\_\_\_

- (ix) Temperature rise:

- At max continuous rating \_\_\_\_\_ °C
- After 10% overload for one hour \_\_\_\_\_ °C

- (x) Efficiencies

% of Maximum Continuous Rating	Efficiency at Unity pf	Efficiency at 0.8 pf
100		
90		
80		
70		
60		
50		

- (xi) Voltage wave form on open circuit:

- (Ph - Ph) \_\_\_\_\_ Volts
- (Ph - N) \_\_\_\_\_ Volts
- Amplitude of 3<sup>rd</sup> Harmonics \_\_\_\_\_
- Amplitude of 5<sup>th</sup> Harmonics \_\_\_\_\_
- Amplitude of 7<sup>th</sup> Harmonics \_\_\_\_\_
- Amplitude of 9<sup>th</sup> Harmonics \_\_\_\_\_
- Amplitude of 11<sup>th</sup> Harmonics \_\_\_\_\_
- Amplitude of 13<sup>th</sup> Harmonics \_\_\_\_\_

- (xii) Inherent Regulation at rated voltage at:

- unity pf \_\_\_\_\_
- 0.8 pf \_\_\_\_\_

- (xiii) Reactance

- Reactance at full rated voltage \_\_\_\_\_

- Leakage reactance  $X_L$  \_\_\_\_\_
- Direct axis synchronous reactance  $X_d$  \_\_\_\_\_
- Quadrature axis synchronous reactance  $X_q$  \_\_\_\_\_
- Direct axis transient reactance  $X'd$  \_\_\_\_\_
- Direct axis sub-transient reactance  $X''d$  \_\_\_\_\_
- Quadrature axis sub-transient reactance  $X''q$  \_\_\_\_\_
- Negative phase sequence reactance  $X_2$  \_\_\_\_\_
- Zero phase sequence reactance  $X_0$  \_\_\_\_\_

(xiv) Time Constants

- Direct axis transient open circuit  $T'do$  \_\_\_\_\_
- Direct axis transient short circuit  $T'd$  \_\_\_\_\_
- Direct axis transient sub transient short circuit  $T''d$  \_\_\_\_\_

(xv) Characteristic Curves

Tenderer to enclose following:

- 1) Manufacturer's Generator Characteristic Curves showing:
  - a. Open Circuit Saturation
  - b. Short Circuit Saturation
  - c. Air Gap Line
  - d. Rated Current Saturation at 0.8 pf
- 2) V-Curves at rated voltage
- 3) Capability Curves at rated voltage.

(xvi) Characteristic Curves

(xvii) Excitation current at max continuous generator output amps

(xviii) Type and make of stator winding temperature monitoring device

□ Range \_\_\_\_\_ °C to \_\_\_\_\_ °C □ Accuracy \_\_\_\_\_ ± \_\_\_\_\_ °C

**11. Excitor**

- (i) Make and type \_\_\_\_\_
- (ii) Type of Enclosure \_\_\_\_\_
- (iii) Rated output \_\_\_\_\_ Amps \_\_\_\_\_ Volts
- (iv) Maximum voltage \_\_\_\_\_
- (v) Class of Insulation \_\_\_\_\_

(vi) Alternator Noise

Frequency Hz	163	125	250	500	1000	2000	4000	8000	<b>Total</b>
Sound dB(A)									

(vii) Excitor winding Temperature rise at maximum continuous rating \_\_\_\_\_ °C

**12. Automatic Voltage Regulator**

- (i) Make and type \_\_\_\_\_
- (ii) Regulated voltage range under all specified steady load conditions for frequencies between 46 and 54 hertz. \_\_\_\_\_ to \_\_\_\_\_ volts.
- (iii) Does the voltage remain within a minimum of  $\pm 7\%$  and a maximum of  $\pm 10\%$  of the set value with 99% recovery effected within 0.5 seconds and full recovery within 1 second with a sudden application of 60% of full load. [Yes / No]

If No, please specify \_\_\_\_\_

- (v) Does the voltage remain within a minimum of  $\pm 7\%$  and a maximum of  $\pm 10\%$  of the set value with 99% recovery effected within 0.5 seconds and full recovery within 1 second with a sudden removal of 100% load. [Yes / No]

If No, please specify \_\_\_\_\_

- (vi) Does the maximum deviation in voltage conform to the requirements of AS1359. [Yes / No]

If No, please specify \_\_\_\_\_

- (vii) Is a manual field regulation provided with the selector and controls mounted on the front of the AVR panel.

[Yes / No]

If No, please specify \_\_\_\_\_

- (viii) Is voltage regulation equipment suitable for parallel operation of alternators

[Yes / No]

If No, please specify \_\_\_\_\_

- (ix) Does the regulation equipment have the following:
- Droop adjustment [ Yes / No]
  - Voltage level adjustment [ Yes / No]
  - Gain setting control [ Yes / No]
  - Stabilising quality control [ Yes / No]
- (iv) Does the alternator output collapse on short circuiting the output terminals in a manner which operates the over current, differential, reverse power and earth fault protection relays.  
[Yes / No]
- (v) Can the Set voltage be re-established within 2 seconds of removing the short circuit (as in 7.0 I above).  
[ Yes / No]
- (vi) What is the percentage difference in phase to neutral voltage for an out of balance loading between any two phases:  $\pm$  \_\_\_\_\_ % of nominal voltage.
- (vii) Can voltage regulation be achieved within 3 seconds of the genset reaching a shaft speed corresponding to 46 Hz upon starting with a resistive load of 30%?  
[ Yes / No]  
If No, please specify \_\_\_\_\_

### 13. Engine Protection Devices

- (i) Are there any provisions for the termination of remote alarms for:
- Low lubricating oil pressure [ Yes / No]
  - Low fuel pressure [ Yes / No]
  - High Cooling water temperature [ Yes / No]
  - High Lubricating oil temperature [ Yes / No]
  - Engine overspeed [ Yes / No]
  - High & low sump level [ Yes / No]

### 14. Instrumentation

- (i) Are the following Engine monitoring provided at the engine control and alarm panel:
- Cooling water pressure inlet [ Yes / No]
  - Cooling water temperature inlet [ Yes / No]
  - Lube oil pressure [ Yes / No]

- Lube oil temperature inlet [ Yes / No]
- Engine speed indicator [ Yes / No]
- Alternator Winding temperature with switch [ Yes / No]
- Alternator hot air temperature [ Yes / No]
- Cylinder Exhaust temperature [ Yes / No]

(ii) Are the following Alternator monitoring parameters provided at the engine common control desk and for remote metering:

- Generator MW [ Yes / No]
- Generator Mar [ Yes / No]
- Generator Field current [ Yes / No]
- Generator Output Volts [ Yes / No]
- Generator Output Amps [ Yes / No]
- Generator Output Power Factor [ Yes / No]
- Generator Output Frequency [ Yes / No]

### 15. Engine Starting System

(i) Type of engine starting system together with any technical advantages.

---

---

### 16. Turbocharger

- (i) Make \_\_\_\_\_
- (ii) Type \_\_\_\_\_
- (iii) Maximum speed \_\_\_\_\_ rpm
- (iv) Maximum operating temperature \_\_\_\_\_ °C
- (v) Boost pressure ratio \_\_\_\_\_ kPa
- (vi) Type of vibration level monitoring device provided \_\_\_\_\_
- 

### 17. Air Intake System

(i) Air Intake Filter

- Make and type \_\_\_\_\_
- Smallest particle allowed to pass through the filter \_\_\_\_\_ microns
- Pressure loss across filter \_\_\_\_\_ kPa
- Is a Service Indicator provided [ Yes / No ]

**18. Fuel System**

(i) Fuel Water/Separator

- Make and model \_\_\_\_\_
- Efficiency \_\_\_\_\_ %

(ii) Fuel Flow Meter

- Make and model \_\_\_\_\_
- Flow rate range \_\_\_\_\_ to \_\_\_\_\_ m/s
- Pressure drop across the flow meter at engine full rated load \_\_\_\_\_ kPa
- Accuracy of flow meter ± \_\_\_\_\_ % (iii) Engine Fuel

Supply Filter (Primary/Secondary)

- Make and Type \_\_\_\_\_
- Pressure drop across filter at engine full rated load \_\_\_\_\_ kPa
- Degree filtration \_\_\_\_\_ microns
- Are service indicators provided [ Yes / No ]

(iii) Day Tank

- 1000 Litres Vertical Day Tank Installed [ Yes / No ]
- Manual Fill Point with Rain Cap [ Yes / No ]
- Day Tank Breather pipe with Rain Cap [ Yes / No ]
- Electronic Automatic Fill Valve [ Yes / No ]
- Visible Day Tank Indicator [ Yes / No ]

**19. Lubricating Oil System**

(i) Type of Engine Lubricating Oil \_\_\_\_\_ (ii)

Are Full Flow Lubricating Oil Filters provided [ Yes / No ]

□ Degree of filtration \_\_\_\_\_ microns

(iii) Are Bypass Lubricating Oil Filters provided [ Yes / No ]

- Degree of filtration \_\_\_\_\_ microns
- Are differential pressure gauges provided [ Yes / No ]
- Is there any provision to extend the differential pressure set points to the engine common alarm panel [ Yes / No ]

**20. Engine Exhaust System**

(i) Silencers attenuation rating \_\_\_\_\_ dBA

- Temperature Monitoring Unit \_\_\_\_\_
- Make and Type \_\_\_\_\_
- Range \_\_\_\_\_ to \_\_\_\_\_ °C
- Accuracy ± \_\_\_\_\_ %

### 21. Engine Crankcase Extraction

- (i) Are there any local Crankcase pressure indicators [ Yes / No ]
- (ii) What are the safety devices for preventing a build-up of excessive crankcase pressure.

---

---

### 22. Engine Cooling System

- (i) Engine Cooling Radiator

- Type \_\_\_\_\_
- System pressure \_\_\_\_\_ KPa

- (ii) Fuel Cooler

- a. Fuel Cooler Module Included [ Yes / No ]
- b. Fuel Cooler Piping Installed [ Yes / No ]

- (iii) Radiator System has protective coating for Tropical climate [ Yes / No ]  
Details to be provided.



### **8.0 SCHEDULE 3 SPECIAL TOOLS ETC.**

The tenderer shall list full details of all special tools, fixtures, appliances or test equipment required to operate, service and maintain the Gensets and auxiliary equipment offered (mechanical, electrical and electronic systems in the tender) over the 8,000hour service life listed above.

<b>Item (Tool etc)</b>	<b>Function</b>

### **9.0 SCHEDULE 4 – DEVIATIONS**

The tenderer shall list below all deviations from the specifications and tender document.

Where no such deviation from specification is listed, full compliance with specification will be required.

Description of Item	Unit	Recommended Qty	Rate ExW	Total Cost

Specification Clause #	Deviation	Justification

## **10.0 SCHEDULE 5 OVERHAUL AND EXPECTED LIFE TIME OF COMPONENTS**

<b>Component</b>	<b>Time Between Overhauls Hours</b>	<b>Expected Life Time Hours</b>
Piston		
Cylinder Liner		
Cylinder Head		
Inlet Valve		
Exhaust Valve		
Injector Nozzle		
Injector Pump		
Main Bearing		
Large End Bearing		
Turbocharger		
<b>(Addition Parts)...</b>		

## **11.0 SCHEDULE 6 MAINTENANCE SCHEDULE IN TERMS OF MACHINE HOURS**

Provide a detailed maintenance program in terms of machine operating hours, indicating when servicing and replacing of parts is required along with expected labour hours for each task. The schedule should include the spare parts that are anticipated to be replaced, time required to carry out the task and the manpower requirements. Assume 90% loading, 8,000 hours per year operation over a 5-year time period. All spare parts prices should be for new parts, delivered EX Works. If a remanufactured parts program is available, separate alternative life cycle costs schedules should be provided along with clear conditions/terms/warranty for remanufactured components.

## **12.0 PRICE SCHEDULE**

### **Supply of 8 x 1MW Containerized Prime Rating Diesel Generators For EFL Power Stations**

	<b>Description</b>	<b>Unit Price (\$)</b>	<b>Total: \$ (VEP)</b> Currency: _____
1	Supply of 1MW(e)(1250KVA) at 0.8pf, 415V, 50Hz three phase Containerized Prime Diesel generating set with auxiliaries and Synchronizing Generator Circuit Breaker (as per 5.7.4) Generator Make/Model: _____		
2	Freight and Transportation Cost		
3	Two (2) sets of Hardcopy & Softcopies for Spare parts manuals, Operation & Maintenance manuals, drawings, design & technical information required for site installation, software, and other documentation as per tender		
4	One (1) set of diagnostics software with required equipment e.g., Laptop, connecting cables		
5	Factory Acceptance Test (FAT)		
6	Commissioning and Training		
7	Delivery Duration: _____ Weeks. Refer to Notes 1 below for delay in supply.		
	<b>TOTAL PRICE (VEP)</b>		
	<b>TOTAL (VIP)</b>		
	<b>Warranty Duration (In months or running hours)</b>		

Please specify currency (FJD, USD, AUD, NZD)

**Notes:**

1. **Liquidated Damages for Delay in Supply:** 0.25% per day of the **Contract Price** up to a maximum of 5% of **Contract Price** which is payable to EFL by the Supplier for any delays in delivery of the Gensets to EFL.
2. Technical:
  - a. The bids must as per the Technical Specifications in the Tender Documents. Bids that do not conform to the technical Specification will be disqualified
  - b. Tenderers shall provide proof of successful completion within the stipulated delivery period of similar contracts undertaken in the past.
  - c. Documentary evidence to prove that the items offered comply with the Technical Specification must be provided.
  - d. Contractor to verify all drawing measurements onsite.
  - e. The Supplier/ Contractor shall provide a warrants for Goods or services for provided unless stated otherwise.

- f. EFL's Engineer or his representative shall have the right to inspect and/or to witness test the Goods at the factory or place of manufacture, for their conformity to the specifications
    - g. The Goods supplied under this Contract shall conform to the standards mentioned in the Technical Specifications
  3. Financial:
    - a. In case of discrepancy between unit and total cost, the unit cost shall prevail
    - b. Any advance payment will require a bank guarantee. And this added cost will be beared by bidder
    - c. The currency used in the tender bid prices must be indicated in the tender bid
    - d. Prices shall be fixed during the Supplier's performance of the Contract and not subject to variation on any account.
    - e. EFL financial terms are applicable for these works.
    - f. For Foreign Supplier, any On-Shore work with incur a withholding Tax of 15% e.g. commissioning, training etc.
  4. EFL Energy Fiji Limited uses Federation Internationale Des Ingenieurs Conseil (FIDIC) Contract template. General conditions of this contract shall be governed by it.
  5. EFL have right to spilt award, tender may be awarded to multiple suppliers. And Minimum order quantity (MOQ) will not be acceptable.
  6. All clarification requests must be sent 5 days prior to the deadline for submission of bids
  7. Price Schedule must be typed and stamped on the bid submission.
  8. Failure to submit required documents may affect bid compliance. Failure to submit mandatory items as stated in Compliance Checklist will result in non-compliance.
  9. Contractor shall provide all materials, tools equipment and labour necessary to perform works.
  10. A detailed work plan to be provided with expected date for the works.
  11. Installation & Commissioning works must incorporate all cost incur for this activity e.g. travel, accommodation, visa etc.
  12. All Sub-contractors to be used for any part of the works are to be declared.

**12.1 Compliance Checklist Declaration**

I \_\_\_\_\_ of \_\_\_\_\_ located at \_\_\_\_\_ confirm that the bid submitted for the following tender MR 15/2026 : Supply of 8 x 1MW Containerized Prime Rating Diesel Generators For EFL Power Stations bid complies with the mandatory bidder submission as stated in Sub Clause 2.6;

	Yes	No	Details
<b>Commercial</b>			
Price Schedule			
Company Profile			
Detailed Scope of Work/Supply			
Program [preferred Gantt Chart] State Duration of Supply in Weeks			
Payment Terms			
Price Validity [ <b>180 days</b> ]			
Withholding Tax Inclusion (If Applicable)			
<b>Technical</b>			
Company’s capabilities (resources, staff cv, etc.)			
Past Project/ Experience submission			
Warranty on Works			
Technical Specification for Generator Unit			
Technical Specification for Controller Unit			
Technical Specification for Circuit Breaker Unit (Refer to 5.7.4)			
Technical Specification for Alternator Unit			
Technical Specification for Auxiliaries, Fuel Tank, Exhaust, Fuel Cooler & Containerized unit			
<b>Scope of Supply</b>			
Statement of Exclusion or Amendment for Tender Specification (if Any)			
Generator as per specification			
Synchronizer with a Generator Circuit Breaker(5.7.4)			
Warranty Duration (In months or running hours)			

**Liquidated Damages for Delay in Supply – 0.25% per day** of the **Contract Price** up to a maximum of 5% of **Contract Price** which is payable to EFL by the Supplier for any delay(s) in delivery of the Gensets to EFL.

Note that these submissions are mandatory submission for a successful tender bid. This declaration must be signed and submitted as well.

Name: \_\_\_\_\_

Position: \_\_\_\_\_

Company: \_\_\_\_\_

Sign Off: \_\_\_\_\_

Date: \_\_\_\_\_

## 12.2 Tender Check List

***The Bidders must ensure that the details and documentation mention below must be submitted as part of their tender Bid***

Tender Number \_\_\_\_\_

Tender Name \_\_\_\_\_

1. Full Company / Business Name: \_\_\_\_\_

**(Attach copy of Registration Certificate)**

2. Director/Owner(s): \_\_\_\_\_

3. Postal Address: \_\_\_\_\_

4. Phone Contact: \_\_\_\_\_

5. Fax Number: \_\_\_\_\_

6. Email address: \_\_\_\_\_

7. Office Location: \_\_\_\_\_

8. TIN Number: \_\_\_\_\_

**(Attach copy of the VAT/TIN Registration Certificate - Local Bidders Only (Mandatory))**

9. FNPf Employer Registration Number: \_\_\_\_\_ **(For Local Bidders only) (Mandatory)**

10. **Provide a copy of Valid FNPf Compliance Certificate (Mandatory- Local Bidders only)**

11. **Provide a copy of Valid FRCS (Tax) Compliance Certificate (Mandatory Local Bidders only)**

12. **Provide a copy of Valid FNU Compliance Certificate (Mandatory Local Bidders only)**

13. Contact Person: \_\_\_\_\_

I declare that all the above information is correct.

Name: \_\_\_\_\_

Position: \_\_\_\_\_

Sign: \_\_\_\_\_

Date: \_\_\_\_\_

### 13.0 TENDER FORM

To: Jitendra Reddy  
Manager Procurement & Inventories  
Energy Fiji Limited  
2 Marlow Street,  
Suva,  
Fiji Islands  
Phone: +679 3224 360  
Email: [tenders@efl.com.fj](mailto:tenders@efl.com.fj)

Sir,

1. Having examined the Tender Document, the receipt of which is hereby duly acknowledged, we, the undersigned, offer to supply  
.....  
*(Description of Goods)* in conformity with the said Tender Document for the sum  
.....  
..... *(total tender amount in words and figures)* or such other sums as may be ascertained in accordance with the Schedule of Prices attached herewith and made part of this Tender.
2. We undertake, if our Tender is accepted, to deliver the Goods in accordance with the delivery schedule specified in the Schedule of Requirements.
4. We agree to abide by this Tender for a period of 90days from the date fixed for Tender opening under Clause 19 of the Instructions to Tenderers, and it shall remain binding upon us and may be accepted at any time before the expiration of that period.
5. Until a formal Contract is prepared and executed, this Tender, together with your written acceptance thereof and your notification of award, shall constitute a binding Contract between us.
6. We understand that you are not bound to accept the lowest or any Tender you may receive.

Dated this: \_\_\_\_\_ day of \_\_\_\_\_ 202\_.

*[Signature] [In the capacity of]*

Duly authorized to sign Tender for and on behalf of

## **14.0 SUBMISSION TO TENDER**

Bidders are requested to upload electronic copies via Tender Link by registering their interest at: <https://www.tenderlink.com/efl>

**EFL will not accept any hard copy submission to be dropped in the tender box at EFL Head Office in Suva.**

**This tender closes at 4.00pm (1600hrs) on Wednesday 4<sup>th</sup> March, 2026.**

For further information or clarification please contact our Supply Chain Office on phone (+679) 3224360 or (+679) 9992400 or email us on [tenders@efl.com.fj](mailto:tenders@efl.com.fj)

**The bidders must ensure that their bid is inclusive of all Taxes payable under Fiji Income Tax Act. Bidders are to clearly state the percentage of VAT that is applicable to the bid prices.**

The lowest bid will not necessarily be accepted as the successful bid.

**The Tender Bids particularly the “Price” must be typed and not hand written.**

**Any request for the extension of the closing date must be addressed to EFL in writing three (3) working days prior to the tender closing date.**

**Tender Submission via email or fax will not be accepted.**