


REFERENCE DRAWINGS:

SK-06	ADSS CONSTRUCTION SCHEDULE
SK-10	ADSS GEOGRAPHICAL PLAN
SK-12	ADSS PROJECT MATERIAL SCHEDULE

NOTES

- REFER TO MATERIAL SCHEDULE (SK-12) FOR THE RECOMMENDED STOCK CODE ITEM.
- GUYWIRE TO BE PRE-TENSIONED AT 10% OF CBL AND GUY TENSION TO BE CHECKED ONE MONTH AFTER TENSIONING.
- ALL MATERIALS TO BE HOT DIP GALVANISED TO AS4680 EXCEPT BOLTS AND BUTS WHICH ARE GALVANISED TO AS1214.

										CONTRACTOR				DESIGNED	KC	08.12.2020	PROJECT NAME				DRAWING No.			
														CHECKED	JD	08.12.2020	ADSS LINE DESIGN ON EXISTING 11kv LINE - EAST HONIARA				SK-17			
														DRAWN	KC	08.12.2020	PROJECT DESCRIPTION EASTERN NETWORK ADSS LINE DESIGN				DRAWING TITLE STAY POLE ASSEMBLY		PROJECT No.	
														CHECKED	JD	08.12.2020								
														APPROVED	IK	08.12.2020					SHEET		REVISION	
														A3		SCALE: AS SHOWN						A3		
AI	FOR CLIENT REVIEW						KC	JD	KC	JD	12.2020	PLOT DATE: May 06,2021 - 11:56am												
AMDT	AMENDMENT DETAIL						DESIGN	CHK'D	DRAWN	CHK'D	APP'D												DATE	