Annex A: Technical Compliance Schedule (to be completed by Supplier)

Clause	Requirement	Complies (Yes / No / Deviation)	Supplier's offered value / reference to data sheet
5.1	Standby rating 250–280 kVA, 415 V, 50 Hz, 0.8 PF		
5.1	Performance class and regulation		
5.2	Engine make, model, cooling, governor, emissions		
5.3	Alternator type, insulation, IP rating		
5.4	Enclosure, noise (dB(A) at stated distance), wind loading		
5.5	Fuel tank capacity, running time at 25/50/75/100% load, bunding		
5.6	Controller, metering, protections, alarms		
5.7	Batteries and charger		
5.8	Cabling		
5.9	Standards and certificates		
8	Testing and commissioning proposed		
9	Training and documentation		
10	Warranty terms and response times		
10.4	Local service and spares availability		